

SUPERSEDED BY:
Under Review AS/NZS 1462-10:1998+27

AS 1462.10-1984

STANDARDS ASSOCIATION OF AUSTRALIA

Australian Standard
METHODS OF TEST FOR UNPLASTICIZED PVC (UPVC)
PIPES AND FITTINGS

AS 1462.10
METHOD FOR PRESSURE TESTING OF
UPVC NON-PRESSURE FITTINGS

SECTION 1. SCOPE AND GENERAL

1.1 SCOPE. This standard sets out two methods for pressure testing of unplasticized PVC (UPVC) fittings for non-pressure applications, viz an hydrostatic test and an air/vacuum test.

1.2 REFERENCED DOCUMENT. The following standard is referred to in this standard:

AS 1349 Bourdon Tube Pressure and Vacuum Gauges.

1.3 RELEVANCE OF TEST. The hydrostatic test ensures that a fitting and/or its subcomponent is able to withstand a positive hydrostatic head, and the air/vacuum test determines the resistance to leakage and infiltration.

16 FEB 1984

