



Standards
Association of
Australia



Australian Standard[®]
2982—1987

LABORATORY CONSTRUCTION

This Australian Standard was prepared by Committee BD/46, Laboratory Construction—Safe Working Practice. It was approved on behalf of the Council of the Standards Association of Australia on 6 July 1987 and published on 3 August 1987.

The following interests are represented on Committee BD/46:

Australian Atomic Energy Commission
Australian Chemical Industry Council
Board of Fire Commissioners, New South Wales
Commonwealth Scientific and Industrial Research Organization
Department of Defence
Department of Health (Commonwealth)
Department of Science (Commonwealth)
Insurance Council of Australia
Metropolitan Fire Brigades Board, Melbourne
National Association of Australian State Road Authorities
National Association of Testing Authorities, Australia
National Building Technology Centre
Public Works Department, New South Wales
Railways of Australia Committee
Royal Australian Chemical Institutes
Royal Australian Institute of Architects

Review of Australian Standards. To keep abreast of progress in industry, Australian Standards are subject to periodic review and are kept up-to-date by the issue of amendments or new editions as necessary. It is important therefore that Standards users ensure that they are in possession of the latest edition, and any amendments thereto.

Full details of all SAA publications will be found in the Catalogue of SAA Publications; this information is supplemented each month by SAA's journal 'The Australian Standard', which subscribing members receive, and which gives details of new publications, new editions and amendments, and of withdrawn Standards.

Suggestions for improvements to Australian Standards, addressed to the head office of the Association, are welcomed. Notification of any inaccuracy or ambiguity found in an Australian Standard should be made without delay in order that the matter may be investigated and appropriate action taken.

This Standard was issued in draft form for comment as DR 82209.

PREFACE

This Standard was prepared by the Association's Committee on Laboratory Construction for Safe Working Practice.

Accidents in several laboratories in the middle 1960s caused at least two employers of scientists including the N.S.W. Public Service Board and CSIRO to produce codes applicable to the use of laboratories, and led to the establishment of a committee by the Standards Association of Australia to produce AS 2243, Safety in Laboratories. That committee (CH/26) also realized that a Standard dealing with *construction* was necessary to complement AS 2243 and a separate committee (BD/46) was formed to produce this Standard. Design and construction recommendations currently included in AS 2243 will be generally removed from that Standard at its next edition. They are now included in this Standard.

This Standard is intended to provide an authoritative source of information and guidance for the design and construction of laboratory buildings, based on considerations for the safety of workers occupying such buildings. It should not be regarded as a detailed design specification.

This Standard has no legal authority in its own right, but may acquire legal standing in the following circumstances:

- (a) Adoption by a Regulatory Authority having jurisdiction.
- (b) Adoption by an owner as a required standard of construction when placing a contract.

It is recommended that the design of a laboratory should incorporate those parts of this Standard which are applicable. The Standard may not need to be applied rigorously to small operations, such as one or two persons in a single room, but its principles should be observed.

Section 2 of this Standard has been drafted in mandatory form. Other sections are in partly mandatory and partly advisory form, depending on the committee's assessment of the importance of particular aspects.

This Standard should be used in conjunction with the various Australian Building Regulations and other regulations such as those on industrial safety, and with a number of other Australian Standards referenced in the Annex.

© Copyright — STANDARDS ASSOCIATION OF AUSTRALIA 1987

Users of Standards are reminded that copyright subsists in all SAA publications. Except where the Copyright Act otherwise allows, no part of this publication may be reproduced, stored in a retrieval system in any form or transmitted by any means without prior permission in writing of the Standards Association of Australia. Requests for permission should be directed to the Head Office of the Association. Where such requests relate to the reproduction of the whole or a substantial part of any Standard, permission may be conditional on an appropriate royalty payment.

CONTENTS

	<i>Page</i>
FOREWORD	5
SECTION 1. SCOPE AND GENERAL	
1.1 SCOPE	6
1.2 APPLICATION	6
1.3 REFERENCED DOCUMENTS	6
1.4 DEFINITIONS	6
1.5 PLANNING CONSIDERATIONS	8
SECTION 2. BUILDING REGULATORY MATTERS	
2.1 SCOPE OF SECTION	10
2.2 FIRE ISOLATION	10
2.3 MEANS OF EGRESS	11
2.4 FALSE CEILINGS	11
2.5 OPENINGS IN FLOORS AND CEILINGS	11
2.6 SURFACE FINISHES—EARLY FIRE HAZARD PROPERTIES	11
SECTION 3. BUILDING ADVISORY MATTERS	
3.1 SITING OF BUILDINGS	12
3.2 ACCESS	12
3.3 STRUCTURE AND DRAWINGS	12
3.4 PROTECTION AGAINST SUNLIGHT	12
3.5 SURFACE FINISHES—FUNCTIONAL PROPERTIES	12
3.6 BENCHES	12
3.7 FLOOR FINISHES	13
3.8 CHANGE ROOMS	13
3.9 FIRST AID FACILITIES	13
3.10 FUME CUPBOARDS	13
3.11 LUNCH AND REST ROOM	13
3.12 WASHING FACILITIES	13
3.13 NOTICES AND SIGNS	13
3.14 MAINTENANCE MANUAL	13
SECTION 4. RETICULATED SERVICES	
4.1 SCOPE OF SECTION	14
4.2 GENERAL REQUIREMENTS	14
4.3 ISOLATING DEVICE	14
4.4 GAS WATER HEATERS	14
4.5 RETICULATION FROM GAS CYLINDERS	14
4.6 VACUUM RETICULATION	14
4.7 HYDRAULIC SERVICES	14
4.8 SAFETY SHOWERS	14
SECTION 5. ELECTRICAL SERVICES	
5.1 STANDARDS AND REGULATIONS	14
5.2 LABORATORY POWER	14
5.3 EMERGENCY LIGHTING	14
SECTION 6. VENTILATION AND AIR TREATMENT	
6.1 GENERAL	15
6.2 MECHANICAL VENTILATION AND RECIRCULATION SYSTEMS	15
6.3 EXHAUST VENTILATION SYSTEMS	15

	<i>Page</i>
SECTION 7. ALARM SYSTEMS AND FIRE PROTECTION EQUIPMENT	
7.1 PORTABLE EXTINGUISHERS	17
7.2 HYDRANTS, HOSE REELS AND FIRE HOSE	17
7.3 AUTOMATIC FIRE SUPPRESSION SYSTEM	17
7.4 FIRE ALARM SYSTEMS	17
7.5 SPECIAL HAZARDS	17
7.6 AIR-HANDLING SYSTEM	17
7.7 MAINTENANCE	17
SECTION 8. SAFETY EQUIPMENT AND CERTIFICATION	
8.1 GENERAL	17
8.2 SAFETY SHOWERS	17
8.3 SAFETY NOTICE BOARDS	17
8.4 LABORATORY CERTIFICATION	17
SECTION 9. STORAGE OF HAZARDOUS SUBSTANCES	
9.1 FLAMMABLE LIQUIDS CABINETS	18
9.2 FLAMMABLE LIQUID STORES	18
9.3 COMPRESSED-GAS CYLINDERS	18
9.4 STORAGE AREAS FOR CORROSIVE MATERIAL	18
9.5 CHEMICAL STORAGE CUPBOARDS	19
9.6 SPECIAL STORAGE FACILITIES	19
9.7 STORAGE FOR SOLID AND LIQUID WASTES	19
SECTION 10. BIOLOGICAL LABORATORIES	
10.1 SCOPE AND APPLICATION OF SECTION	20
10.2 LABORATORY LAYOUT	20
10.3 INTERIOR SURFACES	20
10.4 LIGHTING FIXTURES	20
10.5 SAFE WORKING FACILITIES	20
10.6 VENTILATION	20
10.7 STERILIZATION	20
10.8 WASTE DISPOSAL	20
10.9 HANDWASHING AND CHANGE FACILITIES	20
10.10 LUNCH AND REST ROOM	21
10.11 ANIMAL HOUSE	21
SECTION 11. RADIOLOGICAL LABORATORIES	
11.1 SCOPE AND APPLICATION OF SECTION	22
11.2 GENERAL	22
11.3 CHANGE-ROOMS	22
11.4 LOW-LEVEL LABORATORIES	22
11.5 MEDIUM-LEVEL LABORATORIES	23
11.6 HIGH-LEVEL LABORATORIES	23
SECTION 12. SECONDARY SCHOOL LABORATORIES	
12.1 SCOPE AND APPLICATION OF SECTION	25
12.2 BUILDING CONSTRUCTION	25
12.3 RETICULATED SERVICES	25
12.4 ELECTRICAL SERVICES	25
12.5 VENTILATION AND HEATING	25
12.6 FIRE PROTECTION EQUIPMENT	25
12.7 CHEMICAL STORE	25
12.8 FLAMMABLE LIQUIDS STORAGE	25
APPENDIX A. LIST OF REFERENCED AND RELATED DOCUMENTS	
.....	26

FOREWORD

1 Laboratory hazards. Laboratories in general represent a higher potential hazard than most other occupancies, particularly to non-technical staff. Organizations responsible for commissioning and operating laboratories have an obligation to provide working environments that are basically safe, not only to their normal occupants, but to others who may enter such buildings. Each laboratory must therefore be designed, constructed, maintained and operated so as to reduce potential hazards to an acceptable level.

2 Safe working practice. A disregard for safe working practices can often negate the provisions for safety that are built into a workplace. It is therefore essential that workers follow safe working procedures in the course of their work. It is also necessary that persons with supervisory responsibility in a laboratory should ensure that staff under their control follow safe working practices. This Standard and the AS 2243 series* (which details the safe working practices that should be followed) are complementary.

3 Planning considerations. In the initial planning stage a brief should be prepared by the owner setting out in detail the work to be performed in the laboratory and the potential hazards involved (see Clause 1.5.1). In consultation with the designers of the laboratory, specifications should then be drawn up for the facilities and conditions needed to guard against these hazards, to enable a safe working environment to be provided and to protect the public. This Standard prescribes the facilities and conditions necessary to satisfy these requirements in the most commonly encountered laboratory situations.

4 Types of laboratories. This Standard is intended to apply to a wide range of different laboratories, it being recognized that common design principles apply to laboratories with quite different functions. Certain parts of this Standard apply particularly to the needs of chemical laboratories, but this does not exclude their relevance to other types.

Separate sections refer to the needs of biological laboratories, radiological laboratories and secondary school laboratories. These were included because of specific requests that they should be covered and because of the distinctive requirements that apply to such laboratories.

It is recognized that there are other types of laboratories which have distinctive requirements. If there are sufficient requests for other types of laboratories to be covered by this Standard, they may be included in a later edition.

5 Means of escape. Particular attention has been given to providing adequate means of escape from the building in the event of fire, containing the fire for a sufficient period to permit the evacuation of the occupants, to reducing the effects of fire, and to preventing its spread to other parts of the building.

6 Inspection and maintenance. Laboratories, after construction in accordance with this Standard, need to be inspected and maintained to ensure the specified level of performance throughout their working life, and to ensure the safety of the buildings and their occupants.

* AS 2243 Safety in Laboratories.
Part 1: General.
Part 2: Chemical.
Part 3: Microbiology.
Part 4: Ionizing Radiations.
Part 5: Non-ionizing Radiation.
Part 6: Mechanical Aspects.
Part 7: Electrical Aspects.
Part 8: Fume Cupboards.

STANDARDS ASSOCIATION OF AUSTRALIA

Australian Standard
LABORATORY CONSTRUCTION

SECTION 1. SCOPE AND GENERAL

1.1 SCOPE. This Standard sets out requirements relating to the design and construction of buildings which house laboratories, as defined in Clause 1.4.21. It applies both to new laboratories and where existing buildings are converted to laboratory use, or to a different type of laboratory use. Special sections are included for biological, radiological and secondary schools' laboratories.

The Standard is not intended to apply to those laboratories which do not contain significant hazards such as those referred to in Clause 1.5.2.

Section 2 specifies matters which are recommended for inclusion or reference in Building Regulations. The other sections are in the form of design specifications or advice.

NOTES:

1. This Standard is primarily related to those aspects of laboratory building design which relate to the safety of the occupants. Various construction requirements are detailed which are intended to minimize the hazards associated with laboratories.
2. Not all possible hazards are covered in this Standard, and thus care is needed to ensure that all the problems applying to a particular laboratory are considered in the planning stage.
3. The design and construction of fume cupboards is excluded from this Standard since this is covered by AS 2243.8, but those aspects of fume cupboard design which affect the ventilation of the laboratory are included.
4. The provisions written in mandatory form (see Clause 1.4.31) are those which must be observed by any organization claiming or certifying compliance of a laboratory with this Standard. (See Clause 8.4.1.)

1.2 APPLICATION.

1.2.1 Relationship with other regulations. This Standard in Section 2 gives specific building requirements for laboratories. These requirements are additional to those in the applicable general building regulations, but have no legislative effect unless and until applied through those regulations.

NOTES:

1. The following types of regulations may also apply to laboratories. All laboratories must be checked for compliance with relevant regulations, and certificates obtained as necessary.
 - (a) Health.
 - (b) Labour and industrial safety.
 - (c) Dangerous goods.
 - (d) Plumbing.
 - (e) Flammable liquids storage.
 - (f) Electrical.
2. Where parts of this Standard are more detailed or more stringent than the applicable regulations and are not in conflict with them, then such parts of this Standard should be adopted in the design of the laboratory building.

1.2.2 Changes of use. Where a change of use of a laboratory is proposed, its suitability for the intended use should be fully checked against this Standard, and any necessary modifications of the building implemented.

1.2.3 Review of air recirculation system. Where an air recirculation system has been installed, (see Clause 6.2) a re-evaluation of the system shall be carried out whenever changes to the laboratory use are proposed.

1.3 REFERENCED DOCUMENTS. The Standards referred to in this Standard and other relevant Standards and documents are listed in Appendix A.

1.4 DEFINITIONS. For the purpose of this Standard, the definitions below apply.

1.4.1 Air-handling system—a system for the purpose of providing air in a positive and controlled manner to specific enclosures by means of one or more air-handling plants, ducts, plenums, air-distribution devices and automatic controls.

NOTE: See AS 1668.2 for further definitions of types of air and air-handling systems.

1.4.2 Approved—approved by the local building authority or other relevant statutory authority.

1.4.3 Automatic fire suppression—the provision of the whole laboratory compartment and all sub-compartments, false ceiling spaces and similar permanent enclosures with either of the following:

- (a) An automatic water sprinkler system in accordance with the principles expressed in AS 2118.
- (b) Other approved fixed automatic fire detection and suppression system.

1.4.4 Contaminated (as applied to air)—containing harmful or hazardous concentrations of toxic, noxious, pathogenic, flammable, radioactive or other injurious matter, including dusts.

1.4.5 Corrosive—having the quality of damaging or destroying by direct chemical action. This also includes the effect of caustic substances.

1.4.6 Duct—either—

- (a) a component part of an air-handling system, intended for the passage of air from one part of an air-handling system to another; or
- (b) a shaft to carry reticulated services.

1.4.7 Exit—a building element consisting of any of the following:

- (a) An internal or external stairway.
- (b) A ramp.
- (c) A fire-isolated passageway.
- (d) A doorway opening to a road or open space.

The term also includes a combination of two or more such exits providing egress from a storey or a space in the nature of a storey to a road or open space.