

Australian Standard™

**Double-flanged butterfly valves for
waterworks purposes**

This Australian Standard was prepared by Committee WS-022, Valves for Water Supply Purposes. It was approved on behalf of the Council of Standards Australia on 16 November 2002 and published on 20 December 2002.

The following are represented on Committee WS-022:

Australian Industry Group
Australian Chamber of Commerce
Australian Valve Manufacturers Association
Master Plumbers Australia
Plastics Industry Pipe Association of Australia
Society of Mechanical Engineers of Australia
Water Industry Alliance
Water Services Association of Australia

Keeping Standards up-to-date

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about Standards can be found by visiting the Standards Australia web site at www.standards.com.au and looking up the relevant Standard in the on-line catalogue.

Alternatively, the printed Catalogue provides information current at 1 January each year, and the monthly magazine, *The Australian Standard*, has a full listing of revisions and amendments published each month.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Contact us via email at mail@standards.com.au, or write to the Chief Executive, Standards Australia International Ltd, GPO Box 5420, Sydney, NSW 2001.

Australian Standard™

**Double-flanged butterfly valves for
waterworks purposes**

First published as AS 4795—2002.

COPYRIGHT

© Standards Australia International

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher.

Published by Standards Australia International Ltd
GPO Box 5420, Sydney, NSW 2001, Australia

ISBN 0 7337 4930 5

PREFACE

This Standard was prepared by the Joints Standards Australia/Standards New Zealand Committee WS-022, Valves for Water Supply Purposes, in response to a request from Water Services Association of Australia (WSAA) to provide a suitable product Standard for double-flanged butterfly valves.

The objective of this Standard is to provide material requirements and performance tests for butterfly valves in water supply systems including potable water, recycled water and screened wastewater systems, together with default compliance requirements for the use of manufacturers and certification bodies.

Statements expressed in mandatory terms in notes to tables and figures are deemed to be requirements of this Standard.

Support and contribution is acknowledged from the Water Services Association of Australia (WSAA) and manufacturers.

The terms 'normative' and 'informative' have been used in this Standard to define the application of the appendix to which they apply. A 'normative' appendix is an integral part of a Standard, whereas an 'informative' appendix is only for information and guidance.

CONTENTS

	<i>Page</i>
SECTION 1 SCOPE AND GENERAL	
1.1 SCOPE	4
1.2 REFERENCED DOCUMENTS	4
1.3 DEFINITIONS	4
1.4 DESIGNATION OF SIZE	5
1.5 ALLOWABLE OPERATING PRESSURES	5
SECTION 2 MATERIALS AND COMPONENTS	
2.1 GENERAL	6
2.2 CORROSION-RESISTANT MATERIALS	6
2.3 CONTAMINATION OF WATER	6
2.4 O-RINGS (ELASTOMERIC TOROIDAL SEALING RINGS)	6
SECTION 3 DESIGN	
3.1 GENERAL	8
3.2 END CONNECTIONS	8
3.3 COMPONENT DESIGN	9
3.4 MANUAL ACTUATOR	13
3.5 LIFTING DEVICES	13
3.6 EXTENSION SPINDLE ASSEMBLY	13
3.7 FASTENERS	14
SECTION 4 PROTECTIVE COATINGS	
4.1 GENERAL	15
4.2 COMPONENTS	15
SECTION 5 PERFORMANCE TESTS	
5.1 GENERAL AND TEST SEQUENCE	16
5.2 TYPE TESTS	16
5.3 PRODUCTION TESTS	17
SECTION 6 MARKING AND PACKAGING	
6.1 BODY MARKINGS	19
6.2 DIRECTION OF CLOSURE FOR HANDWHEELS AND CAPS	19
6.3 PACKAGING	19
APPENDICES	
A MEANS FOR DEMONSTRATING COMPLIANCE WITH THIS STANDARD	20
B PURCHASING GUIDELINES	25
C REFERENCED DOCUMENTS	29
D ALTERNATIVE MATERIAL REQUIREMENTS	31
E ALTERNATIVE COATING REQUIREMENTS—TWO-PACK HIGH-BUILD EPOXY COATING	32

STANDARDS AUSTRALIA

Australian Standard

Double-flanged butterfly valves for waterworks purposes

SECTION 1 SCOPE AND GENERAL

1.1 SCOPE

This Standard specifies requirements for Classes 10, 16, 21 and 35, manually operated resilient-seated double-flanged butterfly valves for waterworks purposes, with a maximum operating temperature of 40°C. This standard covers the following:

- (a) Manual actuators, gearboxes and standard spindle caps.
- (b) Water supply applications including potable water and recycled water as well as screened wastewater.
- (c) Valves of nominal size:
 - (i) Seal-on-disc DN 300 to DN 2000.
 - (ii) Seal-in-body: DN 80 to 2000.
 - (iii) Seal-on-body: DN 80 to 2000.
- (d) The capability of the valves to be fitted with electric, hydraulic or pneumatic actuators and to be operated using portable actuators.

Class 35 valves are only supplied with 'Ring Body Flanges' while Class 21 may also be supplied with 'Ring Body Flanges'.

Means for demonstrating compliance with this Standard are given in Appendix A.

NOTE: See Appendix B for purchasing requirements that should be agreed upon at time of inquiry or order.

1.2 REFERENCED DOCUMENTS

The documents referred to in this Standard are listed in Appendix C.

1.3 DEFINITIONS**1.3.1 Bonded**

Glued or adhered where it can be removed on site.

1.3.2 Ring body flange valve

The area, between the flanges of the valve, that are solid cast. The flange holes can either be drilled and tapped, or drilled for clearance of the flange bolts.

1.3.3 Seal on disc

A seal that is attached to the perimeter of the disc of the valve.

1.3.4 Seal in body

A seal that is either clamped or retained integrally in the body of the valve.