

Australian/New Zealand Standard™

**Approval and test specification—
Residual current devices (current-
operated earth-leakage devices)**



AS/NZS 3190:2011

This Joint Australian/New Zealand Standard was prepared by Joint Technical Committee EL-004, Electrical Accessories. It was approved on behalf of the Council of Standards Australia on 25 October 2011 and on behalf of the Council of Standards New Zealand on 3 October 2011.

This Standard was published on 21 November 2011.

The following are represented on Committee EL-004:

Australian Industry Group
Consumer Electronics Suppliers Association
Consumers Federation of Australia
Electrical Compliance Testing Association
Electrical Regulatory Authorities Council
Engineers Australia
International Accreditation New Zealand
Ministry of Economic Development (New Zealand)
New Zealand Manufacturers and Exporters Association
NSW Office of Fair Trading
Plastics Industry Pipe Association of Australia
Testing Interests (Australia)

Keeping Standards up-to-date

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about joint Australian/New Zealand Standards can be found by visiting the Standards Web Shop at www.saiglobal.com.au or Standards New Zealand web site at www.standards.co.nz and looking up the relevant Standard in the on-line catalogue.

For more frequent listings or notification of revisions, amendments and withdrawals, Standards Australia and Standards New Zealand offer a number of update options. For information about these services, users should contact their respective national Standards organization.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Please address your comments to the Chief Executive of either Standards Australia or Standards New Zealand at the address shown on the back cover.

This Standard was issued in draft form for comment as DR AS/NZS 3190.

Australian/New Zealand Standard™

Approval and test specification— Residual current devices (current- operated earth-leakage devices)

Originated in Australia as AS 3190—1974.
First New Zealand edition AS/NZS 3190:2002.
Previous edition AS/NZS 3190:2009.
Eighth edition 2011.

COPYRIGHT

© Standards Australia Limited/Standards New Zealand

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher, unless otherwise permitted under the Copyright Act 1968 (Australia) or the Copyright Act 1994 (New Zealand).

Jointly published by SAI Global Limited under licence from Standards Australia Limited, GPO Box 476, Sydney, NSW 2001 and by Standards New Zealand, Private Bag 2439, Wellington 6140.

PREFACE

This Standard was prepared by the Joint Standards Australia/Standards New Zealand Committee EL-004, Electrical Accessories, to supersede AS/NZS 3190:2009, *Approval and test specification—Residual current devices (current-operated earth-leakage devices)* 12 months from the date of publication.

This Standard will exist in parallel to the deemed to comply Standards listed in Clause 3.2.

The essential safety requirements in AS/NZS 3820, *Essential safety requirements for electrical equipment*, that could be applicable to residual current devices (current-operated earth-leakage devices) are covered by this Standard taken in conjunction with any other relevant requirements affecting safety.

The objective of this Standard is to provide Australian and New Zealand electrical industries (including manufacturers, test laboratories, installers and regulators) with electrical safety requirements and test methods for residual current devices (current-operated earth-leakage devices).

This Standard is one of a series of Approval and Test Specifications to be read in conjunction with AS/NZS 3100, *Approval and test specification—General requirements for electrical equipment*. The purpose of this series is to outline conditions that must be met to secure approval for the sale and use of electrical equipment in Australia and New Zealand. Only safety matters and related conditions are covered.

There is a general acceptance that Type III and Type IV residual current devices do not provide adequate personal protection, however, they are within the scope of this Standard.

This Standard was revised to introduce the following changes:

- (a) Revised requirements for the resistance to fire test.
- (b) The requirements for PSOAs (see Clause 2.4) have been aligned with AS/NZS 3012.
- (c) Deletion of FSE PRCDs requirements and replacement with IEC 62335 SPE-PRCD requirements (see Clause 3.2).
- (d) Changes to marking requirements and symbols including AS/NZS 3012 for PRCDs.
- (e) Revised testing requirements.
- (f) General editorial revision and correction of some minor errors.
- (g) Addition of deemed to comply standards in Clause 3.2 and guidance notes.

The terms ‘normative’ and ‘informative’ have been used in this Standard to define the application of the appendix to which they apply. A ‘normative’ appendix is an integral part of a Standard, whereas an ‘informative’ appendix is only for information and guidance.

This Standard does not purport to include all the necessary provisions of a contract.

CONTENTS

	<i>Page</i>
1 SCOPE AND REFERENCED DOCUMENTS.....	4
2 DEFINITIONS.....	6
3 COMPLIANCE WITH STANDARDS	7
4 CLASSIFICATION.....	8
5 DESIGN AND CONSTRUCTION.....	10
6 RCD ISOLATION AND TEST FACILITY REQUIREMENTS	17
7 MARKING	20
8 TESTS.....	24
APPENDICES	
A RELIABILITY.....	41
B IMPULSE WITHSTAND TEST	46
C PSOA REQUIREMENTS OF AS/NZS 3012.....	47

STANDARDS AUSTRALIA/STANDARDS NEW ZEALAND

Australian/New Zealand Standard**Approval and test specification—Residual current devices (current-operated earth-leakage devices)****1 SCOPE AND REFERENCED DOCUMENTS****1.1 Scope**

This Standard specifies essential safety requirements for residual current devices and residual current relays intended to isolate supply or initiate a ‘tripping’ signal to isolate supply to protected circuits, socket-outlets or equipment in the event of a current flow to earth, which exceeds a predetermined level, and—

- (a) have rated residual currents not exceeding 300 mA;
- (b) have rated load currents not exceeding 125 A a.c.;
- (c) are designed for use at low voltage; and
- (d) are classified in accordance with Clause 4.

The devices may be fixed or portable or, may be integral with a switching device or miniature overcurrent circuit breaker or, may be supplied as a separate attachment.

This Standard does not apply to—

- (i) devices intended to be used with a particular circuit breaker other than a miniature overcurrent circuit-breaker, as defined in AS/NZS 3111 or AS/NZS 60898.1; or
- (ii) devices intended to protect an electricity authority distribution system; or
- (iii) devices for the protection of equipment for mines and covered by the AS/NZS 2081 series of Standards.

1.2 Referenced documents

The following documents are referred to in this Standard.

AS

1931	High-voltage test techniques
1931.1	Part 1: General definitions and test requirements
60068	Environmental testing
60068.2.30	Part 2.30: Tests—Test Db and guidance: Damp heat, cyclic (12+12-hour cycle)
60529	Degrees of protection provided by enclosures (IP Code)

AS/NZS

2081	Electrical equipment for coal and shale mines—Electrical protection devices (series)
3001	Electrical installations—Transportable structures and vehicles including their site supplies
3002	Electrical installations—Shows and carnivals
3012	Electrical installations—Construction and demolition sites
3100	Approval and test specification—General requirements for electrical equipment