

Australian/New Zealand Standard™

**Pressure equipment—In-service
inspection**



AS/NZS 3788:2006

This Joint Australian/New Zealand Standard was prepared by Joint Technical Committee ME-001, Pressure Equipment. It was approved on behalf of the Council of Standards Australia on 27 June 2006 and on behalf of the Council of Standards New Zealand on 7 July 2006.

This Standard was published on 27 July 2006.

The following are represented on Committee ME-001:

ACT WorkCover
Australasian Institute of Engineer Surveyors
Australian Aluminium Council
Australian Building Codes Board
Australian Chamber of Commerce and Industry
Australian Industry Group
Australian Institute for the Certification of Inspection Personnel
Australian Institute of Energy
Australian Institute of Petroleum
Bureau of Steel Manufacturers of Australia
Department for Administrative and Information Services, SA
Department of Consumer and Employment Protection, WorkSafe Division, WA
Department of Infrastructure, Energy and Resources, Tas.
Department of Labour New Zealand
Electricity Engineers Association New Zealand
Energy Networks Association
Engineers Australia
Institution of Professional Engineers New Zealand
Insurance Council of Australia
Land Transport Safety Authority New Zealand
LPG Australia
Materials Australia
National Association of Testing Authorities, Australia
New Zealand Engineering Federation
New Zealand Heavy Engineering Research Association
New Zealand Petrochemical Users Group
Pressure Equipment Association
Victorian WorkCover Authority
Welding Technology Institute of Australia
WorkCover NSW

Keeping Standards up-to-date

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about joint Australian/New Zealand Standards can be found by visiting the Standards Web Shop at www.standards.com.au or Standards New Zealand web site at www.standards.co.nz and looking up the relevant Standard in the on-line catalogue.

Alternatively, both organizations publish an annual printed Catalogue with full details of all current Standards. For more frequent listings or notification of revisions, amendments and withdrawals, Standards Australia and Standards New Zealand offer a number of update options. For information about these services, users should contact their respective national Standards organization.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Please address your comments to the Chief Executive of either Standards Australia or Standards New Zealand at the address shown on the back cover.

This Standard was issued in draft form for comment as DR 05161.

STANDARDS AUSTRALIA/STANDARDS NEW ZEALAND

RECONFIRMATION
OF
AS/NZS 3788:2006
Pressure equipment—In-service inspection

RECONFIRMATION NOTICE

Technical Committee ME-001 has reviewed the content of this publication and in accordance with Standards Australia procedures for reconfirmation, it has been determined that the publication is still valid and does not require change.

Certain documents referenced in the publication may have been amended since the original date of publication. Users are advised to ensure that they are using the latest versions of such documents as appropriate, unless advised otherwise in this Reconfirmation Notice.

Approved for reconfirmation in accordance with Standards Australia procedures for reconfirmation on 10 October 2016.

Approved for reconfirmation in New Zealand on behalf of the Standards Council of New Zealand on 13 December 2016.

The following are represented on Technical Committee ME-001:

Australasian Corrosion Association
Australasian Institute of Engineer Surveyors
Australian Aluminium Council
Australian Building Codes Board
Australian Chamber of Commerce and Industry
Australian Industry Group
Australian Institute for the Certification of Inspection Personnel
Australian Institute of Energy
Australian Institute of Petroleum
Bureau of Steel Manufacturers of Australia
Department of Justice and Attorney General (QLD)
Electricity Engineers Association (New Zealand)
Energy Networks Association
Engineers Australia
Gas Energy Australia
Institution of Professional Engineers New Zealand
Insurance Council of Australia
Materials Australia
National Association of Testing Authorities Australia
New Zealand Heavy Engineering Research Association
New Zealand Manufacturers and Exporters Association
SafeWork NSW
Welding Technology Institute of Australia
Worksafe Division, Department of Commerce, Western Australia
WorkSafe Victoria

NOTES

Australian/New Zealand Standard™

**Pressure equipment—In-service
inspection**

Originated as AS 3788—1990.
Previous edition AS/NZS 3788:2001.
Fourth edition 2006.

COPYRIGHT

© Standards Australia/Standards New Zealand

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher.

Jointly published by Standards Australia, GPO Box 476, Sydney, NSW 2001 and Standards New Zealand, Private Bag 2439, Wellington 6020

ISBN 0 7337 7657 4

PREFACE

This Standard was prepared by the Joint Standards Australia/Standards New Zealand Committee ME-001, Pressure Equipment to supersede AS/NZS 3788:2001, *Pressure equipment—In-service inspection*.

The objective of the revision is to align the Standard with current equipment integrity management and assessment practices and to address some of the problems currently experienced in industry. To achieve this, the Standard has been significantly revised throughout.

While the Standard still sets out minimum inspection intervals, it now allows those intervals to be varied in response to a thorough risk-based engineering assessment. This is intended to allow the efficient use of integrity management programs by large-scale industry. As such assessments require significant resources to consider all the relevant factors, it is expected that the majority of the users of this Standard will continue using the prescribed intervals. It should be noted that the previous Clause 4.4.4.3(c), Further extended period, has been removed to ensure that variations to inspection intervals are properly assessed.

More emphasis has been placed on the responsibility to use competent bodies and personnel for all aspects of the inspection and assessment processes—a reflection of the current philosophy of occupational health and safety regulations. Guidance material is included to aid industry in assessing the competence of bodies and people for different tasks.

The Committee noted that poorly-marked or unidentifiable equipment is a significant issue facing inspectors, and has provided some guidance on dealing with such situations.

The appendices have also been revised, including a review of the normative or informative status of each. Appendix O (regarding fracture mechanics) has been significantly revised. A new appendix has been added regarding the inspection of support structures.

This Standard provides inspection requirements to assist in assuring the continued safe operation of pressure equipment. In some circumstances additional inspection may be necessary for adequate performance or safety. The material contained in this Standard may be used as an aid in the training of inspection personnel.

Users of this Standard are reminded that it has no legal authority in its own right, but acquires legal standing where adopted by government or other authority having jurisdiction, or if specified as part of a commercial contract.

Statements expressed in mandatory terms in notes to tables and figures are deemed to be requirements of this Standard.

The terms ‘normative’ and ‘informative’ have been used in this Standard to define the application of the appendix to which they apply. A ‘normative’ appendix is an integral part of a Standard, whereas an ‘informative’ appendix is only for information and guidance.

CONTENTS

	<i>Page</i>
SECTION 1 SCOPE AND GENERAL	
1.1 SCOPE	5
1.2 APPLICATION	5
1.3 REFERENCED AND RELATED DOCUMENTS	6
1.4 DEFINITIONS	6
1.5 RISK MANAGEMENT AND RISK BASED INSPECTION	9
1.6 SAFETY	9
1.7 SPECIAL CONDITIONS AND VARIATIONS	9
1.8 REFERENCED STANDARDS	9
SECTION 2 INSPECTION REQUIREMENTS	
2.1 OBJECTIVES OF INSPECTION	10
2.2 ASSET INTEGRITY LIFE CYCLE	10
2.3 INSPECTION PROCESS	11
SECTION 3 INSPECTION PERSONNEL AND ADMINISTRATION	
3.1 OWNER'S RESPONSIBILITIES	12
3.2 RESPONSIBILITIES AND CAPABILITIES OF PERSONS CARRYING OUT IN-SERVICE INSPECTION	13
3.3 RESPONSIBILITIES OF INSPECTION BODIES	13
3.4 SUPPORT ORGANIZATIONS	14
SECTION 4 PRESSURE EQUIPMENT INSPECTION	
4.1 GENERAL	15
4.2 COMMISSIONING OR RECOMMISSIONING INSPECTION	15
4.3 OPERATING SURVEILLANCE AND MONITORING	16
4.4 PERIODIC INSPECTION	16
4.5 RISK BASED INSPECTION	29
4.6 INSPECTION OF IDLE PRESSURE EQUIPMENT	29
4.7 PRESSURE-RELIEF DEVICES	30
4.8 CONTROLS CRITICAL FOR SAFEGUARDING EQUIPMENT	37
4.9 INSTRUMENTATION AND CONTROLS	37
4.10 EMERGENCY SHUTDOWN SYSTEMS	37
4.11 AUTOMATIC FIRE-FIGHTING SYSTEMS USED TO PROTECT PRESSURE EQUIPMENT	38
4.12 LOW TEMPERATURE VESSELS	38
4.13 PRESSURE PIPING	38
SECTION 5 ASSESSMENT OF PRESSURE EQUIPMENT INTEGRITY	
5.1 GENERAL	40
5.2 FITNESS FOR SERVICE ASSESSMENT	40
5.3 DETERMINATION OF REMAINING LIFE	45
5.4 DE-RATING	45
SECTION 6 REPAIRS, ALTERATIONS AND RE-RATING	
6.1 GENERAL	47
6.2 REPAIRS	47
6.3 RE-RATING	49

SECTION 7 INVESTIGATION OF DETERIORATION AND FAILURES	
7.1	GENERAL 51
7.2	FAILURE ANALYSIS 51
7.3	RECORDING OF INCIDENTS AND FAILURES 52
SECTION 8 PRESSURE EQUIPMENT DOCUMENTATION AND IDENTIFICATION	
8.1	INFORMATION FILES 53
8.2	REGISTER OF PRESSURE EQUIPMENT 53
8.3	PRESSURE EQUIPMENT IDENTIFICATION 53
8.4	PRESSURE EQUIPMENT MARKING 55
8.5	PRESSURE EQUIPMENT DATA 56
8.6	PRESSURE EQUIPMENT HISTORY 57
APPENDICES	
A	REFERENCED AND RELATED DOCUMENTS 59
B	RISK MANAGEMENT 66
C	SAFETY DURING INSPECTION 70
D	METHODS OF INSPECTION 74
E	INSPECTION AND REPAIR OF TRANSPORTABLE VESSELS 87
F	INSPECTION OF BOILERS 95
G	INSPECTION OF UNFIRED PRESSURE VESSELS—STATIONARY 99
H	INSPECTION OF HEAT EXCHANGERS, COOLERS AND CONDENSERS 102
I	INSPECTION OF PRESSURE PIPING 104
J	INSPECTION OF FIRED HEATERS 118
K	EXAMPLE INSPECTION REPORTS 121
L	PRESERVATION AND INSPECTION OF IDLE PRESSURE EQUIPMENT 123
M	COMMON MODES AND CAUSES OF DETERIORATION AND FAILURE 126
N	ASSESSMENT OF LOCALIZED WALL THINNING OF CYLINDRICAL, CONICAL, AND SPHERICAL SHELLS 131
O	ASSESSMENT OF PLANAR DEFECTS 141
P	PRESSURE RELIEF VALVES—SUPPLEMENTARY INFORMATION 156
Q	INSPECTION OF PRESSURE EQUIPMENT WITH QUICK-ACTUATING CLOSURES AND SWING BOLT DOORS 160
R	INSPECTION OF BURIED OR MOUNDED PRESSURE VESSELS 161
S	INSPECTION OF DEAERATORS 162
T	INSPECTION OF STORAGE TANKS TO API 620 OR EQUIVALENT 163
U	REMAINING LIFE ASSESSMENT 166
V	COMPETENCY OF IN-SERVICE INSPECTION BODIES AND PERSONNEL .. 177
W	INSPECTION OF DRUMS FOR TRANSPORT OF LIQUEFIED GAS 181
X	TESTING OF SOFT SEATED POP ACTION RELIEF VALVES FOR LIQUEFIABLE GAS SERVICE 186
Y	INSPECTION OF HERITAGE BOILERS AND PRESSURE VESSELS 187
Z	INSPECTION OF FOUNDATIONS AND STRUCTURES 195

STANDARDS AUSTRALIA/STANDARDS NEW ZEALAND**Australian/New Zealand Standard
Pressure equipment—In-service inspection****SECTION 1 SCOPE AND GENERAL****1.1 SCOPE**

This Standard specifies the minimum requirements for the inspection, repair and alteration of in-service boilers, pressure vessels, piping, safety equipment, and associated safety controls (hereafter referred to as pressure equipment), and gives guidance in the execution of such activities. Guidance is included for the inspection of ancillary equipment such as structures. This Standard also specifies the requirements for the initial inspection after installation and prior to commissioning. The inspection flow diagram (see Figure 1.1) illustrates the various types of inspection covered by this Standard.

This Standard provides information to facilitate grounds for agreement between interested parties, and the establishment of uniform minimum requirements for in-service inspections, including inspection intervals and procedures, to assist in assuring safe and economic operation. Information is provided on mechanisms of deterioration, the assessment of defects, and the assessment of fitness for service of pressure equipment.

No rules can be written in sufficient detail to cover all aspects of the inspection of in-service pressure equipment. The owner is responsible for ensuring that the extent and frequency of inspection is appropriate and adequate for the continued safe operation of the pressure equipment. This may require the seeking of expert advice.

Duty of Care is now prescribed by Occupational Health and Safety Legislation. This Standard does not supersede such Duty of Care, but is intended to complement and contribute to it.

1.2 APPLICATION

This Standard applies to, but is not limited to, pressure equipment covered by AS/NZS 1200. Typically it includes the following:

- (a) Boilers and associated pressure parts, controls and pipe work covered by AS 1228, BS 1113, BS 2790, AS 2593 and ASME BPV-I.
- (b) Pressure vessels and associated pressure parts, controls and pipe work covered by AS 1210, BS PD 5500, EN 13445, ASME BPV-VIII, AS 2971 (serially produced pressure vessels) and EN 286-1.
- (c) Pressure piping covered by AS 4041, NZS/BS 806, ASME B 31.1 and ASME B 31.3.
- (d) Pressurized storage tanks built to API 620 or equivalent.
- (e) Fired heaters.
- (f) Heritage boilers and pressure vessels.

Although pressure equipment with Hazard Level E (to AS 4343) is within the scope of this Standard, no specific requirements have been included. To ensure safety, in-service inspection of such equipment should follow the principles of this Standard, along with good engineering practice.