

Under revision DR 92070

Dep A

Superseded by AS 2374.6-1994

ON LOAN ONLY  
PLEASE RETURN TO SAA LIBRARY

AS 2374, Part 6—1982  
UDC 621.314.2

RECONFIRMED  
1987

October  
TAS

# Australian Standard 2374, Part 6—1982

---

## POWER TRANSFORMERS Part 6—SOUND LEVELS

[Title allocated by Defence Cataloguing Authority:  
TRANSFORMER, POWER (Sound Levels) ... NSC 5950, 6120]

---



**STANDARDS ASSOCIATION OF AUSTRALIA**

*Incorporated by Royal Charter*



This Australian Standard, prepared by Committee EL/8, Static Electrical Machinery, was approved on behalf of the Council of the Standards Association of Australia on 8 June 1982 and published on 9 August 1982.

---

The following interests were represented on the committee responsible for the preparation of this standard:

- Australian-British Trade Association
- Australian Electrical and Electronic Manufacturers Association
- Confederation of Australian Industry
- Defence Standardization Committee
- Electrical testing laboratories
- Electricity Supply Association of Australia
- Electricity Supply Engineers Association of N.S.W.
- Institution of Engineers, Australia
- Railways of Australia Committee

---

To keep abreast of progress in industry, Australian standards are subject to continuous review and are kept up-to-date by the issue of amendments or new editions as necessary. It is important therefore that standards users ensure that their standards are up-to-date. Full details of all SAA publications will be found in the Annual List of Australian Standards; these details are supplemented by listings in the SAA monthly journal 'The Australian Standard'. Information on the Annual List and 'The Australian Standard' may be obtained from any sales office of the Association, where details are also available of the current status of individual standards. Suggestions for improvements to published standards, addressed to the head office of the Association, are welcomed.

---

*This standard was issued in draft form for comment as DR 81268.*

**AUSTRALIAN STANDARD**

**POWER TRANSFORMERS  
Part 6  
SOUND LEVELS**

**AS 2374, Part 6—1982**

First published .....1982

**PUBLISHED BY THE STANDARDS ASSOCIATION OF AUSTRALIA  
STANDARDS HOUSE, 80 ARTHUR ST, NORTH SYDNEY, N.S.W.**



ISBN 0 7262 2642 4

0 AUG 1982

## PREFACE

This standard was prepared by the Association's Committee on Power Transformers. It is based on AS C61, Power Transformers, for the setting of acceptable levels of sound, and on IEC 551, Measurement of Transformer and Reactor Sound Levels, for methods of measurement, and is Part 6 of a six-part standard to supersede AS C61.

The other Parts of the standard are—

- Part 1—General Requirements
- Part 2—Temperature Rise
- Part 3—Insulation Levels and Dielectric Tests
- Part 4—Tappings and Connections
- Part 5—Ability to Withstand Short Circuit.

For this standard, it was decided to maintain the previous practice of specifying sound levels in terms of sound pressure. However, when sufficient comparative data have been gathered, the standard will be reviewed to provide for the conversion of the sound levels given in Appendix A to levels in terms of sound power.

This standard may require reference to the following standards:

- AS 1259      Sound Level Meters  
                  Part 2—Type 2, Precision
- SAA MP44    Guide for the Use of Sound Measuring Equipment  
                  Part 1—Portable Sound Level Meters.

---

## CONTENTS

	<i>Page</i>
<b>SPECIFICATION</b>	
1 Scope .....	3
2 Application .....	3
3 Definitions .....	3
4 Permissible Sound Level .....	3
5 Test Instruments .....	3
6 Conditions for Measurement .....	3
7 Measurement Methods .....	4
8 Calculation of Corrected Mean Sound Level .....	4
9 Presentation of Results .....	5
<b>APPENDICES</b>	
A Tables of Permissible Sound Levels .....	11
B Calculation of Quadratic Mean .....	14
C Record of Sound Level Measurement (Typical Form) .....	15

© Copyright — STANDARDS ASSOCIATION OF AUSTRALIA 1982

Users of standards are reminded that copyright subsists in all SAA publications. No part of this publication may be reproduced, stored in a retrieval system in any form or transmitted by any means without prior permission in writing of the Standards Association of Australia.

## STANDARDS ASSOCIATION OF AUSTRALIA

**Australian Standard**  
**for**  
**POWER TRANSFORMERS**  
**PART 6—SOUND LEVELS**

**1 SCOPE.** This standard defines the permissible limits of sound level which may be generated by a transformer and sets out the methods of measuring that sound level.

**2 APPLICATION.** This standard is intended to apply to measurements made in the manufacturer's works as, when measurements are made on site, conditions may be very different owing to proximity of other objects, extraneous noises, etc. Nevertheless, the same general rules given herein may be followed when site measurements are made.

The methods described are applicable to transformers of all types covered by AS 2374, Part 1, without further limitation as regards size or voltage, and when fitted with their normal auxiliary equipment, that may influence the measurement result. There may however be special cases where configurations and electrical safety demands different test methods. These methods and the acceptable sound levels shall then be agreed between the purchaser and the manufacturer.

**3 DEFINITIONS.** For the purpose of this standard, the definitions in AS 2374, Part 1, and the following definitions apply:

**3.1 Sound level**—the reading given by a sound level meter complying with Clause 5 herein.

NOTE: This instrument responds to sound pressure.

**3.2 Principal radiating surface**—a hypothetical surface surrounding the transformer or cooling equipment which is assumed to be the surface from which sound is radiated.

NOTE: The method for determining the principal radiating surface for particular equipment is given in Clause 7.2.

**3.3 Prescribed contour**—a horizontal line, spaced at a definite distance from the principal radiating surface, along which the measurement points are located.

NOTE: The method for determining the prescribed contour for particular equipment is given in Clause 7.2.

**3.4 Background noise**—the noise present at the measuring points with the exclusion of that produced by the equipment the sound level of which is being measured. It includes the noise from all other apparatus necessary for the measurement process.

#### 4 PERMISSIBLE SOUND LEVEL.

**4.1 Standard Sound Levels.** The mean sound level of a transformer shall not exceed the value given in Tables A1.1, A1.2 and A3 of Appendix A for the appropriate rating of oil-immersed and dry-type transformers respectively, when measured at the factory.

**4.2 Special Reduced Sound Levels.** Special reduced mean sound levels may be specified for some oil-immersed transformers. The sizes of transformers and the appropriate values of sound level are given in Table A2 of Appendix A.

**4.3 Other Sound Levels.** When other mean sound levels are required, they are subject to agreement between the purchaser and the manufacturer.

**4.4 Acceptance or Rejection of Sound Level Performance.** The acceptance or rejection of any transformer, the mean sound level of which exceeds that specified by the purchaser, is subject to negotiation between the purchaser and the manufacturer.

**4.5 Choice of kV.A. Rating in Tables A1.1, A1.2, A2 and A3.**

**4.5.1 General.** The tables in Appendix A show specific kilovolt ampere ratings (and not ranges). For a rating intermediate between those shown, the sound level for the next higher rating shall be used.

**4.5.2 Transformers with combined cooling (maximum sound level).** The maximum permissible sound level appropriate to the modes of cooling of a transformer having a combination of natural and forced cooling shall be that appropriate to the maximum rating with all cooling equipment operating.

**4.5.3 Transformers with combined cooling (sound level for reduced cooling).** Where a transformer is to be tested for sound level with reduced cooling and correspondingly reduced rating, the permissible sound level shall be that shown in the appropriate table for the correspondingly reduced rating.

**4.5.4 Multi-winding transformers.** For the purpose of determining permissible sound levels, the rating of a multi-winding transformer shall be taken as half the sum of the kilovolt ampere ratings of all windings. Where mixed cooling is also involved, see Clauses 4.6.2 and 4.6.3.

**5 TEST INSTRUMENTS.** Measurements shall be made using a sound level meter complying with AS 1259, Part 2, with the A-weighting network incorporated.

Sound level measurements should be carried out in accordance with the recommendations of SAA MP44.

#### 6 CONDITIONS FOR MEASUREMENT.

**6.1 Criteria for Adequacy of the Test Environment.** The test environment should be free from reflecting objects other than a reflecting floor so that the equipment under test radiates into a free field over a reflecting plane.