

Australian Standard[®]

**Emergency warning and
intercommunication systems in
buildings**

**Part 1: Equipment design and
manufacture**

This Australian Standard was prepared by Committee BD/56, Emergency Warning and Intercommunication Systems in Buildings. It was approved on behalf of the Council of Standards Australia on 4 May 1989 and published on 11 September 1989.

The following interests are represented on Committee BD/56:

Association of Consulting Engineers, Australia
Australian Assembly of Fire Authorities
Australian Fire Protection Association
Australian Uniform Building Regulations Coordinating Council
Building Owners and Managers Association of Australia
Commonwealth Fire Board
Department of Administrative Services—Construction Group
Department of Defence
Electrical Contractors Associations of Australia
Fire Protection Industry Association of Australia
Insurance Council of Australia
Public Works Department, New South Wales
Public Works Department, Victoria
Safety Institute of Australia
Telecom Australia

Review of Australian Standards. To keep abreast of progress in industry, Australian Standards are subject to periodic review and are kept up to date by the issue of amendments or new editions as necessary. It is important therefore that Standards users ensure that they are in possession of the latest edition, and any amendments thereto.

Full details of all Australian Standards and related publications will be found in the Standards Australia Catalogue of Publications; this information is supplemented each month by the magazine 'The Australian Standard', which subscribing members receive, and which gives details of new publications, new editions and amendments, and of withdrawn Standards.

Suggestions for improvements to Australian Standards, addressed to the head office of Standards Australia, are welcomed. Notification of any inaccuracy or ambiguity found in an Australian Standard should be made without delay in order that the matter may be investigated and appropriate action taken.

This Standard was issued in draft form for comment as DR 85304.

Australian Standard[®]

**Emergency warning and
intercommunication systems in
buildings**

**Part 1: Equipment design and
manufacture**

First published as part of AS 2220—1978.
AS 2220—1978 (in part) revised and redesignated
AS 2220.1—1989.

Incorporating:
Amdt 1—1989.
Amdt 2—1993.

PREFACE

This Standard was prepared by the Standards Australia Committee BD/56, Emergency Warning and Intercommunication Systems in Buildings. It is Part 1 of a two-part Standard, the parts of which are as follows:

AS

2220 *Emergency warning and intercommunication systems in buildings*
 Part 1: Equipment design and manufacture (this Standard)
 Part 2: System design, installation and commissioning

This Standard together with AS 2220.2 superseded AS 2220—1978, *Emergency warning and intercommunication systems for buildings*.

This Standard provides more detailed requirements than AS 2220—1978 but it does not differ in the overall intent of that Standard.

AS 1851, *Maintenance of fire protection equipment, Part 10: Emergency warning and intercommunication systems*, specifies the periodic inspection and maintenance requirements to ensure continued effective functioning of the emergency warning and intercommunication systems designed and installed in accordance with AS 2220.

This Standard does not seek to define the buildings in which these systems are to be used as it is considered that this is the responsibility of the Building Authority in the area concerned.

© Copyright — STANDARDS AUSTRALIA

Users of Standards are reminded that copyright subsists in all Standards Australia publications and software. Except where the Copyright Act allows and except where provided for below no publications or software produced by Standards Australia may be reproduced, stored in a retrieval system in any form or transmitted by any means without prior permission in writing from Standards Australia. Permission may be conditional on an appropriate royalty payment. Requests for permission and information on commercial software royalties should be directed to the head office of Standards Australia.

Standards Australia will permit up to 10 percent of the technical content pages of a Standard to be copied for use exclusively in-house by purchasers of the Standard without payment of a royalty or advice to Standards Australia.

Standards Australia will also permit the inclusion of its copyright material in computer software programs for no royalty payment provided such programs are used exclusively in-house by the creators of the programs.

Care should be taken to ensure that material used is from the current edition of the Standard and that it is updated whenever the Standard is amended or revised. The number and date of the Standard should therefore be clearly identified.

The use of material in print form or in computer software programs to be used commercially, with or without payment, or in commercial contracts is subject to the payment of a royalty. This policy may be varied by Standards Australia at any time.

CONTENTS

	<i>Page</i>
FOREWORD	4
SECTION 1. SCOPE AND GENERAL	
1.1 SCOPE	5
1.2 APPLICATION	5
1.3 REFERENCED DOCUMENTS	5
1.4 DEFINITIONS	5
SECTION 2. EMERGENCY WARNING SYSTEM	
2.1 GENERAL	7
2.2 SYSTEM FUNCTIONS	7
2.3 SYSTEM COMPONENTS	7
2.4 EMERGENCY CONTROL PANELS (ECPs)	7
2.5 MAIN EQUIPMENT	9
2.6 ACTUATION DEVICES	12
SECTION 3. EMERGENCY INTERCOMMUNICATION SYSTEM	
3.1 GENERAL	13
3.2 SYSTEM FUNCTIONS	13
3.3 ADDITIONAL EQUIPMENT AT THE ECPs	13
3.4 EQUIPMENT FOR WARDEN INTERCOMMUNICATION POINT (WIP)	13
3.5 PERFORMANCE	13
3.6 FUNCTIONAL REQUIREMENTS	14
3.7 POWER SUPPLY	14
SECTION 4. EQUIPMENT DESIGN AND CONSTRUCTION	
4.1 GENERAL	15
4.2 ELECTRICAL	15
4.3 MECHANICAL	15
4.4 MARKING AND IDENTIFICATION OF EQUIPMENT	16
SECTION 5. PERFORMANCE TESTING	
5.1 GENERAL	17
5.2 FUNCTIONAL ASSESSMENT	17
5.3 ENDURANCE TEST	17
SECTION 6. DOCUMENTATION	
6.1 GENERAL	21
6.2 OPERATOR'S MANUAL	21
6.3 TECHNICAL MANUAL	21
6.4 LOGBOOK	22
APPENDICES	
A TYPICAL BLOCK SCHEMATIC OF BASIC EWIS	23
B INFORMATION TO BE SUPPLIED WHEN SPECIFYING AN EMERGENCY WARNING AND INTERCOMMUNICATION SYSTEM	24
C TYPICAL EMERGENCY CONTROL PANELS	25
D PREPARATION FOR TESTING	27
E OPERATIONAL TEST	28
F TRANSIENT VOLTAGE TEST PROCEDURES	29
G ELECTROMAGNETIC COMPATIBILITY TEST PROCEDURES ..	31

FOREWORD

An emergency warning and intercommunication system is installed in a building for the purpose of enabling the orderly evacuation of the building in the event of an emergency. To achieve this aim, it is essential that the emergency warning and intercommunication system has the following capabilities as appropriate:

- (a) Provision for manual and automatic activation.
- (b) On activation, the ability to alert wardens with an audible alarm. (A visual alarm may also be required.)
- (c) Where both an emergency warning system and an emergency intercommunication system are required to comply with AS 2220, these systems are integrated to provide a positive means of intercommunication between the House Warden and the various floors or Zone Wardens to enable the orderly evacuation of the building.
- (d) Emission of audible or visible signals, or both, that will either -
 - (i) alert the occupants; or
 - (ii) order the occupants to vacate the building.
- (e) Ease of operation.
- (f) Continuously operable under the conditions of the hazard.

STANDARDS AUSTRALIA

Australian Standard

Emergency warning and intercommunication systems in buildings

Part 1: Equipment design and manufacture

SECTION 1. SCOPE AND GENERAL

1.1 SCOPE. This Standard sets out minimum requirements for the design and manufacture of the equipment used in emergency warning and intercommunication systems, which are installed in buildings to ensure warning in the event of an emergency, and assist in the subsequent orderly evacuation of the building.

1.2 APPLICATION. Equipment for emergency warning and intercommunication systems in buildings shall comply with Sections 2, 3 and 4 of this Standard.

NOTE: Information which should be supplied when specifying an EWIS is shown in Appendix B.

1.3 REFERENCE DOCUMENTS. The following documents are referred to in this Standard:

AS STANDARDS

1044	Limits of electromagnetic interference for electrical appliances and equipment
1076	Code of practice for selection, installation and maintenance of electrical apparatus and associated equipment for use in explosive atmospheres (other than mining applications)
1076.1	Part 1: Basic requirements
1099	Basic environmental testing procedures for electrotechnology
1102	Graphical symbols for electrotechnical documentation
1102.101	Part 101: General information and general index
1102.105	Part 105: Semiconductor and electron tubes
1560	Recommendations for the design and use of components intended for mounting on printed circuit boards
1603	Automatic fire detection and alarm systems
1603.4	Part 4: Control and indicating equipment
1931	High voltage testing techniques
1931.1	Part 1: General definitions, test requirements test procedures and measuring devices
1939	Classification of degrees of protection provided by enclosures of electrical equipment
2036	Manually operating fire-alarm call points
2220	Emergency warning and intercommunication systems in buildings
2220.2	Part 2: System design, installation and commissioning
2481	All-or-nothing electrical relays (instantaneous and timing relays)
2546	Printed boards
2546.1	Part 1: General requirements and test methods
2546.3	Part 3: Design and use

2547	Semiconductor devices
2547.2.1	Part 2.1: Integrated circuits—General
2547.2.2	Part 2.2: Integrated circuits—Digital
3000	SAA Wiring Rules
AUSTEL REG 2	Interworking and non-interference requirements for customer premises equipment attached to the public switched telephone network
REG 3	General requirements for customer switching systems attached to the public switched telephone network
IEC 249 249-2	Base materials for printed circuits Part 2: Specifications
801	Electromagnetic compatibility for industrial process measurement and control equipment
801-3	Part 3: Radiated electromagnetic field requirements
UL 94	Tests for flammability of plastic materials for parts in devices and appliances

APPROVAL AND TEST SPECIFICATIONS

AS 3100	Approval and test specification for definitions and general requirements for electrical materials and equipment
3108	Isolating transformers and safety isolating transformers
3108.1	Part 1: General requirements
3108.2	Part 2: Supplementary requirements— Isolating transformers
3108.3	Part 3: Supplementary requirements— Safety isolating transformers
3126	Extra-low voltage transformers
3159	Electronic sound and vision equipment
3250	Mains operated electronic and related equipment for household and similar general use

1.4 DEFINITIONS. For the purpose of this Standard, the definitions below apply.

1.4.1 Alarm system—facility provided in a building to give an alarm in the event of fire, civil commotion, bomb threat, leakage of toxic or noxious fumes, structural damage, or other emergency.

1.4.2 Alarm signal—a signal given by fire alarm, or other alarm system, at the fire indicator panel (FIP) or other point at the building, and to places outside the building, e.g. to a fire brigade.