

Australian/New Zealand Standard™

**Electrical installations—Domestic  
installations**

## **AS/NZS 3018:2001**

This Joint Australian/New Zealand Standard was prepared by Joint Technical Committee EL-001, Wiring Rules. It was approved on behalf of the Council of Standards Australia on 30 July 2001 and on behalf of the Council of Standards New Zealand on 1 August 2001. It was published on 25 September 2001.

---

The following interests are represented on Committee EL-001:

The Association of Consulting Engineers Australia  
Australian Building Codes Board  
Australian Electrical and Electronic Manufacturers Association  
Communications, Electrical Plumbing Union  
Electrical Contractors Association of New Zealand  
Electrical Contractors Association Qld  
Electrical Safety Organisation (New Zealand)  
Electricity Supply Association of Australia  
Institute of Electrical Inspectors  
Institution of Engineers Australia  
Insurance Council of Australia Limited  
Ministry of Economic Development New Zealand  
National Electrical and Communications Association  
New Zealand Council of Elders  
New Zealand Electrical Institute  
Regulatory authorities (electrical)  
Telstra Corporation Limited

---

### **Keeping Standards up-to-date**

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about joint Australian/New Zealand Standards can be found by visiting the Standards Australia web site at [www.standards.com.au](http://www.standards.com.au) or Standards New Zealand web site at [www.standards.co.nz](http://www.standards.co.nz) and looking up the relevant Standard in the on-line catalogue.

Alternatively, both organizations publish an annual printed Catalogue with full details of all current Standards. For more frequent listings or notification of revisions, amendments and withdrawals, Standards Australia and Standards New Zealand offer a number of update options. For information about these services, users should contact their respective national Standards organization.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Please address your comments to the Chief Executive of either Standards Australia International or Standards New Zealand at the address shown on the back cover.

---

AS/NZS 3018:2001  
(Incorporating Amendment No. 1)

Australian/New Zealand Standard™

## **Electrical installations—Domestic installations**

Originated as AS/NZS 3018:1997.  
Second edition 2001.  
Reissued incorporating Amendment No. 1 (July 2003).

### **COPYRIGHT**

© Standards Australia/Standards New Zealand

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher.

Jointly published by Standards Australia International Ltd, GPO Box 5420, Sydney, NSW 2001  
and Standards New Zealand, Private Bag 2439, Wellington 6020

ISBN 0 7337 4086 3

## PREFACE

This Standard was prepared by the Joint Standards Australia/Standards New Zealand Committee EL-001 on Wiring Rules.

*This Standard incorporates Amendment No. 1 (July 2003). The changes required by the Amendment are indicated in the text by a marginal bar and amendment number against the clause, note, table, figure or part thereof affected.*

The purpose of this Standard is to provide requirements and outline acceptable methods for installing electrical equipment in single domestic premises including alterations, additions and repairs. Sufficient information has been included to allow the completion of an electrical installation in a single domestic installation without reference to AS/NZS 3000.

The preparation of this Standard was undertaken following requests from a broad cross-section of the electricity industry for a simplified set of requirements applicable to domestic premises without the need for further reference to AS/NZS 3000 except for alternative methods.

It must be emphasized that this Standard does not attempt to include every installation method outlined in AS/NZS 3000. It contains simplified installation methods which are consistent with AS/NZS 3000 and are considered by the electrical industry to be the most common used for domestic installations. Therefore an installation carried out in accordance with this Standard should be considered as complying with AS/NZS 3000.

The simplified requirements include the following:

- (a) The use of circuit-breakers only.
- (b) The use of self-contained switchboards.
- (c) A recommendation that the switchboard be installed inside the dwelling.
- (d) Drawings of switchboards and circuit diagrams showing examples of arrangements including the use of Residual Current Devices (RCDs).
- (e) Tables providing information on voltage drop calculations based on the size of the consumers mains relevant to the determined demand and the length of the consumers mains and associated final subcircuits.
- (f) Tables providing guidance on the maximum number of points that may be connected to final subcircuits including mixed final subcircuits.
- (g) Drawings showing examples of various supply and metering arrangements.

Any requirements which may be applicable only in Australia or New Zealand are indicated by the symbol **A** or **NZ** in the right margin.

The terms 'normative' and 'informative' have been used in this Standard to define the application of the appendix to which they apply. A 'normative' appendix is an integral part of a Standard, whereas an 'informative' appendix is only for information and guidance.

Statements expressed in mandatory terms in notes to tables are deemed to be requirements of this Standard.

## CONTENTS

	<i>Page</i>
<b>SECTION 1 SCOPE AND GENERAL</b>	
1.1 SCOPE .....	8
1.2 APPLICATION .....	8
1.3 REFERENCED DOCUMENTS .....	9
1.4 DEFINITIONS .....	9
1.5 ARRANGEMENT .....	20
<b>SECTION 2 ELECTRICITY DISTRIBUTOR REQUIREMENTS</b>	
2.1 GENERAL.....	22
2.2 METHODS OF SUPPLY .....	22
2.3 METERING EQUIPMENT .....	26
<b>SECTION 3 CONSUMERS MAINS</b>	
3.1 GENERAL.....	30
3.2 CABLE TYPES .....	30
3.3 ASSUMED CONDITIONS .....	30
3.4 IDENTIFICATION .....	31
3.5 MAXIMUM DEMAND .....	31
3.6 VOLTAGE DROP.....	31
3.7 SIZE OF CONSUMERS MAINS .....	36
<b>SECTION 4 SWITCHBOARDS AND SWITCHGEAR</b>	
4.1 GENERAL.....	37
4.2 SWITCHBOARDS.....	37
4.3 MAIN SWITCHES .....	48
4.4 CIRCUIT PROTECTIVE DEVICES .....	48
<b>SECTION 5 EARTHING AND EQUIPOTENTIAL BONDING</b>	
5.1 GENERAL.....	51
5.2 EARTH ELECTRODE .....	51
5.3 MAIN EARTHING CONDUCTOR.....	51
5.4 MEN LINK.....	53
5.5 PROTECTIVE EARTHING CONDUCTORS.....	53
5.6 EQUIPOTENTIAL BONDING .....	54
5.7 INSTALLATION .....	56
<b>SECTION 6 SELECTION AND INSTALLATION OF CIRCUIT WIRING</b>	
6.1 GENERAL.....	57
6.2 TYPE .....	57
6.3 INSTALLATION REQUIREMENTS .....	57
6.4 BULK THERMAL INSULATION.....	60
6.5 DISTINGUISHING COLOURS OF CABLES.....	60

	<i>Page</i>
6.6 FINAL SUBCIRCUITS.....	61
6.7 NON-METALLIC CONDUIT .....	68
6.8 MARKING OF CABLES ENTERING OR LEAVING A BUILDING .....	68
<b>SECTION 7 ELECTRICAL EQUIPMENT</b>	
7.1 GENERAL.....	70
7.2 PREVENTION OF CONTACT BETWEEN LIVE PARTS AND CONDUCTIVE BUILDING MATERIALS.....	70
7.3 SWITCHES AND CEILING ROSES .....	70
7.4 ACCESSIBILITY .....	70
7.5 LIGHTING EQUIPMENT AND ACCESSORIES .....	70
7.6 SOCKET-OUTLETS.....	71
7.7 CONNECTION OF ELECTRICAL EQUIPMENT.....	72
7.8 ELECTRICAL CONNECTIONS.....	73
7.9 COOKING APPLIANCES.....	75
7.10 ROOM HEATERS.....	75
7.11 ELECTRIC HEATING CABLE SYSTEMS .....	76
7.12 WATER HEATERS .....	77
7.13 SMOKE ALARMS .....	77
7.14 DAMP SITUATIONS AND OUTDOOR AREAS .....	78
<b>SECTION 8 TESTING AND VERIFICATION</b>	
8.1 GENERAL.....	79
8.2 VISUAL INSPECTION .....	79
8.3 TESTING .....	81
<b>SECTION 9 REQUIREMENTS FOR ELECTRICAL INSTALLATIONS IN SPECIAL LOCATIONS</b>	
9.1 LOCATIONS CONTAINING BATHS, SHOWERS OR OTHER FIXED WATER CONTAINERS.....	87
9.2 SWIMMING POOLS, PADDLING POOLS AND SPA POOLS OR TUBS.....	98
<b>APPENDICES</b>	
A LIST OF REFERENCED DOCUMENTS.....	105
B TYPICAL MAXIMUM DEMAND CALCULATIONS .....	107
C MIXED FINAL SUBCIRCUITS.....	110
D VOLTAGE DROP.....	115
INDEX .....	120
ELECTRIC SHOCK SURVIVAL .....	132

## LIST OF TABLES

	<i>Page</i>
3.1 MAXIMUM DEMAND—CALCULATION.....	32
3.2 VOLTAGE DROP (Vd) IN CONSUMERS MAINS BASED ON MAXIMUM DEMAND AND CONDUCTOR SIZE .....	34
6.1 GUIDANCE ON THE NUMBER OF POINTS PER FINAL SUBCIRCUIT .....	62
6.2 VOLTAGE DROP (Vd) IN FINAL SUBCIRCUITS BASED ON MAXIMUM DEMAND AND CONDUCTOR SIZE.....	66
C1 GUIDANCE ON THE LOADING AND NUMBER OF POINTS PER MIXED FINAL SUBCIRCUIT .....	112

## LIST OF FIGURES

	<i>Page</i>
1.1 GUIDE TO TYPICAL ARRANGEMENT OF A DOMESTIC INSTALLATION (TO IDENTIFY SOME DEFINITIONS).....	21
2.1 (in part) EXAMPLES OF METHODS OF SUPPLY .....	23
2.2 (in part) EXAMPLES OF METERING ARRANGEMENTS.....	27
4.1 SWITCHBOARD WITH TWIN ELEMENT WATER HEATER AND WITH LIGHT AND POWER CIRCUITS PROTECTED BY INDIVIDUAL RCDs .....	38
4.2 SWITCHBOARD WITH SINGLE ELEMENT WATER HEATER AND WITH LIGHT AND POWER CIRCUITS PROTECTED BY TWO RCDs.....	40
4.3 INSTALLATION WITH TWIN ELEMENT WATER HEATER AND WITH LIGHT AND POWER CIRCUITS PROTECTED BY INDIVIDUAL RCDs .....	42
4.4 INSTALLATION WITH SINGLE ELEMENT WATER HEATER AND WITH LIGHT AND POWER CIRCUITS PROTECTED BY TWO RCDs.....	43
4.5 LOCATION AND ACCESSIBILITY OF A SWITCHBOARD IN OPEN AREA .....	44
4.6 LOCATION AND ACCESSIBILITY OF A SWITCHBOARD IN A CUPBOARD.....	45
4.7 RESTRICTED AREA SURROUNDING GAS CYLINDERS (BOTTLES).....	46
5.1 SCHEMATIC LAYOUT OF PROTECTIVE EARTHING AND EQUIPOTENTIAL BONDING CONDUCTORS.....	52
6.1 EXAMPLE OF PROTECTION REQUIREMENTS FOR WIRING.....	59
6.2 EXAMPLE OF CONDUIT INSTALLATION .....	69

	<i>Page</i>
8.1 TEST SEQUENCE.....	82
9.1A (in part) BATHS AND SHOWERS, ZONE DIMENSIONS PART I—BATHS.....	91
9.1A (in part) BATHS AND SHOWERS, ZONE DIMENSIONS PART II—SHOWER WITH A BASE.....	92
9.1A (in part) BATHS AND SHOWERS, ZONE DIMENSIONS PART III—SHOWER WITHOUT A BASE.....	93
9.1B (in part) BATHS AND SHOWERS, ZONE DIMENSIONS (PLAN) .....	94
9.1C BATHS AND SHOWERS, ZONE DIMENSIONS (ELEVATION) .....	96
9.1D FIXED WATER CONTAINERS OTHER THAN BATHS AND SHOWERS, ZONE DIMENSIONS .....	97
9.2A ZONE DIMENSIONS OF SWIMMING POOLS IN GROUND.....	103
9.2B ZONE DIMENSIONS OF SWIMMING POOLS ABOVE GROUND.....	103
9.2C ZONE DIMENSIONS OF SPA POOLS AND TUBS WITH WATER CAPACITY NOT EXCEEDING 5000 L.....	104

## STANDARDS AUSTRALIA/STANDARDS NEW ZEALAND

---

**Australian/New Zealand Standard**  
**Electrical installations—Domestic installations**

---

## SECTION 1 SCOPE AND GENERAL

**1.1 SCOPE**

This Standard sets out acceptable methods for electrical installations in single domestic premises, based on the requirements of AS/NZS 3000.

The requirements of AS/NZS 3000 are intended to protect persons, livestock and property from electric shock, fire and physical injury hazards that may arise from a domestic electrical installation that is used with reasonable care and with due regard to the intended purpose of the electrical installation.

**1.2 APPLICATION**

This Standard applies only to electrical installations in single domestic premises including alterations, additions and repairs. The requirements and methods outlined are intended to reflect common installation practices for domestic electrical installations connected to a multiple earthed neutral (MEN) system of earthing. This Standard is consistent with AS/NZS 3000 and includes sufficient definitions, information and illustrations to allow an electrical installation to be carried out without reference to AS/NZS 3000 except for alternative methods.

The requirements in this Standard are modelled on electrical installations with a maximum demand limit of 80 A single phase or 50 A per phase for multiphase, however they do not prohibit application for higher maximum demands.

NOTE: The connection of an electrical installation with a maximum demand in excess of 80 A to a single phase supply may depend on the requirements of the appropriate electricity distributor as they may have limitations on the maximum demand which may be connected to single phase supply.

Electricity distributors and regulatory authorities may have particular requirements which are normally contained in service rules and other documents.

NOTES: The particular requirements may be contained in —

- 1 electricity distributors Service Rules (e.g. matters related to supply and metering); and
- 2 AUSTEL TS 009 (e.g. the segregation of telecommunication cables from other wiring systems);