

Australian/New Zealand Standard™

**Installation couplers intended for
permanent connection in fixed
installations
(IEC 61535, Ed.1.0 (2009) MOD)**



AS/NZS 61535:2011

This Joint Australian/New Zealand Standard was prepared by Joint Technical Committee EL-004, Electrical Accessories. It was approved on behalf of the Council of Standards Australia on 17 October 2011 and on behalf of the Council of Standards New Zealand on 1 December 2011.

This Standard was published on 12 December 2011.

The following are represented on Committee EL-004:

Australian Industry Group
Consumer Electronics Suppliers Association
Consumers Federation of Australia
Electrical Compliance Testing Association
Electrical Regulatory Authorities Council
Engineers Australia
International Accreditation New Zealand
Ministry of Economic Development (New Zealand)
New Zealand Manufacturers and Exporters Association
NSW Office of Fair Trading
Plastics Industry Pipe Association of Australia
Testing Interests (Australia)

Keeping Standards up-to-date

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about joint Australian/New Zealand Standards can be found by visiting the Standards Web Shop at www.saiglobal.com.au or Standards New Zealand web site at www.standards.co.nz and looking up the relevant Standard in the on-line catalogue.

For more frequent listings or notification of revisions, amendments and withdrawals, Standards Australia and Standards New Zealand offer a number of update options. For information about these services, users should contact their respective national Standards organization.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Please address your comments to the Chief Executive of either Standards Australia or Standards New Zealand at the address shown on the back cover.

This Standard was issued in draft form for comment as DR AS/NZS 61535.1.

Australian/New Zealand Standard™

Installation couplers intended for permanent connection in fixed installations (IEC 61535, Ed.1.0 (2009) MOD)

Originated in Australia as AS 3131—1990.
First New Zealand edition AS/NZS 3131:1995.
Previous edition AS/NZS 61535.1:2003.
Jointly revised and redesignated as AS/NZS 61535:2011.

COPYRIGHT

© Standards Australia Limited/Standards New Zealand

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher, unless otherwise permitted under the Copyright Act 1968 (Australia) or the Copyright Act 1994 (New Zealand).

Jointly published by SAI Global Limited under licence from Standards Australia Limited, GPO Box 476, Sydney, NSW 2001 and by Standards New Zealand, Private Bag 2439, Wellington 6140.

PREFACE

This Standard was prepared by the Joint Standards Australia/Standards New Zealand Committee EL-004, Electrical Accessories, to supersede AS/NZS 61535.1:2003, *Installation couplers, Part 1: General requirements*. The 2003 edition will remain current for two years from the publication of this Standard. During this period it is anticipated industry will test and certify installation couplers to either Standard.

The objective of this Standard is to provide Australian and New Zealand industry (including manufacturers, test laboratories, regulators and installers) with general and safety requirements and test methods for installation couplers.

This Standard is an adoption with national modifications and has been reproduced from IEC 61535, Ed.1.0 (2009), *Installation couplers intended for permanent connection in fixed installations* and has been varied as indicated to take account of Australian/New Zealand conditions. The modifications are specified in Appendix ZZ.

As this Standard is reproduced from an International Standard, the following applies:

- (a) Its number appears on the cover and title page, while the International Standard number appears only on the cover.
- (b) In the source text 'this Standard' should read 'this Australian/New Zealand Standard'.
- (c) A full point substitutes for a comma when referring to a decimal marker.

References to International Standards should be replaced by references to Australian or Australian/New Zealand Standards, as follows:

<i>Reference to International Standard</i>		<i>Australian/New Zealand Standard</i>	
IEC		AS	
60529	Degrees of protection provided by enclosures (IP Code)	60529	Degrees of protection provided by enclosures (IP Code)
		AS/NZS	
60112	Method for the determination of the proof and the comparative tracking indices of solid insulating materials	60112	Method for the determination of the proof and the comparative tracking indices of solid insulating materials
60695	Fire hazard testing	60695	Fire hazard testing
60695-2-11	Part 2-11: Glowing/hot-wire based test methods—Glow-wire flammability test method for end-products	60695.2.11	Part 2.11: Glowing/hot wire based test methods—Glow-wire flammability test method for end-products

Only international references that have been adopted as Australian or Australian/New Zealand Standards have been listed.

The terms 'normative' and 'informative' have been used in this Standard to define the application of the annex or appendix to which they apply. A 'normative' annex or appendix is an integral part of a Standard, whereas an 'informative' annex or appendix is only for information and guidance.

CONTENTS

1	Scope.....	6
2	Normative references	6
3	Terms and definitions	7
4	General requirements	9
5	General notes on tests	9
6	Ratings.....	10
7	Classification.....	11
	7.1 rated impulse voltage:	11
	7.2 method of connecting the cable:	11
	7.3 degree of protection against ingress of foreign solid objects and ingress of water according to IEC 60529 (IP-Code)	11
	7.4 location where installation couplers will be installed:	11
	7.5 existence of an earthing contact:	11
	7.6 type of conductor to be connected:.....	11
	7.7 type of terminals for rewirable installation couplers only:	11
8	Marking and documentation.....	12
9	Dangerous compatibility	13
10	Protection against electric shock	14
11	Terminals, terminations and connectable conductors.....	15
	11.1 Terminals and terminations	15
	11.2 Connectable conductors	15
12	Construction.....	16
13	Protection against harmful ingress of solid foreign objects and against harmful ingress of water.....	19
	13.1 Protection against harmful ingress of foreign solid objects.....	19
	13.2 Protection against harmful ingress of water	19
14	Insulation resistance and electric strength	20
15	Construction of contacts	21
16	Temperature rise	22
17	Breaking capacity	22
18	Forces necessary to disengage the parts of the installation coupler.....	23
19	Cables and their connection	23
20	Mechanical strength	27
21	Resistance to heat and ageing	28
22	Screws, current-carrying parts and connections.....	30
23	Clearances, creepage distances and distances through solid insulation	32
24	Resistance to abnormal heat and to tracking	33
	24.1 Resistance to abnormal heat	33
	24.2 Resistance to tracking	35
25	Resistance to rusting.....	35
	Annex A (normative) Routine Earth (PE) continuity tests.....	37
	Annex B (normative) Test circuits for temperature rise test (see Clause 16).....	38

Annex C (normative) Number of sets of test samples used for the tests and sequence of tests for each set	43
Annex D (informative) Guide to use	45
Bibliography.....	47
Figure 1 – Apparatus for testing the cable anchorage	26
Figure 2 – Apparatus for the measuring of the distortion (example).....	27
Figure 3 – Ball-pressure apparatus	29
Figure 4 – Explanation of “small part”	35
Figure B.1 – 1P + N + PE installation couplers, including N (left figure), including PE (right figure).....	38
Figure B.2 – 3P + N + PE installation couplers, 3 phases loaded (left figure), N and PE loaded (right figure)	38
Figure B.3 – 1P + N + PE distribution block, phase and N loaded	39
Figure B.4 – 1P + N + PE distribution block, phase and PE loaded	40
Figure B.5 – 3P + N + PE - to 1P + N + PE distribution block, 3 phases loaded	41
Figure B.6 – 3P + N + PE - to 1P + N + PE distribution block, N and PE loaded.....	42
Figure D.1 – Examples of use of installation couplers	46
Table 1 – Voltage rating for installation couplers.....	10
Table 2 – Test currents for installation couplers	22
Table 3 – Forces to be applied to cable anchorages	24
Table 4 – Torque applied for the tightening and loosening test.....	31
Table 5 – Installation couplers intended for use in supply systems.....	32
Table 5a – Installation couplers intended for use in supply systems with a maximum voltage to earth of 150 V, rated impulse voltage 2,5 kV.....	32
Table 5b – Installation couplers intended for use in supply systems with a maximum voltage to earth of 300 V, rated impulse voltage 4,0 kV.....	33
Table C.1 – Sets of samples	43

FOREWORD

In this standard the following print types are used:

- requirements proper: in roman type;
- *test specifications: in italic type;*
- Explanatory matter: in smaller roman type.

AUSTRALIAN/NEW ZEALAND STANDARD

Installation couplers intended for permanent connection in fixed installations (IEC 61535, Ed.1.0 (2009) MOD)**1 Scope**

This standard applies to two up to five wire installation couplers including earth, if provided, with a rated voltage up to and including 500 V a.c. and a rated connecting capacity up to and including 10 mm² for permanent connection in indoor electrical installations. Installation couplers with additional contacts for voltages other than mains voltages are outside the scope of this standard.

NOTE 1 Installation couplers according to this standard are used e.g. in prefabricated buildings, installation cavities, such as suspended floors and ceilings, or cable tray systems, cable ladder systems, cable ducting systems and cable trunking systems or in commercial show rooms, in partition walls and in any similar application or in furniture complying with IEC 60364-7-713.

NOTE 2 This standard may be used as a guide for installation couplers with additional contacts for voltages other than mains voltages.

NOTE 3 In the UK, where installation couplers have more than 5 wires, they shall meet the requirements of IEC 61535 as though they were included in the scope and shall be tested in such a way that all of the mains voltage pins are subjected to the same level of testing.

NOTE 4 In the USA, these installation couplers are not permitted to be used where they will not be visible after installation.

An installation coupler consists of an installation female connector and an installation male connector for permanent connection not intended to be engaged or disengaged under load nor to be engaged or disengaged other than during first installation or during reconfiguration or maintenance of the wiring system in which installation couplers have been installed. This means that installation couplers are only intended for infrequent use.

Installation couplers are not suitable for use in place of socket-outlet systems. Installation couplers are not suitable for use in place of devices for connecting luminaires (DCLs) according to IEC 61995 or luminaire supporting couplers (LSCs).

NOTE 5 For lower limits of in-service temperatures the necessary information is given in the manufacturer's installation instructions.

In locations where special conditions prevail, as in ships, vehicles and the like and in hazardous locations, for example where explosions are liable to occur, special constructions may be required.

NOTE 6 Particular requirements for installation couplers e.g. for use at higher ambient temperatures, with higher mechanical durability (e.g. metal housings), with higher fire resistance and for use in control circuits (e.g. SELV), are under consideration.

NOTE 7 National rules may have requirements concerning the accessibility of installation couplers.

NOTE 8 Installation couplers are intended to be installed by instructed or skilled persons.

NOTE 9 National rules may specify who is allowed to carry out the connection and disconnection of installation couplers.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.