

Australian Standard™

**Insulators—Ceramic or glass—
Station post for indoor or outdoor use—
Voltages greater than 1000 V a.c.**

**Part 2: Tests
(IEC 60168, Ed. 4.2 (2001) MOD)**

This Australian Standard was prepared by Committee EL-010, Overhead Lines. It was approved on behalf of the Council of Standards Australia on 21 April 2005. This Standard was published on 24 May 2005.

The following are represented on Committee EL-010:

Australasian Railway Association
Australian Chamber of Commerce and Industry
Australian Electrical and Electronic Manufacturers Association
Australian Porcelain Insulators Association
Electricity Engineers Association (New Zealand)
Energy Networks Association

Keeping Standards up-to-date

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about Standards can be found by visiting the Standards Web Shop at www.standards.com.au and looking up the relevant Standard in the on-line catalogue.

Alternatively, the printed Catalogue provides information current at 1 January each year, and the monthly magazine, *The Global Standard*, has a full listing of revisions and amendments published each month.

Australian Standards™ and other products and services developed by Standards Australia are published and distributed under contract by SAI Global, which operates the Standards Web Shop.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Contact us via email at mail@standards.org.au, or write to the Chief Executive, Standards Australia, GPO Box 5420, Sydney, NSW 2001.

This Standard was issued in draft form for comment as DR 05020.

Australian Standard™

**Insulators—Ceramic or glass—
Station post for indoor or outdoor use—
Voltages greater than 1000 V a.c.**

**Part 2: Tests
(IEC 60168, Ed. 4.2 (2001) MOD)**

Originated as part of AS 1137.3—1972.
Revised and redesignated in part as AS 4398.2—1996.
Second edition 2005.

COPYRIGHT

© Standards Australia

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher.

Published by Standards Australia, GPO Box 5420, Sydney, NSW 2001, Australia

ISBN 0 7337 6690 0

PREFACE

This Standard was prepared by the Australian members of the Joint Standards Australia/Standards New Zealand Committee EL-010, Overhead Lines, to supersede AS 4398.2—1996. After consultation with stakeholders in both countries, Standards Australia and Standards New Zealand decided to develop this Standard as an Australian, rather than Australian/New Zealand Standard.

The objective of this Standard is to provide users and manufacturers of station post insulators with definitions and terms, test methods and acceptance criteria to facilitate their specification.

This Standard is an adoption with national modifications and has been reproduced from IEC 60168, Ed. 4.2 (2001), *Tests on indoor and outdoor post insulators of ceramic material or glass for systems with nominal voltages greater than 1000 V*.

Variations to IEC 60168, Ed. 4.2 (2001) are indicated at the appropriate places throughout this standard. Strikethrough (~~example~~) identifies IEC text, tables and figures which, for the purposes of this Australian Standard, are deleted. Where text, tables or figures are added, each is set in its proper place and identified by shading (example). Added figures are not themselves shaded, but are identified by a shaded border.

As this Standard is reproduced from an International Standard, the following applies:

- (a) Its number does not appear on each page of text and its identity is shown only on the cover and title page.
- (b) In the source text ‘this international standard’ should read ‘this Australian Standard’.
- (c) A full point should be substituted for a comma when referring to a decimal marker.
- (d) Any French text on figures should be ignored.

The term ‘informative’ is used to define the application of the annex to which it applies. An informative annex is only for information and guidance.

CONTENTS

	<i>Page</i>
Section 1 - General	1
1.1 Scope and object	1
1.2 Normative references	2
1.3 Definitions	3
Section 2 - Insulators	6
2.1 Insulator designs and insulating materials	6
2.2 Values which characterize a post insulator	6
2.3 Identification of insulators	7
Section 3 - Classification of the tests, sampling rules and procedures	8
3.1 Classification of the tests	8
3.2 Quality assurance	8
3.3 General requirements for type tests	8
3.4 General requirements for sample tests	10
Section 4 - Test procedures for electrical tests	12
4.1 General requirements for high-voltage tests	12
4.2 Standard atmospheric conditions and correction factors for electrical tests	12
4.3 Artificial rain parameters for wet tests	12
4.4 Mounting arrangements for electrical tests	13
4.5 Dry lightning-impulse withstand voltage test – Type test	14
4.6 Dry or wet switching-impulse withstand voltage tests – Type test	15
4.7 Dry power-frequency withstand voltage test – Type test (applicable only to post insulators for indoor use)	16
4.8 Wet power-frequency withstand voltage test – Type test (applicable only to post insulators for outdoor use)	16
4.9 Puncture test – Sample test	17
4.10 Routine electrical test	17
Section 5 - Test procedures for mechanical and other tests	19
5.1 Verification of the dimensions – Type and sample test	19
5.2 Mechanical failing load test – Type and sample test	20
5.3 Test for deflection under load – Special type test	22
5.4 Temperature cycle test – Sample test	22
5.5 Routine thermal shock test (applicable only to toughened glass insulating parts)	23
5.6 Porosity test – Sample test (applicable only to ceramic post insulators)	24
5.7 Galvanizing test – Sample test	24
5.8 Routine visual inspection	26
5.9 Routine mechanical test	27
Section 6 - Tests applicable to post insulators	29
6.1 Type tests	29
6.2 Sample tests	29
6.3 Routine tests	30
6.4 Summary of tests on post insulators	30

Annex A (informative) Methods of testing for tolerances of parallelism, eccentricity, angular deviation, camber, and shed angle of post insulators.....	34
Annex B (informative) Methods of routine testing of unassembled insulator units	37
Annex C (informative) Bibliography	40
Figure 1 – Solid core cylindrical post insulator.....	32
Figure 2 – Cavity core cylindrical post insulator.....	32
Figure 3 – Cylindrical post insulator with internal metal fittings	32
Figure 4 – Cylindrical post insulator with internal metal fittings	33
Figure 5 – Pedestal post insulator	33
Figure 6 – Cylindrical post insulator.....	33
Figure A.1	34
Figure A.2	35
Figure A.3	35
Figure A.4	36
Figure A.5	36
Figure B.1	37
Figure B.2	38
Figure B.3	39
Table 1 – Number of samples for sample tests	10
Table 2 – Mounting height of outdoor post insulators.....	13
Table 3 – Type tests applicable to post insulators	30
Table 4 – Sample tests applicable to post insulators	31
Table 5 – Routine tests applicable to post insulators	31

STANDARDS AUSTRALIA

Australian Standard**Insulators—Ceramic or glass—
Station post for indoor or outdoor use—Voltages greater than 1000 V a.c.
Part 2: Tests
(IEC 60168, Ed. 4.2 (2001) MOD)**

Section 1 - General**1.1 Scope and object**

This International Standard IEC 60168 is applicable to post insulators and post insulator units of ceramic material or glass, for indoor and outdoor use in electrical installations or equipment, operating on alternating current with a nominal voltage greater than 1 000 V and a frequency not greater than 100 Hz.

This standard may be regarded as a provisional standard for post insulators for use on d.c. systems. IEC 60438 gives general guidance for those insulators.

This standard does not apply to composite insulators, or to those indoor post insulators in organic material which are covered by another IEC standard [1]*.

The object of this standard is to define:

- the terms used;
- the electrical and mechanical characteristics of post insulators;
- the conditions under which the specified values of these characteristics are verified;
- the methods of test;
- the acceptance criteria.

Numerical values of characteristics of post insulators are specified in IEC 60273.

This standard does not include requirements dealing with the choice of post insulators for specific operating conditions.

AS 1137.3—1981 has been retained as an obsolescent Standard. It is not recommended for new equipment or to be used in current practice, but is retained to provide for servicing of existing equipment or requirements. In some conditions of high pollution, a purchaser may wish to specify tests in accordance with AS 1137.3—1981.

NOTE 1 A guide for the choice of insulators under polluted conditions is available, see [2].

NOTE 2 This standard does not include radio interference tests or artificial pollution tests. These subjects and relevant test methods are dealt with in other IEC publications, see [3], [4] and [5].

NOTE 3 When this standard is applied to hollow post insulators, other IEC publications should also be taken into account, see [6] and [7].

* The figures in square brackets refer to annex C (Bibliography).