

Australian Standard™

Programmable controllers

Part 7: Fuzzy control programming

This Australian Standard was prepared by Committee IT-006, Information Technology for Industrial Automation. It was approved on behalf of the Council of Standards Australia on 15 January 2004 and published on 22 March 2004.

The following are represented on Committee IT-006:

Association of Consulting Engineers Australia
Australian Electrical and Electronic Manufacturers Association
CSIRO Centre for Planning and Design
CSIRO Manufacturing and Infrastructure Technology
Department of Defence (Australia)
Institute of Instrumentation, Control and Automation, Australia
Institution of Engineers Australia
Monash University
RMIT University
The University of Melbourne

Keeping Standards up-to-date

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about Standards can be found by visiting the Standards Web Shop at www.standards.com.au and looking up the relevant Standard in the on-line catalogue.

Alternatively, the printed Catalogue provides information current at 1 January each year, and the monthly magazine, *The Global Standard*, has a full listing of revisions and amendments published each month.

Australian Standards™ and other products and services developed by Standards Australia are published and distributed under contract by SAI Global, which operates the Standards Web Shop.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Contact us via email at mail@standards.org.au, or write to the Chief Executive, Standards Australia International Ltd, GPO Box 5420, Sydney, NSW 2001.

Australian Standard™

Programmable controllers

Part 7: Fuzzy control programming

First published as AS IEC 61131.7—2004.

COPYRIGHT

© Standards Australia International

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher.

Published by Standards Australia International Ltd
GPO Box 5420, Sydney, NSW 2001, Australia

ISBN 0 7337 5775 8

PREFACE

This Standard was prepared by the Standards Australia Committee IT-006, Information Technology for Industrial Automation.

This Standard is identical with, and has been reproduced from, IEC 61131-7:2000, *Programmable controllers—Part 7: Fuzzy control programming*.

The objective of this Standard is to offer the manufacturers and the users a well-defined common understanding of the basic means to integrate fuzzy control applications in the Programmable Controller languages according to AS IEC 61131-3, as well as the possibility to exchange portable fuzzy control programs among different programming systems.

This Standard is Part 7 of AS IEC 61131 *Programmable controllers*, which consists of the following:

Part 1: General information

Part 2: Equipment requirements and tests

Part 3: Programming languages

Part 4: User guidelines

Part 5: Communications

Part 7: Fuzzy control programming (this Standard)

Part 8: Guidelines for the application and implementation of programming languages

AS IEC 61131 does not have a Part 6. A project to develop IEC 61131-6 *Programmable controller communications via field bus* was deleted in September 2000 by the IEC.

In this Standard, the following print types are used:

- requirements proper: in arial type;
- *test specifications: in italic type;*
- explanatory matter: in smaller arial type.

As this Standard is reproduced from an International Standard, the following applies:

- (a) Its number does not appear on each page of text and its identity is shown only on the cover and title page.
- (b) In the source text ‘this part of IEC 61131’ should read ‘this part of AS IEC 61131’.
- (c) A full point should be substituted for a comma when referring to a decimal marker.

CONTENTS

	<i>Page</i>
INTRODUCTION	vi
1 Scope and object	1
2 Normative references	1
3 Definitions	2
4 Integration into the programmable controller	4
5 Fuzzy Control Language FCL	5
5.1 Exchange of fuzzy control programs	5
5.2 Fuzzy Control Language elements	5
5.3 FCL example	14
5.4 Production rules and keywords of the Fuzzy Control Language (FCL)	14
6 Compliance	18
6.1 Conformance classes of Fuzzy Control Language FCL	18
6.2 Data check list	20
Annex A (informative) Theory	22
A.1 Fuzzy Logic	22
A.2 Fuzzy Control	25
A.3 Performance of Fuzzy control	32
Annex B (informative) Examples	35
B.1 Pre-control	35
B.2 Parameter adaptation of conventional PID controllers	36
B.3 Direct fuzzy control of a process	36
Annex C (informative) Industrial example – Container crane	37
Annex D (informative) Example for using variables in the rule block	48
Annex E (informative) Symbols, abbreviations and synonyms	50
Figure 1 – Example of a fuzzy control Function Block in FBD representation	4
Figure 2 – Data exchange of Programs in Fuzzy Control Language (FCL)	5
Figure 3 – Example of a Function Block interface declaration in ST and FBD languages	6
Figure 4 – Example of ramp terms	7
Figure 5 – Example of usage of variables for membership functions	8
Figure 6 – Example of singleton terms	8
Figure 7 – Example for fuzzy function block	14
Figure 8 – Levels of conformance	18
Figure A.1 – Membership functions of the terms "full legal age" and "adult"	22
Figure A.2 – Description of the linguistic variable "Age" by linguistic terms and their hierarchy on the time scale (age in years)	23
Figure A.3 – Commonly used shapes of membership functions	23

	<i>Page</i>
Figure A.4 – Algorithms for implementing operations between two membership functions	25
Figure A.5 – Structure and functional elements of fuzzy control.....	26
Figure A.6 – The principle of fuzzification (as an example)	26
Figure A.7 – Representation of the knowledge base in linguistic form.....	27
Figure A.8 – Matrix representation of two variables	27
Figure A.9 – Elements of inference.....	28
Figure A.10a – An example showing the principles of aggregation.....	29
Figure A.10b – The principles of activation (as an example)	29
Figure A.10c – The principles of accumulation (as an example).....	30
Figure A.11a – Methods of defuzzification	30
Figure A.11b – Difference between Left Most Maximum and Right Most Maximum	31
Figure A.11c – Difference between Centre of Area and Centre of Gravity	31
Figure A.11d – Methods of defuzzification	32
Figure A.12 – Examples of fuzzy control characteristic curves.....	33
Figure A.13a – Fuzzy-based controller: Fundamental structure.....	33
Figure A.13b – Example of a Fuzzy-based controller	34
Figure B.1 – Example of a pre-control	35
Figure B.2 – Example of a parameter adaptation	36
Figure B.3 – Example of a direct fuzzy control.....	36
Figure C.1 – Industrial example – Container crane	37
Figure C.2 – Linguistic variable "Distance" between crane head and target position	38
Figure C.3 – Linguistic variable "Angle" of the container to the crane head.....	38
Figure C.4 – Linguistic variable "Power"	39
Figure C.5 – Rule base.....	39
Figure C.6 – Fuzzification of the linguistic variable "distance".....	40
Figure C.7 – Fuzzification of the linguistic variable "angle"	40
Figure C.8 – Subset of three rules	41
Figure C.9 – Elements of aggregation	41
Figure C.10 – Principles of aggregation.....	42
Figure C.11 – Elements of activation	42
Figure C.12 – Principles of activation	43
Figure C.13 – Elements of accumulation	43
Figure C.14 – Principles of accumulation.....	44
Figure C.15 – Defuzzification	45
Figure C.16 – Example in SCL	46
Figure D.1 – Principle of the controlled system.....	48
Figure D.2 – Principle of the fuzzy based control of the oven.....	48
Figure D.3 – Rule block.....	48
Figure D.4 – Example in FCL.....	49

	<i>Page</i>
Table 1 – Defuzzification methods	9
Table 2 – Formulae for defuzzification methods	9
Table 3 – Paired algorithms	10
Table 4 – Activation methods	11
Table 5 – Accumulation methods	11
Table 6 – Priority of operators	12
Table 7 – Reserved keywords for FCL	17
Table 8 – FCL Basic Level language elements (mandatory).....	19
Table 9 – FCL Extension Level language elements (optional)	20
Table 10 – Examples of a list with Open Level language elements	20
Table 11 – Data check list	21
Table A.1 – Inference steps and commonly used algorithms.....	29
Table C.1 – Inference steps and assigned operator	39
Table E.1 – Symbols and abbreviations	50
Table E.2 – Synonyms.....	50

INTRODUCTION

The theory of fuzzy logic in the application of control is named fuzzy control. Fuzzy control is emerging as a technology that can enhance the capabilities of industrial automation, and is suitable for control level tasks generally performed in Programmable Controllers (PC).

Fuzzy control is based upon practical application knowledge represented by so-called linguistic rule bases, rather than by analytical (either empirical or theoretical) models. Fuzzy control can be used when there is an expertise that can be expressed in its formalism. That allows to take available knowledge to improve processes and perform a variety of tasks, for instance

- control (closed or open loop, single or multi-variable, for linear or non-linear systems),
- on-line or off-line setting of control systems' parameters,
- classification and pattern recognition,
- real-time decision making (send this product to machine A or B ?),
- helping operators to make decisions or tune parameters,
- detection and diagnosis of faults in systems.

Its wide range of applications and natural approach based on human experience makes fuzzy control a basic tool that should be made available to programmable controller users as a standard.

Fuzzy control can also, in a straightforward way, be combined with classical control methods.

The application of fuzzy control can be of advantage in such cases where there is no explicit process model available, or in which the analytical model is too difficult to evaluate or when the model is too complicated to evaluate in real time.

Another advantageous feature of fuzzy control is that human experience can be incorporated in a straightforward way. Also, it is not necessary to model the whole controller with fuzzy control: sometimes fuzzy control just interpolates between a series of locally linear models, or dynamically adapts the parameters of a "linear controller", thereby rendering it non-linear, or alternatively just "zoom in" onto a certain feature of an existing controller that needs to be improved.

Fuzzy control is a multi-valued control, no longer restricting the values of a control proposition to "true" or "false". This makes fuzzy control particularly useful to model empirical expertise, stating which control actions have to be taken under a given set of inputs.

The existing theory and systems already realized in the area of fuzzy control differ widely in terms of terminology (definitions), features (functionalities) and implementation (tools).

Fuzzy control is used from small and simple applications up to highly sophisticated and complex projects. To cover all kinds of usage in this part of IEC 61131, the features of a compliant fuzzy control system are mapped into defined conformance classes.

The basic class defines a minimum set of features which has to be achieved by all compliant systems. This facilitates the exchange of fuzzy control programs.

Optional standard features are defined in the extension class. Fuzzy control programs applying these features can only be fully ported among systems using the same set of features, otherwise a partial exchange may be possible only. This standard does not force all compliant systems to realize all features in the extension class, but it supports the possibility of (partial) portability and the avoidance of the usage of non-standard features. Therefore, a compliant system should not offer non-standard features which can be meaningfully realized by using standard features of the basic class and the extension class.

In order not to exclude systems using their own highly sophisticated features from complying with this part of IEC 61131 and not to hinder the progress of future development, this standard permits also additional non-standard features which are not covered by the basic class and the extension class. However, these features need to be listed in a standard way to ensure that they are easily recognised as non-standard features.

The portability of fuzzy control applications depends on the different programming systems and also the characteristics of the control systems. These dependencies are covered by the data check list to be delivered by the manufacturer.

STANDARDS AUSTRALIA

Australian Standard**Programmable controllers**
Part 7: Fuzzy control programming

1 Scope and object

This part of IEC 61131 defines a language for the programming of Fuzzy Control applications used by programmable controllers.

The object of this part of IEC 61131 is to offer the manufacturers and the users a well-defined common understanding of the basic means to integrate fuzzy control applications in the Programmable Controller languages according to IEC 61131-3, as well as the possibility to exchange portable fuzzy control programs among different programming systems.

To achieve this, annex A gives a short introduction to the theory of fuzzy control and fuzzy logic as far as it is necessary for the understanding of this part of IEC 61131. It may be helpful for readers of this part of IEC 61131 who are not familiar with fuzzy control theory to read annex A first.

2 Normative references

References to international standards that are struck through in this clause are replaced by references to Australian or Australian/New Zealand Standards that are listed immediately thereafter and identified by shading. Any Australian or Australian/New Zealand Standard that is identical to the International Standard it replaces is identified as such.

The following normative documents contain provisions which, through reference in this text, constitute provisions of this part of IEC 61131. For dated references, subsequent amendments to, or revisions of, any of these publications do not apply. However, parties to agreements based on this part of IEC 61131 are encouraged to investigate the possibility of applying the most recent editions of the normative documents indicated below. For undated references, the latest edition of the normative document referred to applies. Members of IEC and ISO maintain registers of currently valid International Standards.

IEC 60050-351:1998, *International Electrotechnical Vocabulary (IEV) – Part 351: Automatic control*

~~IEC 61131-3:1993, *Programmable controllers – Part 3: Programming languages*~~

AS IEC 61131.3, *Programmable controllers—Part 3: Programming languages* (identical)