

Australian Standard 2238—1982

ELECTRICAL EQUIPMENT FOR EXPLOSIVE ATMOSPHERES NON-SPARKING APPARATUS TYPE OF PROTECTION n



STANDARDS ASSOCIATION OF AUSTRALIA
Incorporated by Royal Charter

THE FOLLOWING SCIENTIFIC, INDUSTRIAL AND GOVERNMENTAL ORGANIZATIONS and departments were officially represented on the committee entrusted with the preparation of this standard:

Australian Coal Association
Australian Electrical and Electronics Manufacturers Association
Australian Institute of Petroleum
Confederation of Australian Industry
Department of Industrial Relations, N.S.W.
Department of Industry and Commerce
Department of Mineral Resources, N.S.W.
Department of Minerals and Energy, Vic.
Department of Mines, Qld
Electrical Contractors Associations of Australia
Electricity Supply Association of Australia
Independent testing interests
Insurance Council of Australia
State electricity regulatory authorities

This standard, prepared by Committee EL/14, Electrical Equipment in Hazardous Locations, was approved on behalf of the Council of the Standards Association of Australia on 24 September 1981, and was published on 25 January 1982.

To keep abreast of progress in industry, Australian standards are subject to continuous review and are kept up-to-date by the issue of amendments or new editions as necessary. It is important therefore that standards users ensure that their standards are up-to-date. Full details of all SAA publications will be found in the Annual List of Australian Standards; these details are supplemented by listings in the SAA monthly journal 'The Australian Standard'. Information on the Annual List and 'The Australian Standard' may be obtained from any sales office of the Association, where details are also available of the current status of individual standards. Suggestions for improvements to published standards, addressed to the head office of the Association, are welcomed.

AUSTRALIAN STANDARD

**ELECTRICAL EQUIPMENT FOR
EXPLOSIVE ATMOSPHERES
NON-SPARKING APPARATUS
TYPE OF PROTECTION n**

AS 2238—1982

First published	1979
Second edition.....	1982
Amended	April 1983
Reprinted incorporating Amdt.....	1985

**PUBLISHED BY THE STANDARDS ASSOCIATION OF AUSTRALIA
STANDARDS HOUSE, 80 ARTHUR ST, NORTH SYDNEY, N.S.W.**

ISBN 0 7262 2430 8

PREFACE

This standard was prepared by the Association's Committee on Electrical Equipment in Hazardous Locations. It supersedes AS 2238—1979 and is intended for the guidance of manufacturers, users, statutory authorities and associated interests, and for use with the SAA Wiring Rules (AS 3000) and relevant mining regulations.

In its terminology, definitions and general treatment of the subject this standard is similar to corresponding draft recommendations issued by the International Electrotechnical Commission (IEC) under document reference 31(Secretariat)109 and acknowledgement is made of the assistance received from that source.

The major changes in this edition are as follows:

- (a) Reference is made to AS 2380, Part 1 for grouping of apparatus, temperature classification and marking.
- (b) New requirements have been introduced for winding wires.
- (c) Requirements for fluorescent lamp starter holders have been deleted.
- (d) The voltage for the dielectric strength test has been reduced to 1000 V.

This standard requires reference to the following standards:

AS 1076	Code of Practice for Selection, Installation and Maintenance of Electrical Apparatus and Associated Equipment for Use in Explosive Atmospheres (Other Than Mining Applications) Part 1—Basic Requirements Part 7—Apparatus with Type of Protection n—Non-sparking Apparatus
AS 1194	Winding Wire
AS 1201	Tubular Fluorescent Lamps for General Lighting Service Part 1—Test and Compliance Requirements

AS 1468	Ballasts for High Pressure Mercury Vapour and Low Pressure Sodium Vapour Discharge Lamps
AS 1593	Electrical Equipment for Explosive Atmospheres—Increased Safety Apparatus—Type of Protection e
AS 1829	Intrinsically Safe Electrical Apparatus for Explosive Atmospheres
AS 1896	Method of Test for Ignition Temperature of Gases and Vapours
AS 1939	Classification of Degrees of Protection Provided by Enclosures for Electrical Equipment
AS 2236	Dust-excluding Ignition-proof Enclosure of Electrical Equipment
AS 2380	Electrical Equipment for Explosive Gas Atmospheres—Explosion Protection Techniques Part 1—General Requirements
AS 2430	Classification of Hazardous Areas Part 1—Explosive Gas Atmospheres
AS 3000	SAA Wiring Rules
AS 3100	Approval and Test Specification for Definitions and General Requirements for Electrical Materials and Equipment
AS 3117	Approval and Test Specification for Bayonet Lampholders
AS 3140	Approval and Test Specification for Edison-type Screw Lampholders
IEC 61	Lamp Caps and Holders Together with Gauges for the Control of Interchangeability and Safety
IEC 155	Starters for Fluorescent Lamps
IEC 162	Luminaires for Tubular Fluorescent Lamps
IEC 238	Edison Screw Lampholders
IEC 262	Ballasts for High Pressure Mercury Vapour Lamps
IEC 400	Lampholders and Starterholders for Tubular Fluorescent Lamps

© Copyright — STANDARDS ASSOCIATION OF AUSTRALIA 1982

Users of standards are reminded that copyright subsists in all SAA publications. No part of this publication may be reproduced, stored in a retrieval system in any form or transmitted by any means without prior permission in writing of the Standards Association of Australia.

CONTENTS

	<i>Page</i>
FOREWORD	4
SECTION 1. SCOPE AND GENERAL	
1.1 Scope	5
1.2 Application	5
1.3 Definitions	5
1.4 Grouping of Apparatus	5
1.5 Temperature Classification	5
SECTION 2. DESIGN AND CONSTRUCTION	
2.1 Potential Ignition Sources	6
2.2 Enclosures	6
2.3 Connection Facilities	6
2.4 Protection of Wiring	6
2.5 Clearances, Separations and Creepage Distances	6
2.6 Windings	7
SECTION 3. MARKING	
3.1 General	8
3.2 Examples	8
SECTION 4. INHERENTLY NON-SPARKING APPARATUS	
4.1 General	9
4.2 Rotating Machines	9
4.3 Fuses and Fuse Assemblies	9
4.4 Plugs and Sockets	9
4.5 Luminaires	10
4.6 Instruments and Low Power Apparatus	10
SECTION 5. APPARATUS PRODUCING OPERATIONAL ARCS, SPARKS OR HOT SURFACES	
5.1 General	11
5.2 Enclosed-break Devices and Non-incendive Components	11
5.3 Hermetically Sealed Device	11
5.4 Sealed Device	11
5.5 Energy Limitation	11
5.6 Restricted-breathing Enclosures	11
SECTION 6. TESTS	
6.1 General	12
6.2 Experimental Tests	12
6.3 Winding Insulation	12
6.4 Impact Tests	12
6.5 Dielectric Strength Test	13
6.6 Screw Lampholder Test	13
6.7 Gasket and Seal Test	13
6.8 Type Test for Apparatus Producing Arcs Sparks or Hot Surfaces	13
6.9 Test for Sealed Devices	13
6.10 Energy Limitation Test	13
6.11 Type Tests for Restricted-breathing Enclosures	15
6.12 Tests for Temperature Classification	15
6.13 Tests in Compliance with AS C100	15
6.14 Agreement with Drawings	15
APPENDICES	
A Igniting Current Data	16
B Restricted-breathing Enclosures	23

STANDARDS ASSOCIATION OF AUSTRALIA

Australian Standard

for

**ELECTRICAL EQUIPMENT FOR EXPLOSIVE ATMOSPHERES—NON-SPARKING
APPARATUS—TYPE OF PROTECTION n**

FOREWORD

The purpose of this standard is to establish the essential constructional features, test requirements and marking requirements for non-sparking electrical apparatus which may be used in areas which are not normally hazardous, and in which an explosive concentration of flammable gas or vapour, if it occurs, will exist for only a short time. The risk of the presence simultaneously of an explosive atmosphere and a source of ignition is considered to be acceptably low.

The requirements which apply to inherently non-sparking electrical apparatus are specified in Section 4 of this standard. Measures are specified in Section 5 which may be applied to those parts of apparatus or circuits which arc or spark or generate hot surfaces in normal operation, and which must, therefore, be suitably protected so that the risk of ignition of an external explosive atmosphere is reduced to an acceptable level.

The classification of hazardous areas is dealt with in AS 2430, Parts 1 and 2. Part 1 applies to explosive gas atmospheres and recognizes the following zones:

Zone 0—an area in which an explosive gas atmosphere is present continuously, or is expected to be present for long periods, or for short periods which occur with high frequency.

Zone 1—an area in which an explosive gas atmosphere can be expected to occur periodically or occasionally during normal operation.

Zone 2—an area in which an explosive gas atmosphere is not expected to occur in normal operation and if it occurs is likely to be present only infrequently and for short duration.

Enclosures complying with this standard will be suitable for installation in a Zone 2 area.

It should be noted that this concept of area classification deals only with risks due to combustible gas and vapours and, by implication, mists.

This standard does not deal with risks due to the presence of combustible dusts.

General constructional requirements are specified in Section 2.

Examples of equipment which may be made to comply with this standard include electric motors, switches and luminaires.

SECTION 1. SCOPE AND GENERAL

1.1 SCOPE. This standard specifies requirements for the construction, assessment and test of non-sparking electrical apparatus which, when operating normally within its rated duty, will not ignite a surrounding explosive atmosphere.

It specifies the features of apparatus which are assessed to achieve a statistically satisfactory level of safety for apparatus in areas which are not normally hazardous.

1.2 APPLICATION. This standard prescribes the minimum requirements for the safety of apparatus in Zone 2*. It supplements the requirements for apparatus for non-hazardous areas as stated in other standards.

The requirements of this standard shall apply in so far as they are essential to the safety of the apparatus. Specific test requirements may be omitted if they are judged to be unnecessary for safety and if justification is given in the documentation.

NOTES:

1. If the electrical apparatus has to withstand particular adverse service conditions, e.g. rough handling, humidity effects, temperature variations of ambient air, gas or vapours, these should be agreed upon between purchaser and manufacturer.
2. When choosing electrical apparatus, the purchaser should take into account the influence and the smouldering temperature of any dusts which are likely to be deposited in a layer. (See Appendix A of AS 2236.)
3. The metal of current-carrying parts, including those in earth continuity paths, should be selected so as to take into account the possible effects of galvanic corrosion arising from dissimilar metals in direct contact.
4. Where necessary, adequate means of earthing shall be provided.

1.3 DEFINITIONS. For the purpose of this standard, the following definitions apply:

1.3.1 Clearance—the shortest distance through air between two conducting parts.

1.3.2 Creepage distance—the shortest distance between two conducting parts along the surface of the insulating parts.

1.3.3 Enclosed-break device—a device which incorporates electrical contacts that are made and broken, which has a net volume not greater than 20 cm³, and which will withstand an internal explosion of the flammable gas or vapour which may enter it without suffering damage and without communicating the internal flammation to the external flammable gas or vapour.

1.3.4 Enclosure—the external casing protecting the electrical and mechanical parts of apparatus.

NOTE: The term excludes cables.

1.3.5 Energy limitation—the concept of restriction of energy at sparking contacts in normal operation to non-incendive levels, and limitation of surface temperatures to ensure safety.

1.3.6 Hermetically sealed device—a device which is so constructed that the external atmosphere cannot gain access to the interior and in which the seal is made by fusion, e.g. soldering, brazing, welding or the fusion of glass to metal.

1.3.7 Non-incendive component—a component with contacts for making and breaking a potentially incendive circuit where either the contacting mechanism or the enclosure in which the contacts are

housed is so constructed that the component prevents ignition of the prescribed flammable gas or vapour under specified operating conditions.

NOTES

1. Non-incendive components are limited to a maximum rating of 250 V and 15 A, and a net volume of not greater than 20 cm³.
2. A non-incendive component is limited in use to the particular circuit for which it has been shown to be non-ignition capable.

1.3.8 Sealed device—a device containing normally arcing parts or hot surfaces which is so constructed that it cannot be opened during normal service and has a free internal volume of less than 100 cm³, and is sealed to effectively prevent entry of an external atmosphere.

1.3.9 Separation—the shortest distance between two conducting parts through solid insulating material.

1.3.10 Type of Protection n—a type of protection applied to electrical apparatus such that, in normal operation, it is not capable of igniting a surrounding explosive atmosphere and a fault capable of causing ignition is not likely to occur.

1.4 GROUPING OF APPARATUS. Non-sparking apparatus shall be grouped in accordance with Clause 1.5 of AS 2380, Part 1, except that non-sparking apparatus shall not be grouped as Group I.

1.5 TEMPERATURE CLASSIFICATION.

1.5.1 General. Apparatus shall be classified in accordance with Clause 1.6 of AS 2380, Part 1.

1.5.2 Permissible Excess Temperatures. Surface temperatures higher than indicated by the marked temperature classification can be permitted for small components, e.g. transistors or resistors, if it has been shown by test that there is no direct or indirect risk of ignition.

For other apparatus, surface temperatures higher than indicated by the marked temperature classification are permissible provided that it is shown by test that the maximum surface temperature is at least 50 K † below the lowest temperature at which ignition of the specified explosive gas/air mixture or mixtures will occur under the intended conditions of use. This is valid only for the flammable gases and vapours specified in the accompanying documentation, and the apparatus shall be marked with the restriction of application.

1.5.3 Unclassified Temperatures. Where apparatus is designed for a particular application or is designed for a maximum surface temperature greater than 450°C, the limiting temperature for accessible surfaces shall be marked on the apparatus in accordance with the requirements of Section 3.

1.5.4 Components of Luminaires. Auxiliary components of luminaires shall be classified in accordance with Clause 4.5.3.

1.5.5 Marking of Lamp Rating. Luminaires shall be marked with the lamp rating appropriate to the temperature class.

*As classified in accordance with AS 2430, Part 1.

†K = kelvin. For temperature difference 1 K = 1°C.

SECTION 2. DESIGN AND CONSTRUCTION

2.1 POTENTIAL IGNITION SOURCES. The apparatus shall not in normal operation—

- (a) produce an arc or spark unless the operational arc or spark is prevented from causing ignition of an external explosive atmosphere by one of the methods described in Section 5; or
- (b) develop a temperature of a surface or hot spot in excess of the maximum value appropriate to the temperature classification of the apparatus, unless the surface temperature or hot spot is prevented from causing ignition of an external explosive atmosphere by one of the methods described in Section 5 as appropriate, or is otherwise shown to be safe as specified in Clause 1.4.2.

NOTE: Sliding contacts are considered as sparking in normal operation.

2.2 ENCLOSURES.

2.2.1 General. The apparatus shall be provided with an enclosure.

NOTE: An enclosure may consist of a hermetically sealed enclosure, a restricted-breathing enclosure, an unrestricted-breathing enclosure, or a combination of these.

2.2.2 Degree of Protection. Enclosures of bare live parts and enclosures for insulated parts shall provide degrees of protection not less than IP 40 and IP 20 of AS 1939, respectively.

NOTE: Enclosures for outdoor use will require a degree of protection to AS 1939 that is superior to the above requirements.

2.2.3 Mechanical Strength. Enclosures shall be capable of complying with the impact test requirements specified in the normal industry standard. Where no standard for the particular equipment exists, or where impact test requirements are not specified, the requirements specified in Clause 6.4 shall apply.

2.2.4 Protective Guards. Every guard provided for the protection of a light-transmitting part or window shall have a mesh where the opening is not greater than 5000 mm² and the distance between bars is not more than 120 mm.

Where plastics are employed for enclosures or guards, they shall be suitable for the particular temperature conditions.

2.3 CONNECTION FACILITIES.

2.3.1 General. Connection facilities shall comply with Clause 2.3.2 or Clause 2.3.3, as appropriate, unless failure to comply would not result in an unsafe condition. (For plugs and sockets, see Clause 4.4).

2.3.2 Connections for External Conductors.

2.3.2.1 General. Terminals provided for external connections shall be designed so that the conductors can be connected readily to the terminals and can be clamped without reducing their cross-sectional area and in such a manner that they are permanently gripped and secured against loosening and twisting, and that the contact pressure will be maintained permanently. This requirement is not intended to exclude the use of terminals which rely for their integrity against loosening on friction alone.

Alternatively, the terminals may be suitable for cable lugs provided that the lugs can be secured against loosening and that the arrangement is such that the contact pressure will be maintained permanently. Where this type of termination is used, means shall be provided for preventing accidental reduction of clearances. This may be achieved by the use of insulating barriers at least as high as the terminals.

2.3.2.2 Size of conductors. Terminals for external connection shall accommodate at least the size of conductor appropriate to the rated current of the equipment.

NOTE: System conditions (voltage drop, fault level, etc) may make it necessary to provide terminals suitable for larger conductors than are required by thermal considerations.

2.3.2.3 Apparatus containing internal sources of heat. Where the apparatus contains internal sources of heat which may cause the temperature of the incoming supply wiring to exceed the recommended limiting temperature for general purpose PVC-insulating wiring (V 75), the apparatus of the terminal enclosure shall be provided with a warning such as—
‘WARNING: WIRING ENTRY TEMPERATURE ... °C. USE ONLY CABLE WITH APPROPRIATE RATING’.

NOTE: If internal sources of heat within the apparatus or the terminal enclosure could cause the temperature of the incoming supply wiring to exceed the recommended limiting temperature for general purpose PVC-insulated wiring, special installation instructions may be required, e.g. heat-resistant sleeving may be necessary.

2.3.3 Internal Connections. Internal connections shall not be subject to undue mechanical stress. They shall be such that contact pressure is adequately maintained. Examples of suitable methods are as follows:

- (a) Screwed or bolted connections.
- (b) Crimped connections.
- (c) Soldering.
- (d) Brazing.
- (e) Welding.
- (f) Pinching screws, provided that the pinching screws do not damage the conductors.
- (g) Machine-wrapped solderless joints (for currents not greater than 1 A).
- (h) Pressure-type wire connectors.

2.4 PROTECTION OF WIRING. Internal wiring which might come in contact with a sharp metallic part shall be either mechanically protected or clamped to avoid chafing.

2.5 CLEARANCES, SEPARATIONS AND CREEPAGE DISTANCES.

2.5.1 General. Where electrical breakdown would be potentially incendive, clearances, separations and creepage distances for the separation of live parts shall comply with the requirements given in Table 2.1, unless the apparatus is subjected to routine high voltage tests conducted at the voltages specified in Clause 6.5 plus 500 V.