

Australian Standard[®]

Diaphragm gas meters



This Australian Standard® was prepared by Committee AG-008, Gas Distribution. It was approved on behalf of the Council of Standards Australia on 25 August 2010. This Standard was published on 15 February 2011.

The following are represented on Committee AG-008:

- Australian Pipeline Industry Association
 - Department of Economic Development, New Zealand
 - Energy Networks Australia
 - Gas Association of New Zealand
 - Gas Technical Regulators Committee
 - LPG Australia
 - New Zealand Institution of Gas Engineers
 - Plastics Industry Pipe Association of Australia
 - Plastics New Zealand
-

This Standard was issued in draft form for comment as DR AS 4647.

Standards Australia wishes to acknowledge the participation of the expert individuals that contributed to the development of this Standard through their representation on the Committee and through the public comment period.

Keeping Standards up-to-date

Australian Standards® are living documents that reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued.

Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments that may have been published since the Standard was published.

Detailed information about Australian Standards, drafts, amendments and new projects can be found by visiting www.standards.org.au

Standards Australia welcomes suggestions for improvements, and encourages readers to notify us immediately of any apparent inaccuracies or ambiguities. Contact us via email at mail@standards.org.au, or write to Standards Australia, GPO Box 476, Sydney, NSW 2001.

STANDARDS AUSTRALIA

RECONFIRMATION

OF

AS 4647—2011

Diaphragm gas meters

RECONFIRMATION NOTICE

Technical Committee AG-008 has reviewed the content of this publication and in accordance with Standards Australia procedures for reconfirmation, it has been determined that the publication is still valid and does not require change.

Certain documents referenced in the publication may have been amended since the original date of publication. Users are advised to ensure that they are using the latest versions of such documents as appropriate, unless advised otherwise in this Reconfirmation Notice.

Approved for reconfirmation in accordance with Standards Australia procedures for reconfirmation on 22 January 2018.

The following are represented on Technical Committee AG-008:

Access Canberra

Australian Industry Group

Australian Pipelines and Gas Association Limited

Department of Planning and Environment - Division of Energy, Water and Portfolio Strategy

Energy Networks Australia

Engineers Australia

Gas Energy Australia

Gas Technical Regulators Committee

International Copper Association Australia

Plastics Industry Pipe Association of Australia

Welding Technology Institute of Australia

NOTES

Australian Standard[®]

Diaphragm gas meters

Originated as AG 702—1976.
Previous edition AS 4647—2005.
Second edition 2011.

COPYRIGHT

© Standards Australia Limited

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher, unless otherwise permitted under the Copyright Act 1968.

Published by SAI Global Limited under licence from Standards Australia Limited, GPO Box 476, Sydney, NSW 2001, Australia

ISBN 978 0 7337 9774 3

PREFACE

This Standard has been prepared by the Australian Members of Joint Standards Australia/Standards New Zealand Committee AG-008, Gas Distribution Committee, to supersede AS 4647—2005, *Specification for domestic diaphragm gas meters*.

After consultation with stakeholders in both countries, Standards Australia and Standards New Zealand decided to develop this Standard as an Australian Standard rather than an Australian/New Zealand Standard.

The Standard provides basic requirements for diaphragm gas meters of maximum flow rate (Q_{\max}) up to 8 m³/h when tested on air at pressure absorption of 125 Pa, to ensure optimum performance, both—

- (a) when purchased; and
- (b) after extended service.

The Standard is not intended to provide a comprehensive list of requirements for pattern approval and thus does not address the performance of the meter against test gases other than air, or the application of any temperature or pressure corrections to the metered gas volume. However, it can be used to complement a pattern approval standard with the aim of providing a comprehensive set of requirements for pattern approval, purchase and market surveillance of diaphragm gas meters.

This Standard has no legal status in its own right but may acquire legal standing where adopted by a government or other authority having jurisdiction over meter specification.

The terms ‘normative’ and ‘informative’ have been used in this Standard to define the application of the appendix to which they apply. A ‘normative’ appendix is an integral part of the Standard, whereas an ‘informative’ appendix is only for information and guidance.

Statements expressed in mandatory terms in notes to tables and figures are deemed to be requirements of the Standard.

CONTENTS

	<i>Page</i>
SECTION 1 SCOPE AND GENERAL	
1.1 SCOPE	4
1.2 REFERENCED DOCUMENTS	4
1.3 DEFINITIONS	5
SECTION 2 WORKING ENVIRONMENT	
2.1 GAS TYPE	8
2.2 TEMPERATURE	8
2.3 WORKING PRESSURE	8
2.4 MOUNTING	8
SECTION 3 METER CONSTRUCTION	
3.1 MATERIALS OF CONSTRUCTION	9
3.2 MECHANICAL STRENGTH	12
3.3 HEAT RESISTANCE.....	12
3.4 METER INDEX	12
3.5 LABELLING METERS	14
3.6 RECORDS.....	15
SECTION 4 PERFORMANCE	
4.1 TEST MEDIUM.....	16
4.2 INITIAL PERFORMANCE	16
4.3 IN-SERVICE PERFORMANCE	16
4.4 NOISE IN OPERATION	16
4.5 RECORDING OF TEST RESULTS.....	16
SECTION 5 ROUTINE TESTING AND INSPECTION	
5.1 TESTS TO BE CONDUCTED	17
5.2 DURABILITY TESTS	18
5.3 TEST RESULT UNCERTAINTY	18
APPENDICES	
A TEST METHODS FOR DETERMINING ENVIRONMENTAL SUITABILITY OF METER INDICES	20
B EFFECT OF EXPOSURE TO ULTRAVIOLET RADIATION.....	22
C TEST METHOD FOR CHEMICAL RESISTANCE OF SYNTHETIC DIAPHRAGMS.....	23
D TEST METHODS FOR MECHANICAL STRENGTH OF METER CASES.....	25
E DROP TEST METHOD	27
F TEST METHODS FOR PROTECTIVE COATING.....	28
G TEST METHOD FOR MAGNETIC FIELDS.....	32
H TEST METHOD FOR TEMPERATURE RESISTANCE AND AGEING OF DIAPHRAGMS.....	33
I DURABILITY TEST METHODS.....	35
J INCLINED PRESSURE GAUGE 750 Pa RANGE	37

STANDARDS AUSTRALIA

Australian Standard
Diaphragm gas meters

SECTION 1 SCOPE AND GENERAL

1.1 SCOPE

This Standard specifies requirements on the working environment, materials of construction and performance of diaphragm meters of maximum flow rate (Q_{\max}) up to 8 m³/h when tested on air at pressure absorption of 125 Pa. (Meters up to this capacity are generally produced in large quantities.) The design and construction requirements are intended to provide for an expected minimum working life of twenty years.

1.2 REFERENCED DOCUMENTS

The following documents are referred to in this Standard.

AS

1199	Sampling procedures for inspection by attributes
1199.1	Part 1: Sampling schemes indexed by acceptance quality limit (AQL) for lot-by-lot inspection
1580	Paints and related materials—Methods of test
1580.408.4	Part 405.4: Adhesion (crosscut)
1580.481.3	Part 481.3: Coatings—Exposed to weathering—Degree of corrosion of coated metal substrates
1834	Material for soldering
1834.1	Part 1: Solder alloys
1834.2	Part 2: Flux-cored solders
2331	Methods of test for metallic and related coatings
2331.3.1	Part 3.1: Corrosion and related property tests—Neutral salt spray (NSS) test
2706	Numerical values—Rounding and interpretation of limiting values
4564	Specification for general purpose natural gas
4670	Commercial propane and commercial butane for heating purposes

AS/NZS

1580	Paints and related materials—Methods of test
1580.405.1	Part 405.1: Determination of pencil hardness of paint film
1580.481.1.9	Part 481.1.9: Coatings—Exposed to weathering—Degree of blistering
4944	Gas meters—In-service compliance testing
60079	Electrical apparatus for explosive gas atmospheres

ISO/IEC

Guide 98	Uncertainty in measurement
Guide 98-3	Part 3: Guide to the expression of uncertainty in measurement