

Australian Standard™

**Installation and maintenance of steel
pipe systems for gas**

This Australian Standard was prepared by Committee AG-008, Gas Distribution. It was approved on behalf of the Council of Standards Australia on 20 December 2004.

This Standard was published on 18 February 2005.

The following are represented on Committee AG-008:

Australian Liquefied Petroleum Gas Association
Energy Networks Association
Energy Retailers Association of Australia
Gas Technical Regulators Committee
Welding Technology Institute of Australia

Keeping Standards up-to-date

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about Standards can be found by visiting the Standards Web Shop at www.standards.com.au and looking up the relevant Standard in the on-line catalogue.

Alternatively, the printed Catalogue provides information current at 1 January each year, and the monthly magazine, *The Global Standard*, has a full listing of revisions and amendments published each month.

Australian Standards™ and other products and services developed by Standards Australia are published and distributed under contract by SAI Global, which operates the Standards Web Shop.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Contact us via email at mail@standards.org.au, or write to the Chief Executive, Standards Australia, GPO Box 5420, Sydney, NSW 2001.

Australian Standard™

Installation and maintenance of steel pipe systems for gas

Originated as AS 1697—1981.
Second edition 2005.

COPYRIGHT

© Standards Australia

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher.

Published by Standards Australia, GPO Box 5420, Sydney, NSW 2001, Australia

ISBN 0 7337 6464 9

PREFACE

This Standard was prepared by the Standards Committee AG-008, Gas Distribution, to supersede AS 1697—1981, *SAA Gas Pipeline Code*.

It covers gas distribution networks covered by AS 4645 for operating pressures up to 1050 kPa. Operating pressures above 1050 kPa are covered by AS 2885.1. The responsibility for the superseded edition of AS 1697 was with the Standards Australia Committee ME-038. AG-008 was assigned the responsibility leading up to this edition.

Users of the Standard should note that AG 603 has been revised by AG-008 in parallel with the revision of AS 1697. The revised AG 603 is designated AS 4645, *Gas distribution network management*. AS 1697 relates to AS 4645 as depicted in Figure 1.1. AS 3723, *Installation and maintenance of plastics pipe systems for gas* (also shown in Figure 1.1) is under revision.

The terms ‘normative’ and ‘informative’ have been used in this Standard to define the application of the appendix to which they apply. A ‘normative’ appendix is an integral part of a Standard, whereas an ‘informative’ appendix is only for information and guidance.

The relationship between the gas distribution Standards is shown in Figure 1.1.

Statements expressed in mandatory terms in notes to tables are deemed to be requirements of this Standard.




FIGURE 1.1 RELATIONSHIP BETWEEN GAS DISTRIBUTION STANDARDS

NOTES:

- 1 AG 606 (to be AS 4568) is used for preparation of SOP/SC as required by technical regulator (advisory only).
- 2 AS 4645 specifies safety management of a gas distribution network for its life cycle. Refers to AS 1697 for steel and AS 3723 for plastics (see Note 3).
- 3 AS 1697 and AS 3723 specify material specific requirements for construction and installation (and operation/repair where material specific).

CONTENTS

	<i>Page</i>
SECTION 1 SCOPE AND GENERAL	
1.1 SCOPE	5
1.2 EXCLUSIONS	5
1.3 RETROSPECTIVE APPLICATION	6
1.4 REFERENCED DOCUMENTS	6
1.5 RECORDS.....	6
1.6 DEFINITIONS	6
1.7 PRESSURE CLASSIFICATIONS.....	8
SECTION 2 MATERIALS AND COMPONENTS	
2.1 NEW MATERIALS AND NEW COMPONENTS	10
2.2 RECLAIMED MATERIALS AND RECLAIMED COMPONENTS.....	10
2.3 IDENTIFICATION	10
2.4 PIPE THREADS, THREADED PIPE FITTINGS, FLANGED PIPE JOINTS AND WELDED PIPE JOINTS	13
2.5 VALVES, REGULATORS, FITTINGS AND ACCESSORIES	13
SECTION 3 DESIGN	
3.1 GENERAL	15
3.2 MAXIMUM ALLOWABLE OPERATING PRESSURE (MAOP).....	15
3.3 MAXIMUM ALLOWABLE HOOP STRESS	15
3.4 WALL THICKNESS	15
3.5 CORROSION MITIGATION.....	16
3.6 SUPPORTS	17
3.7 BENDS, ELBOWS AND MITRES	17
3.8 EXPANSION AND FLEXIBILITY	19
SECTION 4 WELDING	
4.1 GENERAL	20
4.2 PREHEAT AND POST-WELD HEAT TREATMENT	20
4.3 WELDING POSITIONS.....	20
4.4 QUALIFICATION OF A WELDING PROCEDURE.....	20
4.5 ASSESSMENT OF A TEST WELD TO QUALIFY A WELDING PROCEDURE... 20	20
4.6 QUALIFICATION OF A WELDER	24
4.7 DISQUALIFICATION OF A WELDER	24
4.8 DESIGN OF A WELDED JOINT	24
4.9 PRODUCTION WELDS	30
4.10 WELDING ON A GAS MAIN AFTER COMMISSIONING OR AFTER PRESSURE TEST	30
4.11 WELDING ONTO AN IN-SERVICE GAS MAIN.....	30
4.12 ASSESSMENT OF PRODUCTION WELDS AND REPAIR WELDS	31
4.13 CRITERIA OF ACCEPTANCE FOR GIRTH WELD DISCONTINUITIES.....	31
4.14 REPAIR OF AN UNACCEPTABLE WELD	32
4.15 REMOVAL OF AN ARC BURN AND CUTTING OUT OF AN UNACCEPTABLE WELD OR ARC BURN	32
SECTION 5 CONSTRUCTION AND INSTALLATION	
5.1 HANDLING	33
5.2 PROTECTION	33

	<i>Page</i>
5.3 POSITIONING	34
5.4 BURYING	34
5.5 INSPECTORS	37
5.6 ITEMS TO BE INSPECTED	37
5.7 MARKERS	37
5.8 COMPONENTS AND FABRICATED ASSEMBLIES	37
 SECTION 6 PRESSURE TESTING	
6.1 GENERAL	38
6.2 SAFETY	38
6.3 TEST PRESSURES	38
6.4 TESTING MAINS AND SERVICES	39
6.5 HOLD PERIOD	39
6.6 PREPARATION OF THE TEST SECTION	39
6.7 PRESSURIZATION	39
6.8 TEST PROCEDURE	40
6.9 ASSESSMENT OF PRESSURE TEST	40
6.10 DISPOSAL OF TEST MEDIUM	40
6.11 REPORTS AND RECORDS	40
 SECTION 7 COMMISSIONING	
7.1 SAFETY PRECAUTIONS	42
7.2 PURGING	42
7.3 COMMISSIONING OF GAS MAINS	42
7.4 PRESSURE-LIMITING REGULATORS	43
7.5 OVER-PRESSURE SAFETY DEVICES	43
7.6 ODORANT FADE	43
 SECTION 8 MAINTENANCE	
8.1 GENERAL	44
8.2 CORROSION PROTECTION SYSTEMS	44
8.3 ELECTRICAL HAZARDS	44
8.4 REPAIRS	44
 APPENDICES	
A REFERENCED DOCUMENTS	45
B APPLICATION OF VARIOUS TYPES OF TEST EQUIPMENT	48

STANDARDS AUSTRALIA

Australian Standard

Installation and maintenance of steel pipe systems for gas

SECTION 1 SCOPE AND GENERAL

1.1 SCOPE

This Standard specifies materials, design, construction, installation, testing and maintenance requirements for steel piping systems covered by AS 4645, for the distribution of fuel gas suitable for domestic, commercial or industrial uses, where—

- (a) the pressure of the gas is not greater than 1050 kPa and the operating temperature range of the materials is from -30°C to 120°C ; or
- (b) where the hoop stress level is not greater than 20 % of the Specified Minimum Yield Stress (SMYS) of the pipe used in that system.

The Standard does not extend to the exclusions listed in Clause 1.2.

NOTES:

- 1 Some requirements of this Standard are suitable for consumer piping operating at >200 kPa, being not otherwise provided in AS 5601. The operator of such piping should decide which requirements are appropriate, and should obtain any necessary agreement from the regulator having jurisdiction over the operation of that piping.
- 2 The relevant technical regulator may regard this standard as appropriate for other than fuel gas.

1.2 EXCLUSIONS

This Standard does not apply to the following:

- (a) Gas steel piping systems that operate at pressures exceeding 1050 kPa or have a stress level of more than 20 % of the SMYS. (Pipes with such a stress level are covered by AS 2885.1.)
- (b) Piping from the outlet of the meter that measures gas to a consumer, and any other piping covered by AS 5601.

NOTE: Requirements for pipes downstream of the consumer's meter are generally provided in AS 5601, but where the operating pressure of the downstream pipe will be higher than provided for in AS 5601, the piping requirements of this Standard are appropriate according to the pressure (or AS 2885.1 for even higher pressures).

- (c) Piping associated with the handling and storage of liquefied petroleum gas (see AS/NZS 1596).
- (d) The design and manufacture of proprietary items (including meters).
- (e) Piping associated with gas manufacturing plants, petroleum processing plants, industrial plants or mines.
- (f) Pressure vessels (see AS 1210).
- (g) Piping for LP Gas in the liquid phase.