

Australian Standard[®]

**Battery chargers for stationary
batteries**

This Australian Standard was prepared by Committee EL/5, Secondary Batteries. It was approved on behalf of the Council of Standards Australia on 22 May 1992 and published on 17 August 1992.

The following interests are represented on Committee EL/5:

Australian Automobile Association
Australian Automotive Aftermarket Association
Australian Electrical and Electronic Manufacturers Association
Australian Federation of Consumer Organizations
Australian Lead Development Association
Confederation of Australian Industry
Department of Defence
Electricity Supply Association of Australia
Federal Chamber of Automotive Industries
Institution of Engineers, Australia
Telecom Australia

Additional interests participating in preparation of Standard:

Regulatory authorities electrical

***Review of Australian Standards.** To keep abreast of progress in industry, Australian Standards are subject to periodic review and are kept up to date by the issue of amendments or new editions as necessary. It is important therefore that Standards users ensure that they are in possession of the latest edition, and any amendments thereto.*

Full details of all Australian Standards and related publications will be found in the Standards Australia Catalogue of Publications; this information is supplemented each month by the magazine 'The Australian Standard', which subscribing members receive, and which gives details of new publications, new editions and amendments, and of withdrawn Standards.

Suggestions for improvements to Australian Standards, addressed to the head office of Standards Australia, are welcomed. Notification of any inaccuracy or ambiguity found in an Australian Standard should be made without delay in order that the matter may be investigated and appropriate action taken.

This Standard was issued in draft form for comment as DR 91013.

Australian Standard[®]

**Battery chargers for stationary
batteries**

First published as AS 4044—1992.

PREFACE

This Standard was prepared by the Standards Australia Committee on Secondary Batteries. The electrical safety requirements for stationary battery chargers are not completely specified in this Standard but are specified in AS 3100—1990, *Approval and test specification—General requirements for electrical equipment*.

 CONTENTS

	<i>Page</i>
1 SCOPE	3
2 REFERENCED DOCUMENTS	3
3 DEFINITIONS	3
4 CLASSIFICATION	4
5 ALTERNATING CURRENT INPUT CHARACTERISTICS	4
6 DIRECT CURRENT OUTPUT CHARACTERISTICS	4
7 SAFETY REQUIREMENTS	6
8 ENVIRONMENTAL REQUIREMENTS	7
9 ALARMS, AUTOMATIC SHUT-DOWN FACILITIES AND METERS	7
10 INSTRUCTION MANUAL	8
11 TEST EQUIPMENT	8
 APPENDICES	
A INFORMATION TO BE SUPPLIED BY THE PURCHASER	9
B PSOPHOMETRIC NOISE MEASUREMENT	11
C POWER FACTOR MEASUREMENT	12
D VOLTAGE ADJUSTMENT TEST	13
E VOLTAGE REGULATION TEST	13
F FLOAT VOLTAGE TEMPERATURE COMPENSATION	14
G SHORT-CIRCUIT TEST	14
H ALTERNATING CURRENT POWER RESTORATION TEST	14
I START-UP TEST	15
J DYNAMIC RESPONSE TEST	15
K RIPPLE VOLTAGE TEST	16
L POWER FACTOR MEASUREMENTS WITH DISTORTED CURRENT WAVEFORMS	17

© Copyright — STANDARDS AUSTRALIA

Users of Standards are reminded that copyright subsists in all Standards Australia publications and software. Except where the Copyright Act allows and except where provided for below no publications or software produced by Standards Australia may be reproduced, stored in a retrieval system in any form or transmitted by any means without prior permission in writing from Standards Australia. Permission may be conditional on an appropriate royalty payment. Requests for permission and information on commercial software royalties should be directed to the head office of Standards Australia.

Standards Australia will permit up to 10 percent of the technical content pages of a Standard to be copied for use exclusively in-house by purchasers of the Standard without payment of a royalty or advice to Standards Australia.

Standards Australia will also permit the inclusion of its copyright material in computer software programs for no royalty payment provided such programs are used exclusively in-house by the creators of the programs.

Care should be taken to ensure that material used is from the current edition of the Standard and that it is updated whenever the Standard is amended or revised. The number and date of the Standard should therefore be clearly identified.

The use of material in print form or in computer software programs to be used commercially, with or without payment, or in commercial contracts is subject to the payment of a royalty. This policy may be varied by Standards Australia at any time.

STANDARDS AUSTRALIA

Australian Standard

Battery chargers for stationary batteries

1 SCOPE This Standard specifies requirements for stabilized constant-potential battery chargers that are designed to supply direct current power from an alternating current source, while charging a float-type stationary battery, and which may simultaneously supply power to a connected direct current system load.

NOTE: Appendix A provides guidance on information to be supplied by a purchaser.

2 REFERENCED DOCUMENTS The following documents are referred to in this Standard:

AS

1042	Direct-acting indicating electrical measuring instruments and their accessories
1044	Electromagnetic interference—Household electrical appliances, portable tools and similar electrical equipment—Limits and methods of measurement
1104	Informative symbols for use on electrical and electronic equipment
1217	Acoustics—Determination of sound power levels of noise sources
1217.2	Part 2: Precision methods for broad-band sources in reverberation rooms
1217.3	Part 3: Precision methods for discrete-frequency and narrow-band sources in reverberation rooms
1259	Acoustics—Sound level meters
1939	Degrees of protection provided by enclosures for electrical equipment (IP Code)
2374	Power transformers
3000	SAA Wiring Rules
3100	Approval and test specification—General requirements for electrical equipment
CCITT	Recommendation 0.41: Psophometer for use on telephone type circuits

3 DEFINITIONS For the purpose of this Standard, the definitions given in AS 3100 and those below apply.

3.1 Audible noise—the sound level produced by the battery charger measured in decibels.

3.2 Battery—a unit consisting of one or more cells connected in a series, parallel, or a series-parallel arrangement to supply the voltage and current requirements of the load.

3.3 Boost charge—a charge performed at a higher potential than a float or equalizing charge. A boost charge is applied to partially restore the capacity of a discharged battery at a faster rate than a float charge.

3.4 Capacity—the quantity of electricity in ampere hours (A.h) which a fully charged battery can deliver under specified conditions.

The capacity of a cell or battery is denoted by the symbol C . As the capacity varies with rate of discharge, the symbol C is followed by a numerical suffix giving the rate of discharge. Thus C_{120} is the capacity in ampere hours (A.h) at the 120 hour rate of discharge. The specified temperature is usually 25°C. The final voltage depends on battery type and conditions of service.

Capacity may be specified as follows:

- (a) *Actual capacity*—the quantity of electricity in ampere hours (A.h) that can be withdrawn from a cell or battery for a specific set of operating conditions including discharge rate, temperature, initial state of charge, age and final voltage.
- (b) *Rated capacity*—the quantity of electricity in ampere hours (A.h), declared by the manufacturer which a battery can deliver after a full charge under specified conditions.

NOTE: The specified conditions are rate of discharge, final voltage and temperature.

3.5 Cell—an assembly of electrodes and electrolytes which constitutes the basic unit of a battery.

3.6 Charger efficiency—the output power in watts divided by the input power in watts, expressed in percent.

3.7 Constant voltage charge—a charge during which the voltage across the battery terminals of the battery charger is maintained at a constant value.

3.8 Displacement factor—the ratio of the active power of the fundamental wave to the apparent power of the fundamental wave.

3.9 Equalizing charge—an extended charge to ensure complete charging of all the cells in the battery. An equalizing charge is performed at a higher potential than a float charge.