

# Australian Standard<sup>®</sup> 2713—1987

see also AS 3590.1-1990

see also AS 3590.2-1990

see also AS 3590.3-1990

---

## LIGHTING AND THE VISUAL ENVIRONMENT FOR SCREEN-BASED TASKS

*For referenced documents see Annex*



---

**STANDARDS ASSOCIATION OF AUSTRALIA**  
*Incorporated by Royal Charter*

This Australian standard was prepared by Committee LG/1, Interior Lighting. It was approved on behalf of the Council of the Standards Association of Australia on 14 October 1986 and published on 2 March 1987.

---

The following interests are represented on Committee LG/1:

Association of Consulting Engineers Australia  
Australian Chamber of Commerce  
Australian Electrical and Electronic Manufacturers Association  
Australian Optometrical Association  
Confederation of Australian Industry  
Department of Employment and Industrial Relations  
Department of Housing and Construction  
Department of Industrial Relations, New South Wales  
Department of Public Works, New South Wales  
Electricity Supply Association of Australia  
Illuminating Engineering Societies of Australia  
Public Works Department, Victoria  
Royal Australian Institute of Architects  
University of Sydney

---

*Review of Australian Standards.* To keep abreast of progress in industry, Australian standards are subject to periodic review and are kept up-to-date by the issue of amendments or new editions as necessary. It is important therefore that standards users ensure that they are in possession of the latest edition, and any amendments thereto.

Full details of all SAA publications will be found in the Catalogue of SAA Publications; this information is supplemented each month by SAA's journal 'The Australian Standard', which subscribing members receive, and which gives details of new publications, new editions and amendments, and of withdrawn standards.

Suggestions for improvements to Australian standards, addressed to the head office of the Association, are welcomed. Notification of any inaccuracy or ambiguity found in an Australian standard should be made without delay in order that the matter may be investigated and appropriate action taken.

---

AUSTRALIAN STANDARD

# LIGHTING AND THE VISUAL ENVIRONMENT FOR SCREEN-BASED TASKS

AS 2713—1987

First published .....	1984
Second edition .....	1987



PUBLISHED BY THE STANDARDS ASSOCIATION OF AUSTRALIA  
STANDARDS HOUSE, 80 ARTHUR ST, NORTH SYDNEY, N.S.W.

ISBN 0 7262 4547 X

## PREFACE

This standard was prepared by the Association's Committee on Interior Lighting to supersede AS 2713—1984. The 1984 edition was prepared in response to a request from the Australian Journalists Association for guidance on the lighting and environmental conditions necessary for the satisfactory performance of screen-based visual tasks, especially those involving visual display units and other terminals which utilize a cathode ray tube display.

The use of screen-based equipment such as visual display units and microform readers has continued to increase, and such equipment is now found in an increasing variety of work places. Work with screen-based equipment differs in a number of important ways from traditional reading and writing tasks, often referred to as 'hard copy' tasks. For example, individual workers have much less freedom in choosing—and in periodically changing—their working position and/or line of sight. Also, the worker's line of sight is nearer to the horizontal. Correct ergonomic design of the workstation is therefore of particular importance, especially when screen-based equipment is in continuous use by an operator seated in a fixed position. Appendix B provides information on ergonomic and other factors associated with the design and use of screen-based equipment which interact with lighting and visual conditions.

The standard makes extensive reference to AS 1680\* which sets out recommendations which are applicable generally for all types of visual tasks. The committee intends that recommendations for the lighting of screen-based tasks be incorporated in a revision of AS 1680 which is in course of preparation.

The major change introduced in this edition is the deletion from Clause 7.3 of a maximum luminance limit which previously applied for recessed luminaires. The maximum luminances which apply to all types of luminaires for glare control purposes remain as specified in Clause 5.2, by reference to the recommendations of AS 1680.

It should be noted that provision of good lighting and environmental conditions cannot compensate for defects in message visibility which are caused by the design or construction of the screen-based equipment. On the other hand, an unsatisfactory lighting installation or environment can greatly reduce the visibility of an otherwise satisfactory screen display.

The recommendations in this standard are based on the equipment and practices existing at the time of its preparation. Attention is drawn to the fact that the design and use of screen-based equipment is still at an early stage of development, and further changes are likely to take place, both in equipment design and in the associated lighting and environmental design techniques.

---

\* AS 1680, Code of Practice for Interior Lighting and the Visual Environment.

© Copyright — STANDARDS ASSOCIATION OF AUSTRALIA 1987

Users of standards are reminded that copyright subsists in all SAA publications. No part of this publication may be reproduced, stored in a retrieval system in any form or transmitted by any means without prior permission in writing of the Standards Association of Australia.

## CONTENTS

	Page
1 SCOPE ....	4
2 REFERENCED DOCUMENTS ....	4
3 DEFINITIONS ....	4
4 OBJECTIVES ....	5
5 GENERAL REQUIREMENTS ....	5
6 ILLUMINANCE LEVELS ....	7
7 CHOICE OF LIGHTING SYSTEM ....	8
<b>APPENDICES</b>	
A PROCEDURE FOR THE MEASUREMENT OF SCREEN LUMI- NANCE ....	9
B ERGONOMIC AND OTHER FACTORS RELATING TO THE DESIGN AND USE OF SBE ....	10
C INFORMATION TO BE SUPPLIED TO FACILITATE THE DESIGN OF INTERIORS SUITED TO SCREEN-BASED TASKS	16
ANNEX. LIST OF REFERENCED AND RELATED DOCUMENTS	17

## STANDARDS ASSOCIATION OF AUSTRALIA

**Australian Standard**  
**for**  
**LIGHTING AND THE VISUAL ENVIRONMENT FOR SCREEN-BASED TASKS**

**1 SCOPE.** This standard sets out recommendations for the creation of a suitable visual environment for the use of screen-based equipment (SBE). The general recommendations in AS 1680 will also apply to areas where SBE is used, unless otherwise indicated in this standard.

The recommendations apply primarily to installations where operators use SBE for prolonged periods (see Clause 4.1 and Paragraph B2, Appendix B).

**NOTES:**

1. Whilst the recommendations of this standard are concerned primarily with lighting and visual conditions, attention is drawn to the importance of ergonomic and other factors in creating a satisfactory environment for the use of SBE. Some of these factors are described in Appendix B and further information may be obtained from documents referenced in the Annex.
2. Appendix C provides a checklist of the information which should be provided to facilitate the design of interiors suited to screen-based tasks.

**2 REFERENCED DOCUMENTS.** A list with titles of the documents referred to in this standard is given in the Annex. The Annex also lists several additional documents which are considered useful sources of information on the subject of this standard.

**3 DEFINITIONS.** For the purpose of this standard, the following definitions apply:

**3.1 Brightness (luminosity)**—the attribute of visual sensation according to which a surface appears to emit or reflect more or less light.

NOTE: This is a subjective effect which cannot be measured in absolute units, and the term should only be used to describe the appearance of a source or surface.

**3.2 General lighting**—lighting designed to illuminate an area without special provision for local requirements within that area.

NOTE: Normally this is provided by an arrangement of luminaires which produce approximately uniform illuminance throughout an interior.

**3.3 Glare**—a visual condition which results in discomfort, annoyance, interference with visual efficiency, or eye fatigue due to the brightness of a portion of the field of view (e.g. lamps, luminaires, or other surfaces) being markedly greater than the rest.

NOTE: 'Glare' comprises two distinct effects. These are 'discomfort glare' which causes discomfort without necessarily impairing the visibility of objects, and 'disability glare' which impairs the visibility of objects without necessarily causing discomfort. Both effects are usually present but in artificially lit interiors the controlling of discomfort glare will normally control disability glare effects as well.

**3.4 Illuminance**—the luminous flux incident on a surface per unit area. The unit is the lux (lx). Symbol *E*.

**3.5 Illumination**—the process of lighting an object.

**3.6 Local lighting**—the illumination of a specific task area by a luminaire or luminaires specially provided for the purpose.

NOTE: This method of lighting frequently contributes little, if any, general illumination and in such cases should be used only in conjunction with general lighting.

**3.7 Luminaire**—apparatus (fixed or portable) which distributes, filters or transforms the light given by a lamp or lamps and which includes all the items necessary for fixing and protecting these lamps and for connecting them to the supply circuit.

It does not include permanent parts of a building such as a ceiling or other structural elements.

**3.8 Luminance (at a point of a surface and in a given direction)**—the luminous intensity per unit projected area of a surface. For example, if a very small portion of a surface has a luminous intensity of 1 cd in a particular direction, and if the orthogonal projection (on a plane perpendicular to the given direction) of that portion has an area *A*, the average luminance in that direction is 1/*A* candelas per unit area. The unit is the candela per square metre (cd/m<sup>2</sup>).

**3.9 Microform reader**—an optical projection device, with either a front projection or back projection screen, for viewing an enlarged micro-image with the unaided eye. The term includes microfiche and microfilm readers.

NOTE: Requirements for the design and construction of microfiche readers are provided in AS 2653, AS 2654 and AS 2655.

**3.10 Partition screen**—an opaque screening device, either floor mounted or suspended which, when suitably placed, will eliminate the direct or reflected view of bright windows or luminaires.

**3.11 Reflectance (reflection factor)**—the ratio of the luminous flux reflected from a surface to the incident luminous flux.

**3.12 Room index**—a factor dependent on the shape of a room or space which is used to indicate the relative efficiency with which light energy is utilized.

NOTE: The room index is given by the following equation:

$$\text{Room index} = \frac{L \times W}{H_m(L + W)}$$

where

*L* = length of the room

*W* = width of the room

*H<sub>m</sub>* = mounting height of the luminaires above the working plane.

**3.13 SBE workstation**—a particular location within an office, business or industrial environment at which any form of SBE (screen-based equipment) is installed and used.

NOTE: Guidelines for the design of microform workstations are provided in AS 2466.