

AS 2444

SUPERSEDED BY AS 2444 - 1990

AS 2444—1985  
UDC 614.845.505

SUPERSEDED BY:

# Australian Standard<sup>®</sup> 2444—1985

---

## PORTABLE FIRE EXTINGUISHERS— SELECTION AND LOCATION



**STANDARDS ASSOCIATION OF AUSTRALIA**  
*Incorporated by Royal Charter*



E

This Australian standard was prepared by Committee FP/3, Fire Extinguishers. It was approved on behalf of the Council of the Standards Association of Australia on 18 April 1985 and published on 10 May 1985.

---

The following interests are represented on Committee FP/3:

Board of Fire Commissioners of New South Wales  
Building Owners and Managers Association of Australia  
Commonwealth Fire Board  
Department of Consumer Affairs, N.S.W.  
Department of Defence  
Department of Home Affairs and Environment  
Department of Housing and Construction  
Department of Industrial Relations, N.S.W.  
Fire Protection Industry Association of Australia  
Insurance Council of Australia  
Metropolitan Fire Brigades Board, Melbourne  
Ministry of Consumer Affairs, Vic.  
Telecom Australia  
Trade Practices Commission  
Western Australia Fire Brigades Board

---

*Review of Australian Standards.* To keep abreast of progress in industry, Australian standards are subject to periodic review and are kept up-to-date by the issue of amendments or new editions as necessary. It is important therefore that standards users ensure that they are in possession of the latest edition, and any amendments thereto.

Full details of all SAA publications will be found in the Catalogue of SAA Publications; this information is supplemented each month by SAA's journal 'The Australian Standard', which subscribing members receive, and which gives details of new publications, new editions and amendments, and of withdrawn standards.

Suggestions for improvements to Australian standards, addressed to the head office of the Association, are welcomed. Notification of any inaccuracy or ambiguity found in an Australian standard should be made without delay in order that the matter may be investigated and appropriate action taken.

---

This standard was issued in draft form for comment as DR 84065. ✓

**AUSTRALIAN STANDARD**

# **PORTABLE FIRE EXTINGUISHERS— SELECTION AND LOCATION**

**AS 2444—1985**

First published .....	1981
Second edition .....	1982 ✓
Third edition .....	1985

**PUBLISHED BY THE STANDARDS ASSOCIATION OF AUSTRALIA  
STANDARDS HOUSE, 80 ARTHUR ST, NORTH SYDNEY, N.S.W.**



ISBN 0 7262 3795 7

## PREFACE

This standard was prepared by the Association's Committee on Fire Extinguishers, to supersede AS 2444—1982. AS 2444 was first published in 1981, and revised in 1982 to incorporate expanded tables on the distribution of and travel distances to extinguishers.

This edition separates the selection of portable fire extinguishers into an advisory section, and specifies requirements for the location and distribution of portable fire extinguishers in two further sections. Guidance for the selection of extinguishers is based on extinguisher classification and rating, while requirements for the location and distribution of extinguishers take account of extinguisher classification and rating, and of potential hazard classification.

For some time, it has been a requirement that portable fire extinguishers carry a classification and rating which indicates the size of fire against which they can be expected to be effective. A list of extinguishers which have been tested is available from the Quality Assurance and Certification Department at the Head Office of the Standards Association of Australia.

Commonwealth and State regulations require all fire extinguishers to comply with the relevant Australian standard and to bear the Standards Mark. In a number of areas, regulations nominate extinguishers of specific types and sizes for certain applications. In other circumstances, building configuration or occupancy may preclude adherence to travel distances specified in the standard. In this event, the extinguishers may require to be grouped in banks at appropriate intervals and locations, i.e. hydrant points, etc.

It should be noted that Standards-marked extinguishers with body-stamped dates from 1976 to 1981 (inclusive) may be found to be labelled with a 'C' classification denoting suitability for use on electrical hazards, e.g. 2A: 10B:C. Extinguishers so labelled were produced to comply with AS 1850-1976 and may be selected and located in accordance with this standard.

Australian standards dealing with portable fire extinguishers are as follows:

- AS 1841 Portable Fire Extinguishers—Water (Gas Container) Type
- AS 1842 Portable Fire Extinguishers—Water (Stored Pressure) Type
- AS 1844 Portable Fire Extinguishers—Foam (Gas Container) Type
- AS 1845 Portable Fire Extinguishers—Foam (Stored Pressure) Type
- AS 1846 Portable Fire Extinguishers—Dry Chemical Type
- AS 1847 Carbon Dioxide Type Portable Fire Extinguishers
- AS 1848 Portable Fire Extinguishers—Halogenated Hydrocarbon Type
- AS 1849 Identification Colours for Portable Fire Extinguishers
- AS 1850 Portable Fire Extinguishers—Classification, Rating and Fire Testing
- AS 1851.1 Maintenance of Fire Protection Equipment, Part 1—Portable Fire Extinguishers

©Copyright — STANDARDS ASSOCIATION OF AUSTRALIA 1985

Users of standards are reminded that copyright subsists in all SAA publications. No part of this publication may be reproduced, stored in a retrieval system in any form or transmitted by any means without prior permission in writing of the Standards Association of Australia.

## CONTENTS

	<i>Page</i>
<b>SECTION 1. SCOPE AND GENERAL</b>	
1.1 Scope .....	4
1.2 Referenced Documents .....	4
1.3 Definitions .....	4
<b>SECTION 2. SELECTION OF PORTABLE FIRE EXTINGUISHERS</b>	
2.1 General .....	5
2.2 Classification and Rating .....	5
2.3 Factors Affecting Selection .....	5
<b>SECTION 3. LOCATION OF PORTABLE FIRE EXTINGUISHERS</b>	
3.1 General .....	7
3.2 Location .....	7
3.3 Support .....	7
3.4 Cabinet or Enclosure .....	7
3.5 Environment .....	7
3.6 Record of Installation .....	7
<b>SECTION 4. DISTRIBUTION OF PORTABLE FIRE EXTINGUISHERS</b>	
4.1 General .....	10
4.2 Class A Hazards .....	10
4.3 Class B Hazards .....	10
4.4 Vehicles .....	10
<b>APPENDIX A. PORTABLE FIRE EXTINGUISHER SELECTION CHART</b> .....	<b>12</b>

## STANDARDS ASSOCIATION OF AUSTRALIA

## Australian Standard

for

## PORTABLE FIRE EXTINGUISHERS—SELECTION AND LOCATION

## SECTION 1. SCOPE AND GENERAL

**1.1 SCOPE.** This standard sets out criteria for the selection of portable fire extinguishers and specifies requirements for their location and distribution.

**1.2 REFERENCED DOCUMENTS.** The following standards are referred to in this standard:

- AS 1850 Portable Fire Extinguishers—Classification, Rating and Fire Testing
- AS 1851.1 Maintenance of Fire Protection Equipment, Part 1—Portable Fire Extinguishers
- AS 2036 Manually Operated Fire Alarm Call Points
- AS 2441 Installation of Fire Hose Reels
- AS K185 Colours for Specific Purposes

**1.3 DEFINITIONS.** For the purpose of this standard, the following definitions apply:

**1.3.1 Approved**—approved by the Regulatory Authority.

**1.3.2 Portable fire extinguisher**—a first attack firefighting appliance which is designed to be carried and operated by hand and which, when charged to design capacity, has a gross mass of not greater than 23 kg.

**1.3.3 Light hazard**—where the amount and type of combustibles present are such that fires of only small initial size may be expected. Light hazards are classified as follows:

- (a) Class A light hazards include premises such as offices, schoolrooms, churches and assembly halls.

- (b) Class B areas where flammable liquids are stored in containers not exceeding 5 L in capacity, and the total quantity stored in any one fire compartment does not exceed 25 L.

**1.3.4 Ordinary hazard**—where the amount and type of combustibles present are such that fires of only moderate initial size may be expected. Ordinary hazards are classified as follows:

- (a) Class A ordinary hazards include mercantile storage and display areas, showrooms and workshops.
- (b) Class B areas where flammable liquids are stored in containers where the surface area of the liquid does not exceed 2 m<sup>2</sup>, or in container storage not exceeding a total of 250 L in containers not greater than 20 L capacity.

**1.3.5 High hazard**—where the amount and type of combustibles present are such that fires of large initial size may be expected. High hazards are classified as follows:

- (a) Class A high hazards include woodworking areas, warehouses with high-piled storage, foam plastics processing and storage.
- (b) Class B areas where flammable liquids are stored in containers where the surface area of the liquid exceeds 2 m<sup>2</sup>, or in container storage exceeding a total of 250 L.

**1.3.6 Regulatory Authority**—a Minister of the Crown, a government department or other public authority having power to issue regulations, orders or other instructions in respect of any subject covered by this standard.