

Australian Standard™

Gaseous fire extinguishing systems

This Australian Standard was prepared by Committee FP-011, Gaseous Fire Protection. It was approved on behalf of the Council of Standards Australia on 28 August 2002. This Standard was published on 13 November 2002.

The following are represented on Committee FP-011:

Australian Chamber of Commerce and Industry
Australian Government Analytical Laboratories, Scientific Services Laboratory
Australian Industry Group
Australian Museum
Commerce Queensland
Department of Defence (Australia)
Fire Protection Association Australia
Institute of Security Executives
Society of Fire Protection Engineers Australasian Chapter
Telecommunications Interests
Waterways Authority (NSW)
WorkCover New South Wales

Keeping Standards up-to-date

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about Standards can be found by visiting the Standards Web Shop at www.standards.com.au and looking up the relevant Standard in the on-line catalogue.

Alternatively, the printed Catalogue provides information current at 1 January each year, and the monthly magazine, *The Global Standard*, has a full listing of revisions and amendments published each month.

Australian Standards™ and other products and services developed by Standards Australia are published and distributed under contract by SAI Global, which operates the Standards Web Shop.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Contact us via email at mail@standards.org.au, or write to the Chief Executive, Standards Australia, GPO Box 5420, Sydney, NSW 2001.

Australian Standard™

Gaseous fire extinguishing systems

Originated in part as AS 4214.1—1995, AS 4214.2—1995, AS 4214.3—1995, AS 4214.4—1995, AS 4214.5—1995, AS 4214.6—1998 and AS 4214.7—1998.
AS 4214.1—1995, AS 4214.2—1995, AS 4214.3—1995, AS 4214.4—1995, AS 4214.5—1995, AS 4214.6—1998 and AS 4214.7—1998 revised, amalgamated and redesignated as AS 4214—2002.
Reissued incorporating Amendment No. 1 (May 2005).

COPYRIGHT

© Standards Australia

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher.

Published by Standards Australia, GPO Box 5420, Sydney, NSW 2001, Australia

ISBN 0 7337 4803 1

PREFACE

This Standard was prepared by the Standards Australia Committee FP-011, Gaseous Fire Extinguishing Systems, to supersede AS 4214—1995, *Gaseous fire extinguishing systems—General requirements*.

This Standard incorporates Amendment No. 1 (May 2005). The changes required by the Amendment are indicated in the text by a marginal bar and amendment number against the clause, note, table, figure or part thereof affected.

This revision is based on ISO 14520.1 and NFPA 12, *Carbon dioxide extinguishing systems*. The Committee has introduced higher levels of safety and security. Additionally, this revision includes a section dedicated to marine application. Appendices cover gaseous agents including an appendix for carbon dioxide.

It is essential that gaseous fire extinguishing systems be maintained to ensure instant readiness when required. The importance of maintenance cannot be too highly emphasized. Maintenance requirements for gaseous systems are detailed in AS 1851.12 (see Clause 1.4).

Gas containers manufactured for use in Australia are required to meet the design criteria set out in AS 2030.1, *The approval, filling, inspection, testing and maintenance of containers for the storage and transport of compressed gases, Part 1: Containers for compressed gases other than acetylene*.

Attention is drawn to AS 2030.1, as it requires containers to be designed for a pressure developed at the nominated maximum temperature of 65°C. This is some 10°C higher than that nominated in overseas codes. Accordingly, this aspect should be kept in mind for any imported containers.

It is a basic assumption in all technical standards work that each Standard be used only by persons competent in the field of application. This is of particular importance in fire protection work. Accordingly, it is emphasized that only trained and experienced designers interpret the design requirements contained herein.

The term ‘normative’ has been used in this Standard to define the application of the appendix to which it applies. A ‘normative’ appendix is an integral part of this Standard.

This Standard incorporates a Commentary on some Clauses. The Commentary directly follows the relevant Clause, is designated by ‘C’ preceding the clause number and is printed in italics in a panel. The Commentary is for information only and does not need to be followed for compliance with the Standard.

CONTENTS

| | <i>Page</i> |
|--|-------------|
| FOREWORD..... | 6 |
| SECTION 1 SCOPE AND GENERAL | |
| 1.1 SCOPE | 7 |
| 1.2 APPLICATION | 8 |
| 1.3 OBJECTIVE..... | 8 |
| 1.4 REFERENCED DOCUMENTS | 9 |
| 1.5 DEFINITIONS | 10 |
| 1.6 SYMBOLS AND UNITS | 13 |
| 1.7 INTERPRETATION OF SPECIFIED LIMITING VALUES | 13 |
| 1.8 USES AND LIMITATIONS..... | 14 |
| 1.9 LISTING REQUIREMENTS | 15 |
| SECTION 2 SAFETY REQUIREMENTS | |
| 2.1 PERSONNEL SAFETY REQUIREMENTS..... | 16 |
| 2.2 SYSTEM SAFETY REQUIREMENTS..... | 17 |
| SECTION 3 SYSTEM DESIGN | |
| 3.1 SPECIFICATIONS, PLANS AND APPROVALS | 21 |
| 3.2 ACCEPTANCE OF INSTALLATIONS..... | 22 |
| 3.3 APPROVAL OF COMPONENTS..... | 22 |
| 3.4 EXTINGUISHING AGENT CONCENTRATION REQUIREMENTS | 22 |
| 3.5 TOTAL FLOODING QUANTITY | 24 |
| 3.6 SPECIAL CONDITIONS | 26 |
| 3.7 ALTITUDE ADJUSTMENT | 26 |
| 3.8 HOLDING TIME | 27 |
| 3.9 LOCAL APPLICATION SYSTEMS..... | 27 |
| 3.10 SYSTEM PERFORMANCE..... | 27 |
| 3.11 EXTENDED DISCHARGE..... | 28 |
| 3.12 SYSTEM FLOW CALCULATIONS..... | 28 |
| SECTION 4 TOTAL FLOODING ENCLOSURE REQUIREMENTS | |
| 4.1 GENERAL | 32 |
| 4.2 NON-CLOSABLE OPENINGS..... | 32 |
| 4.3 VENTILATION AND SERVICES..... | 32 |
| 4.4 PRESSURE-RELIEF VENTING..... | 32 |
| 4.5 ENCLOSURE STRENGTH AND ALLOWABLE PRESSURE..... | 33 |
| SECTION 5 SUPPLY | |
| 5.1 QUALITY | 34 |
| 5.2 STORAGE CONTAINER DESIGN | 34 |
| 5.3 STORAGE CONTAINER ARRANGEMENT..... | 34 |
| 5.4 VALVES | 35 |
| 5.5 PRESSURE-REDUCTION DEVICES | 36 |

| | |
|--|--|
| SECTION 6 DISTRIBUTION SYSTEM | |
| 6.1 | GENERAL 37 |
| 6.2 | PIPEWORK..... 37 |
| 6.3 | COMPATIBILITY 37 |
| 6.4 | PRESSURE RATING..... 37 |
| 6.5 | HYDROSTATIC PRESSURE TEST..... 37 |
| 6.6 | INSTALLATION OF PIPEWORK..... 37 |
| 6.7 | DIRT TRAPS 38 |
| 6.8 | DRAIN TRAPS 38 |
| 6.9 | SAFETY DEVICES 39 |
| 6.10 | NOZZLES 39 |
| SECTION 7 DETECTION, ACTUATION AND CONTROL SYSTEMS | |
| 7.1 | GENERAL 40 |
| 7.2 | DETECTION..... 40 |
| 7.3 | ACTUATION 42 |
| 7.4 | CONTROL AND INDICATING EQUIPMENT (CIE)—ELECTRICAL 43 |
| 7.5 | LOCAL CONTROL (LC) AND LOCAL CONTROL STATION (LCS)..... 43 |
| 7.6 | AURAL ALARMS AND VISUAL WARNING DEVICES 44 |
| 7.7 | PNEUMATIC SERVO RELEASE 45 |
| SECTION 8 MARKING | |
| 8.1 | CONTROL AND INDICATING EQUIPMENT (CIE)..... 46 |
| 8.2 | WARNING NOTICES 46 |
| 8.3 | NUMBER OF CONTAINERS AND QUANTITY MARKING..... 49 |
| 8.4 | IDENTIFICATION AND MARKING OF CONTAINERS 49 |
| 8.5 | LABELLING OF INDICATORS AND CONTROLS..... 50 |
| 8.6 | IDENTIFICATION OF DISCHARGE NOZZLES 50 |
| SECTION 9 MARINE | |
| 9.1 | GENERAL 51 |
| 9.2 | USE AND LIMITATIONS..... 51 |
| 9.3 | AGENT SELECTION 52 |
| 9.4 | SAFETY REQUIREMENTS..... 52 |
| 9.5 | SYSTEM DESIGN 52 |
| 9.6 | ENCLOSURE REQUIREMENTS..... 56 |
| 9.7 | AGENT SUPPLY 57 |
| 9.8 | DISTRIBUTION SYSTEM..... 57 |
| 9.9 | DETECTION, ACTUATION AND CONTROL..... 58 |
| 9.10 | MARKING 59 |
| 9.11 | COMMISSIONING AND ACCEPTANCE 59 |
| 9.12 | DOCUMENTATION..... 60 |
| 9.13 | INSPECTION AND MAINTENANCE..... 60 |
| SECTION 10 COMMISSIONING AND ACCEPTANCE | |
| 10.1 | SCOPE 61 |
| 10.2 | PRELIMINARY REVIEWS AND CHECKS 61 |
| 10.3 | FUNCTIONAL TESTS 63 |
| 10.4 | DISCHARGE TEST 64 |
| 10.5 | COMPLETION CERTIFICATE AND DOCUMENTATION 65 |

Page

APPENDICES

| | | | |
|----|---|--|-----|
| | A | COMMISSIONING CHECK LIST..... | 66 |
| | B | DISCHARGE TEST | 68 |
| | C | CERTIFICATE OF COMPLETION..... | 70 |
| | D | DOOR FAN TEST FOR DETERMINATION OF MINIMUM HOLDING TIME | 72 |
| | E | GASEOUS FIRE EXTINGUISHING SYSTEMS USING IG-541 (INERGEN) EXTINGUISHING AGENT-INERT..... | 80 |
| | F | GASEOUS FIRE EXTINGUISHING SYSTEMS USING CARBON DIOXIDE (CO ₂) EXTINGUISHING AGENT..... | 89 |
| A1 | G | GASEOUS FIRE EXTINGUISHING SYSTEMS USING IG-55 (ARGONITE) EXTINGUISHING AGENT—INERT..... | 116 |
| | H | GASEOUS FIRE EXTINGUISHING SYSTEMS USING FIC-13I1 (CF ₃ I) TRIFLUOROIODOMETHANE (TRIODIDE) EXTINGUISHING AGENT— HALOCARBON..... | 124 |
| | I | GASEOUS FIRE EXTINGUISHING SYSTEMS USING HCFC BLEND A (NAF S-III) EXTINGUISHING AGENT— HALOCARBON..... | 132 |
| | J | GASEOUS FIRE EXTINGUISHING SYSTEMS USING HFC-227 _{ea} (FM-200) EXTINGUISHING AGENT—HALOCARBON | 140 |
| | K | GASEOUS FIRE EXTINGUISHING SYSTEMS USING HFC-23 (FE-13) EXTINGUISHING AGENT—HALOCARBON | 149 |

FOREWORD

Gaseous fire extinguishing systems covered in this Standard are intended to extinguish, suppress or inert fires.

Several different extinguishing agents have been developed in recent years, and there is a need for dissemination of information on systems and the design methods required for their extinguishing agents. This Standard has been prepared to meet this need.

Gaseous fire extinguishing systems utilizing extinguishing agents that have been supported by the presentation of full technical data to the Committee have been included in the appendices. These data include relevant details on the health and safety aspects, environmental acceptability and the system design methods, hardware and software.

In addition, alternative requirements to the release of extinguishing agents during testing and commissioning procedures have been included. These are linked to the inclusion of enclosure integrity testing.

The requirements of this Standard are made in the light of the best technical data known to the Committee at the time of writing, but since a wide field is covered it has been impracticable to consider every possible factor or circumstance that might affect implementation of the recommendations.

This Standard has been prepared on the basis that personnel with the appropriate levels of skill, training and practical experience would undertake the functions associated with the design, installation, testing and commissioning of gaseous fire extinguishing systems, to provide safe and satisfactory performance, including exercising a duty of care to avoid unnecessary release of extinguishing agent.

It is important that the protection of a structure, building or plant be considered on a holistic approach basis. Gaseous fire extinguishing systems form only a part of the available facilities, but it should not be assumed that their adoption necessarily removes the need to consider supplementary measures, such as the provision of portable fire extinguishers or other mobile appliances for first aid or emergency use, or to deal with special hazards.

Gaseous fire extinguishing systems have for many years been recognized as effective for extinguishing flammable liquid fires and fires in the presence of electrical and ordinary Class A hazards. However, when planning systems, designers should be aware that there may be hazards for which these agents are not suitable, or that in certain circumstances or situations there may be dangers in their use, which will require special precautions.

Advice on these matters can be obtained from the manufacturers of gaseous fire extinguishing systems. Additional information can also be sought from fire authorities, health and safety authorities, insurers and the authority having jurisdiction.

Gaseous fire extinguishing systems need to be maintained to ensure readiness when required. The importance of maintenance cannot be too highly emphasized.

STANDARDS AUSTRALIA

Australian Standard
Gaseous fire extinguishing systems

SECTION 1 SCOPE AND GENERAL

1.1 SCOPE

A1 | This Standard sets out requirements for design, installation, testing and commissioning of gaseous fire extinguishing systems for both total flooding and local application types. It applies to central and distributed supply systems.

This Standard does not apply to explosion suppression.

This Standard deals with systems utilizing electrically non-conducting extinguishing agents that do not leave a residue after discharge and for which there is sufficient data currently available to enable validation of performance characteristics by an internationally recognized fire protection test and approval body (see Clause 1.9). It is not intended to indicate approval by the authorities having jurisdiction of the systems utilizing the agents included in Table 1.1. It is essential that this Standard be used in conjunction with its separate, specific extinguishing agent contained in the appendices of this Standard.

The characteristics of extinguishing agents and their suitability for classes of fire are also considered.

NOTES:

- 1 This Standard should be read in conjunction with AS 1851.12, which covers inspection, testing and maintenance of gaseous fire extinguishing systems.
- 2 Gas pressures have been expressed in bars with the SI units (MPa, kPa) shown in brackets immediately following.
- 3 Where values have been obtained from sources such as NFPA, they have been conservatively rounded.
- A1 | 4 For the purposes of this Standard, fire extinguishing includes inerting.