

Australian/New Zealand Standard™

**Electrical installations—Selection of
cables**

**Part 1.2: Cables for alternating voltages
up to and including 0.6/1 kV—Typical
New Zealand conditions**



AS/NZS 3008.1.2:2010

This Joint Australian/New Zealand Standard was prepared by Joint Technical Committee EL-001, Wiring Rules. It was approved on behalf of the Council of Standards Australia on 22 March 2010 and on behalf of the Council of Standards New Zealand on 29 March 2010.

This Standard was published on 22 April 2010.

The following are represented on Committee EL-001:

Association of Consulting Engineers Australia
Australian Building Codes Board
Australian Industry Group
Communications, Electrical and Plumbing Union
Consumers' Federation of Australia
Electrical and Communications Association (Qld)
Electrical Contractors Association of New Zealand
Electrical Regulatory Authorities Council
Electrical Safety Organisation (New Zealand)
ElectroComms & Energy Utilities Industries Skills Council
Energy Networks Australia
Institute of Electrical Inspectors
Ministry of Economic Development (New Zealand)
National Electrical and Communications Association
New Zealand Council of Elders
New Zealand Electrical Institute
Telstra Corporation Limited

Keeping Standards up-to-date

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about joint Australian/New Zealand Standards can be found by visiting the Standards Web Shop at www.saiglobal.com.au or Standards New Zealand web site at www.standards.co.nz and looking up the relevant Standard in the on-line catalogue.

For more frequent listings or notification of revisions, amendments and withdrawals, Standards Australia and Standards New Zealand offer a number of update options. For information about these services, users should contact their respective national Standards organization.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Please address your comments to the Chief Executive of either Standards Australia or Standards New Zealand at the address shown on the back cover.

Australian/New Zealand Standard™

**Electrical installations—Selection of
cables**

**Part 1.2: Cables for alternating voltages
up to and including 0.6/1 kV—Typical
New Zealand conditions**

Originated in Australia as AS 3008.1—1984.
Second edition 1989.
Jointly revised and redesignated AS/NZS 3008.1.2:1998.
Fourth edition 2010.

COPYRIGHT

© Standards Australia/Standards New Zealand

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher.

Jointly published by Standards Australia, GPO Box 476, Sydney, NSW 2001 and Standards New Zealand, Private Bag 2439, Wellington 6140

ISBN 978-1-86975-128-9

PREFACE

This Standard was prepared by the Joint Standards Australia/Standards New Zealand Committee EL-001, Wiring Rules, to supersede AS/NZS 3008.1.2:1998, *Electrical installations—Selection of cables, Part 1.2 Cables for alternating voltages up to and including 0.6/1 kV—Typical New Zealand installation conditions*. This Standard is applicable to New Zealand installation conditions where the nominal ambient air and soil temperatures are 30°C and 15°C, respectively. Part 1.1 is applicable to Australian installation conditions where the nominal air and soil temperatures are 40°C and 25°C respectively. Each Part is a complete Standard and requires no reference to the other.

Part 2 will deal with cables for use with alternating voltages over 1 kV.

The objective of the Standard is to specify current-carrying capacity, voltage drop and short-circuit temperature rise of cables, to provide a method of selection for those types of electric cables and methods of installation that are in common use at working voltages up to and including 0.6/1 kV at 50 Hz a.c.

This Standard differs from the 1998 edition as follows:

- (a) The limitations of the installation of thermoplastic insulated cables have been further clarified.
- (b) An explanation has been provided regarding the properties of cross-linked materials at higher temperatures.
- (c) Information has been included on the effect of harmonic currents on balanced three-phase systems, the effect of parallel cables and the effect of electromagnetic interference.
- (d) Ratings for cables with flexible conductors and cables exposed to the sun have been extended in the tables of current-carrying capacities.
- (e) Thermoplastic insulated cables with temperature ratings of 90°C and 105°C have been included in the tables covering current-carrying capacities of cables with 90°C rated cross-linked insulation materials.
- (f) For cables with conductor sizes up to 10 mm² the values of current-carrying capacities for installation in underground wiring enclosures have also been used for the situation of installations 'buried direct'.
- (g) Current-carrying capacities for cables installed in wiring enclosures have been recalculated according to IEC 60287.
- (h) The values for all current-carrying capacities have been expressed to the nearest ampere to align with current IEC practice.
- (i) Additional values for a.c. resistance and three-phase voltage drop have been included for single-core aerial cables with bare or insulated conductors operating at a conductor temperature of 80°C.
- (j) Table headings have been simplified and now listed in an Appendix for ease of reference.

In the preparation of this Standard, reference was made to IEC 60287 and acknowledgment is made of the assistance received from that source.

Statements expressed in mandatory terms in notes to tables and figures are deemed to be requirements of this Standard.

The term 'informative' has been used in this Standard to define the application of the appendix to which it applies. An 'informative' appendix is only for information and guidance.

CONTENTS

	<i>Page</i>
SECTION 1 SCOPE AND APPLICATION	
1.1 SCOPE	6
1.2 APPLICATION	6
1.3 ALTERNATIVE SPECIFICATIONS	7
1.4 REFERENCED AND RELATED DOCUMENTS	7
1.5 DEFINITIONS	8
SECTION 2 CABLE SELECTION PROCEDURE	
2.1 GENERAL	10
2.2 SELECTION PROCESS.....	10
2.3 DETERMINATION OF MINIMUM CABLE SIZE BASED ON CURRENT-CARRYING CAPACITY CONSIDERATIONS	10
2.4 DETERMINATION OF MINIMUM CABLE SIZE BASED ON VOLTAGE DROP CONSIDERATIONS	11
2.5 DETERMINATION OF MINIMUM CABLE SIZE BASED ON THE SHORT-CIRCUIT TEMPERATURE CONSIDERATIONS	12
SECTION 3 CURRENT-CARRYING CAPACITY	
3.1 RATINGS.....	13
3.2 TYPES OF CONDUCTORS	13
3.3 TYPES OF CABLE.....	15
3.4 INSTALLATION CONDITIONS.....	16
3.5 EXTERNAL INFLUENCES ON CABLES.....	20
SECTION 4 VOLTAGE DROP	
4.1 GENERAL	86
4.2 DETERMINATION OF VOLTAGE DROP FROM MILLIVOLTS PER AMPERE METRE	86
4.3 DETERMINATION OF VOLTAGE DROP FROM CIRCUIT IMPEDANCE.....	87
4.4 DETERMINATION OF VOLTAGE DROP FROM CABLE OPERATING TEMPERATURE	88
4.5 DETERMINATION OF VOLTAGE DROP FROM LOAD POWER FACTOR	89
4.6 DETERMINATION OF VOLTAGE DROP IN UNBALANCED MULTIPHASE CIRCUITS.....	90
SECTION 5 SHORT-CIRCUIT PERFORMANCE	
5.1 GENERAL	113
5.2 FACTORS GOVERNING THE APPLICATION OF THE TEMPERATURE LIMITS.....	113
5.3 CALCULATION OF PERMISSIBLE SHORT-CIRCUIT CURRENTS.....	114
5.4 INFLUENCE OF METHOD OF INSTALLATION	115
5.5 MAXIMUM PERMISSIBLE SHORT-CIRCUIT TEMPERATURES.....	115

APPENDICES

A	EXAMPLES OF THE SELECTION OF CABLES TO SATISFY CURRENT-CARRYING CAPACITY, VOLTAGE DROP AND SHORT-CIRCUIT PERFORMANCE REQUIREMENTS	117
B	LIST OF TABLES.....	126
C	EXAMPLES OF THE APPLICATION OF REDUCTION FACTORS FOR HARMONIC CURRENTS	130
D	RECOMMENDED CIRCUIT CONFIGURATIONS FOR THE INSTALLATION OF SINGLE-CORE CABLES IN PARALLEL	131

STANDARDS AUSTRALIA/STANDARDS NEW ZEALAND

Australian/New Zealand Standard
Electrical installations—Selection of cables

**Part 1.2: Cables for alternating voltages up to and including 0.6/1 kV—
Typical New Zealand conditions**

SECTION 1 SCOPE AND APPLICATION

1.1 SCOPE

This Standard sets out a method for cable selection for those types of electrical cables and methods of installation that are in common use at working voltages up to and including 0.6/1 kV at 50 Hz a.c.

Three criteria are given for cable selection, as follows:

- (a) Current-carrying capacity.
- (b) Voltage drop.
- (c) Short-circuit temperature rise.

This Standard provides sustained current-carrying capacities and voltage drop values for those types of electrical cable and installation practices in common use in New Zealand. A significant amount of explanatory material is also provided on the application of rating factors that arise from the particular installation conditions of a single circuit or groups of circuits. Also, provided in Section 5 is information on cable selection based on short-circuit temperature limits.

NOTE: A number of worked examples on cable selection are included in Appendix A.

This Standard does not take into account the effects that may occur owing to temperature rise at the terminals of equipment and reference is necessary to AS/NZS 3000 and the individual equipment Standards.

NOTE: For ease of reference, an index of the Tables included in this Standard is provided in Appendix B.

1.2 APPLICATION

This Standard is intended to apply to installations made or carried out after the date of publication, but it is recommended that it not be applied on a mandatory basis until 6 months after the date of publication. However, if work on an installation commenced before publication of this edition, the inspecting authority may grant permission for the installation to be carried out in accordance with the superseded edition.