

Australian/New Zealand Standard™

**Tests for electric cables under fire
conditions—Circuit integrity**

**Part 2: Test method for fire with shock
at a temperature of at least 830 °C for
cables of rated voltage up to and
including 0.6/1.0 kV and with an overall
diameter not exceeding 20 mm**



AS/NZS IEC 60331.2:2017

This Joint Australian/New Zealand Standard was prepared by Joint Technical Committee EL-003, Electric Wires and Cables. It was approved on behalf of the Council of Standards Australia on 5 March 2017 and by the New Zealand Standards Approval Board on 5 April 2017.

This Standard was published on 1 May 2017.

The following are represented on Committee EL-003:

Australian Cable Makers' Association
Australian Industry Group
Electrical Compliance Testing Association
Electrical Contractors Association of New Zealand
Electrical Regulatory Authorities Council
Institute of Electrical Inspectors
National Electrical and Communications Association
Queensland University of Technology
Worksafe New Zealand

Keeping Standards up-to-date

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about joint Australian/New Zealand Standards can be found by visiting the Standards Web Shop at www.saiglobal.com or Standards New Zealand web site at www.standards.govt.nz and looking up the relevant Standard in the on-line catalogue.

For more frequent listings or notification of revisions, amendments and withdrawals, Standards Australia and Standards New Zealand offer a number of update options. For information about these services, users should contact their respective national Standards organization.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Please address your comments to the Chief Executive of Standards Australia or the New Zealand Standards Executive at the address shown on the back cover.

This Standard was issued in draft form for comment as DR AS/NZS IEC 60331.2:2016.

Australian/New Zealand Standard™

Tests for electric cables under fire conditions—Circuit integrity

Part 2: Test method for fire with shock at a temperature of at least 830 °C for cables of rated voltage up to and including 0.6/1.0 kV and with an overall diameter not exceeding 20 mm

Originated as part of AS/NZS 1660.5.5:1998.
Previous edition AS/NZS 1660.5.5:2005.
Jointly revised in part and redesignated as AS/NZS IEC 60331.2:2017.

COPYRIGHT

© Standards Australia Limited

© The Crown in right of New Zealand, administered by the New Zealand Standards Executive

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher, unless otherwise permitted under the Copyright Act 1968 (Australia) or the Copyright Act 1994 (New Zealand).

Jointly published by SAI Global Limited under licence from Standards Australia Limited, GPO Box 476, Sydney, NSW 2001 and by Standards New Zealand, PO Box 1473, Wellington 6140.

PREFACE

This Standard was prepared by the Joint Standards Australia/Standards New Zealand Committee, EL-003 Electric Wires and Cables, to supersede, in part, AS/NZS 1660.5.5:2005, *Test methods for electric cables, cords and conductors*, Method 5.5: *Fire tests—Circuit integrity*.

The objective of this Standard is to specify the test apparatus and procedure and gives the performance requirements, including recommended flame application times, for low-voltage power cables of rated voltage up to and including 0.6/1.0 kV and control cables with a rated voltage which are required to maintain circuit integrity when subject to fire and mechanical shock under specified conditions, intended for use when testing cables not greater than 20 mm overall diameter.

This Standard is identical with and has been reproduced from IEC 60331-2, Ed 1.0 (2009), *Tests for electric cables under fire conditions—Circuit integrity*, Part 2: *Test method for fire with shock at a temperature of at least 830°C for cables of rated voltage up to and including 0,6/1,0 kV and with an overall diameter not exceeding 20 mm*.

As this Standard is reproduced from an International Standard, the following applies:

- (a) In the source text ‘this part of 60331 should read ‘this Australian/New Zealand Standard’.
- (b) A full point substitutes for a comma when referring to a decimal marker.

None of the normative references in the source document have been adopted as Australian or Australian/New Zealand Standards.

CONTENTS

| | | |
|-------|--|----|
| 1 | Scope | 7 |
| 2 | Normative references..... | 7 |
| 3 | Terms and definitions | 7 |
| 4 | Test conditions – Test environment..... | 8 |
| 5 | Test apparatus | 8 |
| 5.1 | Test equipment..... | 8 |
| 5.2 | Test wall and mounting | 11 |
| 5.3 | Source of heat | 13 |
| 5.3.1 | Burner | 13 |
| 5.3.2 | Flow meters and flow rates | 14 |
| 5.3.3 | Verification | 15 |
| 5.4 | Shock producing device | 15 |
| 5.5 | Positioning of source of heat..... | 16 |
| 5.6 | Continuity checking arrangements | 16 |
| 5.7 | Fuses | 16 |
| 6 | Test specimen | 16 |
| 6.1 | Test specimen preparation..... | 16 |
| 6.2 | Test specimen mounting | 17 |
| 7 | Test procedure | 17 |
| 7.1 | Test equipment and arrangement..... | 17 |
| 7.2 | Electrical connections | 17 |
| 7.3 | Flame and shock application..... | 19 |
| 7.4 | Electrification..... | 19 |
| 8 | Performance requirements..... | 20 |
| 8.1 | Flame application time | 20 |
| 8.2 | Acceptance criteria | 20 |
| 9 | Retest procedure | 20 |
| 10 | Test report..... | 20 |
| 11 | Cable marking | 20 |
| | Annex A (normative) Verification procedure for the source of heat | 21 |
| | Annex B (informative) Guidance on the choice of recommended test apparatus | 23 |
| | Bibliography | 24 |
| | Figure 1 – Schematic diagram of test configuration..... | 9 |
| | Figure 2 – Plan view of fire test equipment | 10 |
| | Figure 3 – End elevation of fire test equipment (not to scale) | 11 |
| | Figure 4 – Typical rubber bush (hardness: 50-60 shore A) for fastening wall | 13 |
| | Figure 5 – Burner face | 14 |
| | Figure 6 – Schematic diagram of an example of a burner control system using rotameters | 15 |
| | Figure 7 – Example of method of mounting a sample for test | 17 |

Figure 8 – Basic circuit diagram – Electric power and control cables with rated voltage up to 600/1 000 V 19

Figure A.1 – Temperature measuring arrangement 21

INTRODUCTION

IEC 60331 consists of the following parts under the general title: *Tests for electric cables under fire conditions – Circuit integrity*:

- Part 1: Test method for fire with shock at a temperature of at least 830 °C for cables of rated voltage up to and including 0,6/1,0 kV and with an overall diameter exceeding 20 mm
- Part 2: Test method for fire with shock at a temperature of at least 830 °C for cables of rated voltage up to and including 0,6/1,0 kV and with an overall diameter not exceeding 20 mm
- Part 3: Test method for fire with shock at a temperature of at least 830 °C for cables of rated voltage up to and including 0,6/1,0 kV tested in a metal enclosure
- Part 11: Apparatus – Fire alone at a flame temperature of at least 750 °C
- Part 21: Procedures and requirements – Cables of rated voltage up to and including 0,6/1,0 kV
- Part 23: Procedures and requirements – Electric data cables
- Part 25: Procedures and requirements – Optical fibre cables

NOTE Parts 21, 23 and 25 relate to fire-only conditions at a flame temperature of at least 750 °C.

Since its first edition (1970), IEC 60331 has been extended and has introduced a range of test apparatus in order that a test may be carried out on large and small power, control, data and optical fibre cables.

Successful tests carried out in accordance with this standard will enable an identification to be marked on the product.

NOTES

AUSTRALIAN/NEW ZEALAND STANDARD

Tests for electric cables under fire conditions—Circuit integrity

Part 2:

Test method for fire with shock at a temperature of at least 830 °C for cables of rated voltage up to and including 0.6/1.0 kV and with an overall diameter not exceeding 20 mm

1 Scope

This part of IEC 60331 specifies the test apparatus and procedure and gives the performance requirements, including recommended flame application times, for low-voltage power cables of rated voltage up to and including 0.6/1.0 kV and control cables with a rated voltage which are required to maintain circuit integrity when subject to fire and mechanical shock under specified conditions. It is intended for use when testing cables not greater than 20 mm overall diameter.

NOTE Cables of larger diameter should be tested using the apparatus, procedure and requirements of IEC 60331-1.

This standard describes the means of test specimen preparation, the continuity checking arrangements, the electrical testing procedure, the method of burning the cables and the method of shock production, and gives requirements for evaluating test results

Annex A provides the method of verification of the burner and control system used for the test.

Requirements are stated for an identification that may optionally be marked on the cable to signify compliance with this standard.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60584-1, *Thermocouples – Part 1: Reference tables*

IEC 60269-3, *Low-voltage fuses – Part 3: Supplementary requirements for fuses for use by unskilled persons (fuses mainly for household and similar applications) – Examples of standardized systems of fuses A to F*

IEC Guide 104, *The preparation of safety publications and the use of basic safety publications and group safety publications*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

3.1**circuit integrity**

ability of an electric cable to continue to operate in the designated manner whilst subjected to a specified flame source for a specified period of time under specified conditions.