

Australian Standard™

**Water supply—Valves for the control of
hot water supply temperatures**

**Part 2: Tempering valves and end-of-line
temperature-actuated devices**

This Australian Standard was prepared by Committee WS-026, Valves Primarily for Use in Warm and Hot Water Systems. It was approved on behalf of the Council of Standards Australia on 13 July 2001 and published on 8 February 2002.

The following interests are represented on Committee WS-026:

AUSTAP

Australian Industry Group

Business New Zealand

Consumers Federation of Australia

Gas Appliance Manufacturers Association of Australia

Housing Industry Association

Institute of Hospital Engineering Australia

Master Plumbers and Mechanical Contractors Association of NSW

Master Plumbers, Gasfitters and Drainlayers New Zealand

NSW Health Department

New Zealand Engineering Federation

South Australian Department of Human Services

Water Corporation Western Australia

Keeping Standards up-to-date

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about Standards can be found by visiting the Standards Australia web site at www.standards.com.au and looking up the relevant Standard in the on-line catalogue.

Alternatively, the printed Catalogue provides information current at 1 January each year, and the monthly magazine, *The Australian Standard*, has a full listing of revisions and amendments published each month.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Contact us via email at mail@standards.com.au, or write to the Chief Executive, Standards Australia International Ltd, GPO Box 5420, Sydney, NSW 2001.

Australian Standard™

**Water supply—Valves for the control of
hot water supply temperatures**

**Part 2: Tempering valves and end-of-line
temperature-actuated devices**

First published as AS 4032.2—2002.

COPYRIGHT

© Standards Australia International

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher.

Published by Standards Australia International Ltd
GPO Box 5420, Sydney, NSW 2001, Australia

ISBN 0 7337 4037 5

PREFACE

This Standard was prepared by the Australian members of the Joint Standards Australia/Standards New Zealand Committee WS-026, Valves Primarily for Use in Warm and Hot Water Systems. After consultation with stakeholders in both countries, Standards Australia and Standards New Zealand decided to develop this Standard as an Australian Standard rather than an Australian/New Zealand Standard.

The objective of this Standard is to provide manufacturers with requirements for tempering valves and end-of-line temperature-actuated devices that give reasonable protection to users against exposure to high or excessive fluctuations in mixed water temperatures caused by the following:

- (a) Maintaining an outlet temperature within specified limits, including shut-off of the cold water supply.
- (b) Closing the outlet when the mixed water temperature exceeds a specified maximum.

This Standard is Part 2 of a suite of Standards that covers valves for the control of hot water temperatures, as follows:

AS

4032 Water supply—Valves for the control of hot water supply temperatures

4032.1 Part 1: Thermostatic mixing valves—Materials, design and performance requirements

4032.2 Part 2: Tempering valves and end-of-line temperature-actuated devices (this Standard)

Upon completion, the suite will include the following:

Part 3: Mandatory field testing, maintenance and replacement of thermostatic elements

The terms ‘normative’ and ‘informative’ have been used in this Standard to define the application of the appendix to which they apply. A ‘normative’ appendix is an integral part of a Standard, whereas an ‘informative’ appendix is only for information and guidance.

This Standard necessarily deals with existing conditions, but is not intended to discourage innovation or to exclude materials, equipment and methods that may be developed in the future. Revisions will be made from time to time in view of such developments, and amendments to this edition will be made only when absolutely necessary.

CONTENTS

	<i>Page</i>
FOREWORD	5
SECTION 1 SCOPE AND GENERAL	
1.1 SCOPE	6
1.2 REFERENCED DOCUMENTS	6
1.3 DEFINITIONS	7
1.4 INSTRUMENTATION	7
1.5 TOLERANCES	7
1.6 MARKING.....	7
SECTION 2 MATERIALS	
2.1 GENERAL	9
2.2 COPPER ALLOY MATERIALS	9
2.3 DIAPHRAGM MATERIALS AND VALVE SEATS	9
2.4 SPRING MATERIALS	9
2.5 CONTAMINATION OF WATER	9
SECTION 3 DESIGN AND CONSTRUCTION	
3.1 GENERAL	10
3.2 STRENGTH.....	10
3.3 END CONNECTIONS.....	10
3.4 COMPONENTS AND VALVE SEATS	10
3.5 REPAIR	10
3.6 INSTRUCTIONS.....	10
SECTION 4 TEMPERING VALVES	
4.1 GENERAL	11
4.2 INLET AND OUTLET CONNECTIONS	11
4.3 DESIGN REQUIREMENTS.....	11
4.4 TEMPERATURE STABILITY OF MIXED WATER	11
4.5 SEQUENCE OF TESTS	12
4.6 ENDURANCE OF THERMOSTATIC ELEMENT AND OPERATING MECHANISM	13
4.7 MARKING.....	13
4.8 MANUFACTURER'S INSTRUCTIONS.....	13
SECTION 5 END-OF-LINE TEMPERATURE-ACTUATED FLOW DEVICES	
5.1 GENERAL	14
5.2 CONNECTIONS.....	14
5.3 ACTUATING TEMPERATURE	14
5.4 PERFORMANCE	14
5.5 ENDURANCE	14
5.6 MARKING.....	14
5.7 MANUFACTURER'S INSTRUCTIONS.....	15

APPENDICES

A	INSTRUMENTATION	16
B	TORQUE TEST	17
C	LEAKAGE TEST	19
D	INFORMATION ON SCALDS FROM HOT WATER.....	20
E	TEMPERATURE STABILITY OF MIXED WATER TEST—TEMPERING VALVES.....	21
F	ENDURANCE TEST—TEMPERING VALVES.....	31
G	PERFORMANCE AND ENDURANCE TESTS—END-OF-LINE TEMPERATURE-ACTUATED FLOW DEVICES	33

FOREWORD

The type and nominal size of tempering valves and ancillary equipment (if any) are selected with consideration of factors that include the following:

Tempering valves

General

- (a) Nominal size (DN).
- (b) Number and size of water inlets and outlets.
- (c) Number and size of connections.
- (d) Minimum and maximum dynamic pressures and cooperating temperatures for hot and cold water.
- (e) Minimum and maximum flow rates.
- (f) Whether provided with integral cross-flow prevention devices

Ancillary equipment—Pressure control devices

Maximum pressure ratio (cold to hot or hot to cold)

Maximum continuous working pressures for hot and cold water.

End-of-line temperature-actuated devices

General

- (i) Minimum and maximum dynamic pressures and operating temperatures for hot and cold water
- (ii) Flow rates

STANDARDS AUSTRALIA

Australian Standard**Water supply—Valves for the control of hot water supply temperatures****Part 2: Tempering valves and end-of-line temperature-actuated devices**

SECTION 1 SCOPE AND GENERAL

1.1 SCOPE

This Standard specifies requirements for the design, construction, testing and performance of—

- (a) tempering valves of nominal sizes not larger than DN 32; and
- (b) end-of-line temperature-actuated devices of nominal size DN 15, for use with hot water at—
 - (i) continuous operating temperature not exceeding 85°C;
 - (ii) temperature under emergency conditions, not exceeding 99°C; and
 - (iii) continuous working pressure not exceeding 1400 kPa.

The major requirement of the testing procedures is that the device under test does not permit the continuous discharge of water from the outlet in excess of 50°C.

Discharges of water with a temperature in excess of this figure, which comply with the specified cumulative time/temperature factors, are acceptable.

1.2 REFERENCED DOCUMENTS

The following documents are referred to in this Standard:

AS

- | | |
|--------|--|
| 1349 | Bourdon tube pressure and vacuum gauges |
| 1432 | Copper tubes for plumbing, gasfitting and drainage applications |
| 1722 | Pipe threads of Whitworth form |
| 1722.1 | Part 1: Sealing pipe threads |
| 1722.2 | Part 2: Fastening pipe threads |
| 2345 | Dezincification resistance of copper alloys |
| 2837 | Wrought alloy steels — Stainless steel bars and semi-finished products |
| 3688 | Water supply—Copper and copper alloy body compression and capillary fittings and threaded-end connectors |

AS/NZS

- | | |
|--------|---|
| 3500 | National plumbing and drainage code |
| 3500.0 | Part 0: Glossary of terms |
| 4020 | Products for use in contact with drinking water |