

Australian Standard[®]

POWER TRANSFORMERS
Part 5—ABILITY TO WITHSTAND
SHORT-CIRCUIT

[Title Allocated by Defence Cataloguing Authority:
TRANSFORMER, POWER (Ability to withstand Short Circuit)
...NSC 5950, 6120]

This Australian standard, prepared by Committee EL/8, Static Electrical Machinery, was approved on behalf of the Council of the Standards Association of Australia on 8 June 1982 and published on 9 August 1982.

The following interests were represented on the committee responsible for the preparation of this standard:

Australian-British Trade Association
Australian Electrical and Electronic Manufacturers Association
Confederation of Australian Industry
Defence Standardization Committee
Electrical testing laboratories
Electricity Supply Association of Australia
Electricity Supply Engineers Association of N.S.W.
Institution of Engineers, Australia
Railways of Australia Committee

Review of Australian Standards. *To keep abreast of progress in industry, Australian Standards are subject to periodic review and are kept up to date by the issue of amendments or new editions as necessary. It is important therefore that Standards users ensure that they are in possession of the latest edition, and any amendments thereto.*

Full details of all Australian Standards and related publications will be found in the Standards Australia Catalogue of Publications; this information is supplemented each month by the magazine 'The Australian Standard', which subscribing members receive, and which gives details of new publications, new editions and amendments, and of withdrawn Standards.

Suggestions for improvements to Australian Standards, addressed to the head office of Standards Australia, are welcomed. Notification of any inaccuracy or ambiguity found in an Australian Standard should be made without delay in order that the matter may be investigated and appropriate action taken.

This Standard was issued in draft form for comment as DR 79177.

Australian Standard[®]

POWER TRANSFORMERS
Part 5—ABILITY TO WITHSTAND
SHORT-CIRCUIT

First published (included in AS C61)	1931
Revised	1946
Revised	1963
Revised	1970
Revised and issued as AS 2374, Part 5	1982

PUBLISHED BY STANDARDS AUSTRALIA
(STANDARDS ASSOCIATION OF AUSTRALIA)
1 THE CRESCENT, HOMEBUSH, NSW 2140

ISBN 0 7262 2641 6

PREFACE

This standard was prepared by the Association's Committee on Static Electrical Machinery. It is based closely on IEC 76—5 (including Amendment No 1), Power Transformers, Part 5: Ability to Withstand Short Circuits, and is Part 5 of a six-part standard to supersede AS C61—1970, Power Transformers.

The other Parts of the standard are:

- Part 1— General Requirements
- Part 2— Temperature Rise
- Part 3— Insulation Levels and Dielectric Tests
- Part 4— Tappings and Connections
- Part 6— Sound Levels

Where this standard differs from IEC 76—5 and changes have been made in compliance with Australian requirements, these changes are indicated by a rule in the margin. Only minor deviations from IEC 76—5 have been made but additional information and requirements have been introduced.

The main additions include:

- (a) Table 4 (b) which sets out maximum current densities for different classes of transformers.
- (b) Appendix A which gives guidance for a reduced schedule of short-circuit tests for category one transformers, that may be applied by agreement between the purchaser and the manufacturer.

 CONTENTS

	<i>Page</i>
SECTION 1. SCOPE AND DEFINITIONS	
1.1 Scope	3
1.2 Definitions	3
SECTION 2. REQUIREMENTS WITH REGARD TO ABILITY TO WITHSTAND SHORT-CIRCUIT	
2.1 General	4
2.2 Overcurrent Conditions	4
SECTION 3. DEMONSTRATION OF ABILITY TO WITHSTAND SHORT-CIRCUIT	
3.1 Thermal Ability to Withstand Short-circuit	6
3.2 Dynamic Ability to Withstand Short-circuit	7
APPENDIX A. MODIFIED SHORT-CIRCUIT TEST PROCEDURE FOR CATEGORY I TRANSFORMERS	10

© Copyright — STANDARDS AUSTRALIA

Users of Standards are reminded that copyright subsists in all Standards Australia publications and software. Except where the Copyright Act allows and except where provided for below no publications or software produced by Standards Australia may be reproduced, stored in a retrieval system in any form or transmitted by any means without prior permission in writing from Standards Australia. Permission may be conditional on an appropriate royalty payment. Requests for permission and information on commercial software royalties should be directed to the head office of Standards Australia.

Standards Australia will permit up to 10 percent of the technical content pages of a Standard to be copied for use exclusively in-house by purchasers of the Standard without payment of a royalty or advice to Standards Australia.

Standards Australia will also permit the inclusion of its copyright material in computer software programs for no royalty payment provided such programs are used exclusively in-house by the creators of the programs.

Care should be taken to ensure that material used is from the current edition of the Standard and that it is updated whenever the Standard is amended or revised. The number and date of the Standard should therefore be clearly identified.

The use of material in print form or in computer software programs to be used commercially, with or without payment, or in commercial contracts is subject to the payment of a royalty. This policy may be varied by Standards Australia at any time.

STANDARDS ASSOCIATION OF AUSTRALIA

**Australian Standard
for
POWER TRANSFORMERS**

PART 5—ABILITY TO WITHSTAND SHORT-CIRCUIT

SECTION 1. SCOPE AND DEFINITIONS

1.1 SCOPE. This standard specifies the design of power transformers as defined in AS 2374, Part 1, and the requirements necessary both in regard to their ability to withstand short-circuit and the means of demonstrating that ability.

NOTES:

1. Pending the publication of a standard that applies to dry-type transformers*, the requirements of this standard may be applied to dry-type transformers subject to agreement between the purchaser and the manufacturer and taking into account the principles established in Sections 2 and 3.
2. A reduced schedule of short-circuit tests may be applied to Category I transformers by agreement between purchaser, manufacturer and testing authority. Guidance on the reduced schedule is given in Appendix A.

1.2 DEFINITIONS. For the purpose of this standard the definitions given in AS 2374, Part 1 apply.

* In course of preparation.