

Australian Standard™

Refrigerated display cabinets

**Part 11: Installation, maintenance and
user guide**



This Australian Standard was prepared by Committee ME-008, Refrigerated Display Cabinets. It was approved on behalf of the Council of Standards Australia on 26 September 2003.

This Standard was published on 1 October 2003.

The following are represented on Committee ME-008:

Australian Greenhouse Office
Australian Retailers Association
Commercial Refrigeration Manufacturers Association of Australia
Food Science Australia
Institution of Engineers Australia
Refrigeration Air Conditioning Companies Association

Keeping Standards up-to-date

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about Standards can be found by visiting the Standards Web Shop at www.standards.com.au and looking up the relevant Standard in the on-line catalogue.

Alternatively, the printed Catalogue provides information current at 1 January each year, and the monthly magazine, *The Global Standard*, has a full listing of revisions and amendments published each month.

Australian Standards™ and other products and services developed by Standards Australia are published and distributed under contract by SAI Global, which operates the Standards Web Shop.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Contact us via email at mail@standards.org.au, or write to the Chief Executive, Standards Australia, GPO Box 476, Sydney, NSW 2001.

This Standard was issued in draft form for comment as DR 03216.

Australian Standard™

Refrigerated display cabinets

Part 11: Installation, maintenance and user guide

Originated as AS B220—1966.
Previous edition AS 1731.11—2000.
Second edition 2003.
Reissued incorporating Amendment No. 1 (December 2005).

COPYRIGHT

© Standards Australia

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher.

Published by Standards Australia GPO Box 476, Sydney, NSW 2001, Australia

ISBN 0 7337 5535 6

PREFACE

This Standard was prepared by the Australian members of the Joint Standards Australia/Standards New Zealand Committee ME-008, Refrigerated Display Cabinets, to supersede AS 1731.11—2000, *Refrigerated display cabinets, Part 11: Installation, maintenance and user guide*. After consultation with stakeholders in both countries, Standards Australia and Standards New Zealand decided to develop this Standard as an Australian, rather than an Australian/New Zealand Standard.

This Standard incorporates Amendment No. 1 (December 2005). The changes required by the Amendment are indicated in the text by a marginal bar and amendment number against the clause, note, table, figure or part thereof affected.

This Standard is based on International Standard prEN ISO 23953-2:2003, *Refrigerated display cabinets, Part 2: Classification, requirements and test conditions*.

This Standard is Part 11 of a series of Standards for refrigerated display cabinets, as follows:

AS

- 1731 Refrigerated display cabinets
- 1731.1 Part 1: Terms and definitions
- 1731.2 Part 2: General mechanical and physical requirements
- 1731.3 Part 3: Linear dimensions, areas and volumes
- 1731.4 Part 4: General test conditions
- 1731.5 Part 5: Temperature test
- 1731.6 Part 6: Classification according to temperatures
- 1731.7 Part 7: Defrosting test
- 1731.8 Part 8: Water vapour condensation test
- 1731.9 Part 9: Electrical energy consumption test
- 1731.10 Part 10: Test for absence of odour and taste
- 1731.11 Part 11: Installation, maintenance and user guide (this Standard)
- 1731.12 Part 12: Measurement of the heat extraction rate of the cabinets when the condensing unit is remote from the cabinet
- 1731.13 Part 13: Test report
- 1731.14 Part 14: Minimum energy performance standard (MEPS) requirements

CONTENTS

	<i>Page</i>
1 SCOPE.....	4
2 REFERENCED DOCUMENTS.....	4
3 OBJECTIVE	4
4 IMPORTANT SITING CONDITIONS.....	4
5 INSTALLATION OF REFRIGERATING EQUIPMENT	5
6 CABINET OPERATION	6
7 MAINTENANCE	7

STANDARDS AUSTRALIA

Australian Standard
Refrigerated display cabinets

Part 11: Installation, maintenance and user guide

1 SCOPE

1.1 Scope of Standard

A1

This Standard specifies terminology, general mechanical and physical requirements, test conditions as well as installation and maintenance, for commercial refrigerators and freezers used for the sale or display of food products including beverages.

This Standard does not cover refrigerated vending machines, ice-makers, cabinets intended for use in catering and similar non-retail applications.

1.2 Scope of Part 11

This Part of AS 1731 gives information concerning the installation and maintenance of refrigerated display cabinets and includes a guide for users.

2 REFERENCED DOCUMENTS

The following documents are referred to in this Standard:

AS

1731 Refrigerated display cabinets

1731.2 Part 2: General mechanical and physical requirements

3 OBJECTIVE

The objective of this Standard is to provide guidance on installation and maintenance practices for use by manufacturers, suppliers, purchasers, operators and regulators of these systems.

4 IMPORTANT SITING CONDITIONS

4.1 Climate

In order to keep the ambient climate at the place of installation within agreed limits, it may be necessary to install airconditioning. Such an installation should include control of the relative humidity, as excessive humidity is detrimental to cabinet performance. It can be more economical to dehumidify the air by airconditioning than through cabinet evaporators operating at lower temperatures, as the latter is not energy efficient.

The grouping of cabinets in a defined area will be advantageous in terms of performance and operating costs; however, it may also cause customer discomfort.

4.2 Air draughts

The location of the cabinets should be such that air draughts are minimized or avoided. Cabinets should not be installed adjacent to doors or in areas where exposure to considerable air movement will be experienced, e.g., from airconditioning, ventilation and heating outlets.