



Reinforced Autoclaved Aerated Concrete

Part 3: Construction



This Australian Standard® was prepared by Committee BD-0106, Autoclaved Aerated Concrete. It was approved on behalf of the Council of Standards Australia on 23 November 2015.

This Standard was published on 23 December 2015.

The following are represented on Committee BD-0106:

- Association of Consulting Structural Engineers of NSW
 - Australian Building Codes Board
 - Australian Institute of Building
 - Building Designers Association of Australia
 - Consult Australia
 - CSIRO
 - Engineers Australia
 - Housing Industry Association
 - Master Builders Australia
 - National Precast Concrete Association Australia
-

This Standard was issued in draft form for comment as DR AS 5146.3:2015.

Standards Australia wishes to acknowledge the participation of the expert individuals that contributed to the development of this Standard through their representation on the Committee and through the public comment period.

Keeping Standards up-to-date

Australian Standards® are living documents that reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued.

Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments that may have been published since the Standard was published.

Detailed information about Australian Standards, drafts, amendments and new projects can be found by visiting www.standards.org.au

Standards Australia welcomes suggestions for improvements, and encourages readers to notify us immediately of any apparent inaccuracies or ambiguities. Contact us via email at mail@standards.org.au, or write to Standards Australia, GPO Box 476, Sydney, NSW 2001.

Australian Standard[®]

Reinforced Autoclaved Aerated Concrete

Part 3: Construction

First published as AS 5146.3:2015.

COPYRIGHT

© Standards Australia Limited

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher, unless otherwise permitted under the Copyright Act 1968.

Published by SAI Global Limited under licence from Standards Australia Limited, GPO Box 476, Sydney, NSW 2001, Australia

ISBN 978 1 76035 359 9

PREFACE

This Standard was prepared by the Standards Australia Committee BD-106, Autoclaved Aerated Concrete (AAC).

The objective of this Standard is to provide construction details and specifications that comply with the requirements of AS 5146.1, *Reinforced autoclaved aerated concrete, Part 1: Structures* and AS 5146.2, *Reinforced autoclaved aerated concrete, Part 2: Design*.

Statements expressed in mandatory terms in Notes to Figures and Tables are deemed to be requirements of this Standard.

All figures in this standard are reproduced with copyright permission from CSR Limited. CSR Limited does not assume any responsibility for the use of that content in any other context or for any modification of its original content. It is recommended that users of this standard obtain their own independent expert advice in relation to building and related activities.

CONTENTS

	<i>Page</i>
SECTION 1 SCOPE AND GENERAL	
1.1 SCOPE.....	5
1.2 APPLICATION	5
1.3 NORMATIVE REFERENCES	6
1.4 DEFINITIONS.....	7
SECTION 2 GENERAL REQUIREMENTS	
2.1 GENERAL.....	10
2.2 EXCLUSIONS.....	10
2.3 REINFORCED AAC MEMBERS AND STRUCTURES	10
2.4 CONNECTORS	10
2.5 DURABILITY	10
2.6 FIRE RESISTANCE	12
2.7 BUSHFIRE RESISTANCE	13
2.8 PREVENTION OF MOISTURE PENETRATION.....	13
2.9 CONTROL JOINTS AND ARTICULATION JOINTS	16
2.10 INSTALLATION	18
2.11 TOLERANCES	19
2.12 TEMPORARY BRACING AND PROTECTION	20
2.13 MATERIALS AND FIXINGS IN PARTICULAR APPLICATIONS.....	20
SECTION 3 STRUCTURAL CAPACITIES OF REINFORCED AAC MEMBERS, BATTENS AND FIXINGS	
3.1 SCOPE OF SECTION	25
3.2 RACKING RESISTANCE.....	25
3.3 LOAD CAPACITY OF REINFORCED AAC WALLS AND FACADES.....	25
3.4 LOAD CAPACITY OF REINFORCED AAC FLOORS	29
SECTION 4 75 mm REINFORCED AAC WALLS IN HOUSES AND LOW-RISE MULTI- RESIDENTIAL BUILDINGS	
4.1 SCOPE OF SECTION	30
4.2 CUSTOMIZED DETAILS.....	30
4.3 STANDARDS DETAILS	30
SECTION 5 75 mm REINFORCED AAC INTER-TENANCY WALLS IN LOW-RISE MULTI-RESIDENTIAL BUILDINGS	
5.1 SCOPE OF SECTION	74
5.2 CUSTOMIZED DETAILS.....	74
5.3 STANDARDS DETAILS	74
SECTION 6 75 mm REINFORCED AAC FLOORS IN HOUSES, LOW-RISE MULTI-RESIDENTIAL AND COMMERCIAL BUILDINGS	
6.1 SCOPE OF SECTION	89
6.2 CUSTOMIZED DETAILS.....	89
6.3 STANDARDS DETAILS	89

	<i>Page</i>
SECTION 7 150–250 mm REINFORCED AAC FLOORS	
7.1 SCOPE.....	130
7.2 CUSTOMIZED DETAILS.....	130
7.3 STANDARDS DETAILS	130
SECTION 8 HIGH RISE REINFORCED AAC FACADES	
8.1 SCOPE OF SECTION	148
8.2 CUSTOMIZED DETAILS.....	149
8.3 STANDARDS DETAILS	149
APPENDIX A INFORMATION TO BE SHOWN ON DOCUMENTS	
AS PER AS 5146.1	172

STANDARDS AUSTRALIA

Australian Standard Reinforced Autoclaved Aerated Concrete

Part 3: Construction

SECTION 1 SCOPE AND GENERAL

1.1 SCOPE

This Standard sets out requirements for construction using Reinforced Autoclaved Aerated Concrete (Reinforced AAC) members complying with AS 5146.1 and AS 5146.2, including associated fixings, flashings and control joints. This Standard does not cover the construction of structures consisting of unreinforced autoclaved aerated concrete blocks.

NOTES:

- 1 The term 'Reinforced AAC structures' refers to buildings that incorporate 'Reinforced AAC members', such as walls, floors, roofs, beams and the like made of Reinforced AAC. In this Standard, the term 'components' refers to items made from other materials, such as bolts, fixings, flashings and the like.
- 2 The forms of construction and detailing prescribed in Sections 2 and 3, together with Sections 4, 5, 6, 7 or 8 for the applications described therein, satisfy the requirements of AS 5146.1. However, they are not the only forms of construction or details capable of doing so. Other construction and details may be assessed separately for compliance with AS 5146.1.
- 3 This Standard should not be interpreted in a way that prevents the design and construction of structures that use alternative materials or methods of design or construction not specifically referred to herein. However, the design and construction of such structures are outside the scope of this Standard.
- 4 This Standard is based on the assumption that the design information is conveyed to the builders via comprehensive documentation such as drawings, details and specifications.

1.2 APPLICATION

For the applications stated herein, construction in accordance with this Standard satisfies the durability, fire resistance, serviceability, strength, stability and resistance to water penetration requirements of AS 5146.1 and AS 5146.2, and the Standards referenced therein.

Sections 4, 5, 6, 7 and 8 of this Standard provide details specific to durability, fire resistance, serviceability, strength, stability and resistance to water penetration requirements of Reinforced AAC members, and associated fixings, flashings and control joints, in all classes of building defined in the National Construction Code Volumes One and Two, except Class 10b and 10c structures.

The wind resistance of external walls provided in Section 3 are applicable only to buildings that incorporate a lining capable of resisting wind pressure exerted from inside the building, where the cavity between the lining and the cladding is sealed and where windows and doors in the external walls incorporate seals.