

Australian Standard<sup>®</sup>

---

**Fire hydrant installations**

**Part 1: System design, installation  
and commissioning**

---



This Australian Standard was prepared by Committee FP/9, Fire Hydrant Installations. It was approved on behalf of the Council of Standards Australia on 9 October 1991 and published on 16 December 1991.

---

The following interests are represented on Committee FP/9:

Australian Fire Protection Association  
Australian Uniform Building Regulations Coordinating Council  
N.S.W. Fire Brigade  
Board of Works, Melbourne  
Building Owners and Managers Association of Australia  
Bush Fire Council of New South Wales  
Commonwealth Fire Board  
Confederation of Australian Industry  
Department of Administrative Services  
Department of Defence  
Department of Transport and Communications  
Fire Protection Industry Association of Australia  
Institution of Engineers, Australia  
Insurance Council of Australia  
Metropolitan Fire Brigades Board, Melbourne  
Water Board Sydney-Illawarra-Blue Mountains  
Western Australian Fire Brigades Board

---

*Review of Australian Standards.* To keep abreast of progress in industry, Australian Standards are subject to periodic review and are kept up-to-date by the issue of amendments or new editions as necessary. It is important therefore that Standards users ensure that they are in possession of the latest edition, and any amendments thereto.

Full details of all Australian Standards and related publications will be found in the Standards Australia Catalogue of Publications; this information is supplemented each month by the magazine 'The Australian Standard', which subscribing members receive, and which gives details of new publications, new editions and amendments, and of withdrawn Standards.

Suggestions for improvements to Australian Standards, addressed to the head office of Standards Australia, are welcomed. Notification of any inaccuracy or ambiguity found in an Australian Standard should be made without delay in order that the matter may be investigated and appropriate action taken.

---

**Australian Standard®**

---

**Fire hydrant installations**

**Part 1: System design, installation  
and commissioning**

---

First published as AS 2419—1980.  
Revised and redesignated AS 2419.1—1988.  
Second edition 1991.

## PREFACE

This Standard was prepared by the Standards Australia Committee on Fire Hydrant Installations, to supersede AS 2419—1988.

The Standard specifies requirements for the installation within properties of fire hydrants which may, in certain cases, be supplemented by hydrants installed by water supply authorities on street mains.

The changes in this Standard include a revision and expansion of the requirements for hydrant system design and acceptable sources of water supply, water supply capacities, and general revisions to account for advances in technology for materials, methods of installation and firefighting requirements.

### © Copyright — STANDARDS AUSTRALIA

Users of Standards are reminded that copyright subsists in all Standards Australia publications and software. Except where the Copyright Act allows and except where provided for below no publications or software produced by Standards Australia may be reproduced, stored in a retrieval system in any form or transmitted by any means without prior permission in writing from Standards Australia. Permission may be conditional on an appropriate royalty payment. Requests for permission and information on commercial software royalties should be directed to the head office of Standards Australia.

Standards Australia will permit up to 10 percent of the technical content pages of a Standard to be copied for use exclusively in-house by purchasers of the Standard without payment of a royalty or advice to Standards Australia.

Standards Australia will also permit the inclusion of its copyright material in computer software programs for no royalty payment provided such programs are used exclusively in-house by the creators of the programs.

Care should be taken to ensure that material used is from the current edition of the Standard and that it is updated whenever the Standard is amended or revised. The number and date of the Standard should therefore be clearly identified.

The use of material in print form or in computer software programs to be used commercially, with or without payment, or in commercial contracts is subject to the payment of a royalty. This policy may be varied by Standards Australia at any time.

## CONTENTS

	<i>Page</i>
FOREWORD .....	5
<b>SECTION 1 SCOPE AND GENERAL</b>	
1.1 SCOPE .....	6
1.2 REFERENCED DOCUMENTS .....	6
1.3 DEFINITIONS .....	6
<b>SECTION 2 BASIC REQUIREMENTS</b>	
2.1 PROVISION OF HYDRANTS WITHIN PROPERTIES .....	8
2.2 TYPE OF SYSTEM .....	8
2.3 PLANS AND SPECIFICATIONS .....	8
2.4 QUALIFIED PERSONNEL .....	8
<b>SECTION 3 SOURCES OF WATER SUPPLY</b>	
3.1 SOURCES OF WATER SUPPLY .....	10
3.2 ACCEPTABLE SOURCE OF SUPPLY .....	10
3.3 COMBINED SYSTEMS .....	10
<b>SECTION 4 SYSTEM DESIGN</b>	
4.1 GENERAL .....	11
4.2 HYDRAULIC DESIGN .....	11
4.3 LOCATION OF HYDRANTS PROTECTING BUILDINGS .....	11
4.4 PIPEWORK DESIGN .....	13
4.5 REQUIRED SYSTEM PERFORMANCE .....	14
<b>SECTION 5 ANCILLARY EQUIPMENT</b>	
5.1 GENERAL .....	19
5.2 FIRE HOSE AND FITTINGS .....	19
5.3 CABINETS, ENCLOSURES OR RECESSES .....	19
5.4 PRESSURE GAUGES .....	22
5.5 PUMPED HYDRANT SYSTEMS .....	23
5.6 FIRE AUTHORITY BOOSTER CONNECTION .....	23
5.7 BOOSTERS IN SERIES (RELAY) WITH PUMPS .....	24
5.8 INTERNAL BOOSTER CONNECTION FOR PORTABLE RELAY PUMPS .....	25
<b>SECTION 6 PIPING, VALVES, AND FITTINGS</b>	
6.1 GENERAL .....	27
6.2 PIPE AND PIPE FITTING SPECIFICATIONS .....	27
6.3 SYSTEM PROTECTION AND IDENTIFICATION .....	27
6.4 PIPE JOINTS AND GASKETS .....	28
6.5 VALVES .....	28
6.6 ORIFICE PLATE .....	29
6.7 STRAINERS .....	29
6.8 SUPPORT OF HYDRANT PIPEWORK .....	29
6.9 THRUST BLOCKS AND ANCHORS .....	31
6.10 PRESSURE GAUGES .....	31
<b>SECTION 7 TESTING</b>	
7.1 GENERAL .....	34
7.2 HYDROSTATIC TESTS .....	34
7.3 COMMISSIONING TEST .....	34
7.4 SYSTEMS WHICH INCORPORATE A BOOSTER .....	34
7.5 SYSTEMS WITH BOOSTER IN SERIES (RELAY) .....	34
7.6 SYSTEMS WHICH INCORPORATE A PUMP .....	34
7.7 SYSTEMS WHICH INCORPORATE A TANK .....	34
7.8 RECORDING OF TEST RESULTS .....	35

	<i>Page</i>
<b>APPENDICES</b>	
<b>A</b> HYDRANT INSTALLATION WATER SUPPLY FLOW CHART ....	36
<b>B</b> SPECIAL HAZARDS ....	37
<b>C</b> LIST OF REFERENCED DOCUMENTS ....	38
<b>D</b> SYSTEM RESISTANCE CURVE FOR COMBINED HYDRANT AND SPRINKLER SYSTEMS ....	39
<b>E</b> WATER SUPPLY RELIABILITY ....	40
<b>COMMENTARY GUIDE TO THE USE OF THIS STANDARD</b> ....	42

## FOREWORD

The purpose of this Standard is to specify a hydrant system which is compatible with the needs of today's fire authorities to extinguish more efficiently the outbreak of fire within premises.

The availability of hydrants is essential to fire protection. Hydrants may be used to quell an initial outbreak of fire, quench a dying fire controlled by an automatic protection system, or provide the sole firefighting facility, e.g. after other means have been unsuccessful.

Although hydrants are installed within properties for use by the fire authority, they may also be used by trained personnel.

An adequate source of water is a fundamental consideration in the design of a fire hydrant installation. This supply must be available at all times, but may comprise water from more than one source. A source based on a 4 h duration at the flow rates given in this Standard is regarded as the minimum safe quantity to enable fire brigades to extinguish a major fire and, if necessary, protect neighbouring properties.

Hydrant systems should also be regularly inspected, tested, and maintained to ensure continued readiness for use. Where pumpsets are installed, regular maintenance is essential.

## STANDARDS AUSTRALIA

**Australian Standard**  
**Fire hydrant installations**

**Part 1: System design, installation, and commissioning**

**SECTION 1 SCOPE AND GENERAL**

**1.1 SCOPE** This Standard sets out requirements for the design, installation, and commissioning of fire hydrant systems within properties.

NOTE: A commentary written in an advisory manner has been added to this Standard and includes charts for fire nozzle discharge calculations and pressure losses in fire hose. Appendix A sets out a flow chart for water supply system design, and Appendix B provides guidance on fire hydrant installations for special hazards.

Requirements for maintenance of fire hydrant installations are given in AS 1851.4.

**1.2 REFERENCED DOCUMENTS** A list of the documents referred to in this Standard is given in Appendix C.

**1.3 DEFINITIONS** For the purpose of this Standard, the definitions below apply.

**1.3.1 Approved and approval**—approved by, or the approval of, a regulatory authority.

**1.3.2 Block plan**—a plan of the risk clearly indicating the as-constructed location of all mains, isolating valves and hydrants.

**1.3.3 Design pressure**—the working pressure plus any increase in pressures incurred when the hydrant is closed, e.g. pump running no-flow condition.

**1.3.4 Fire brigade booster connection**—a connecting device enabling the fire brigade to pressurize or pump water into a fire hydrant system.

**1.3.5 Fire compartment**—a volume which is enclosed by a fire-rated construction.

**1.3.6 Fire hydrant**—an assembly installed in a water pipeline which provides a valved outlet to permit a controlled supply of water to be taken from the pipeline for firefighting.

**1.3.7 Fire-resistance level (FRL)**—the fire-resistance rating periods in minutes, determined for—

- (a) structural adequacy,
- (b) integrity, and
- (c) insulation,

expressed in that order, i.e. FRL XX/ YY/ ZZ.

**1.3.8 High-rise installation**—a fire hydrant installation in a building where the floor of the topmost storey, excluding a storey containing only heating, ventilation, lifts, water tanks, or similar service equipment, is more than 25 m above the floor of the lowest storey providing egress by a normal route to a road or open area.

**1.3.9 Hydrant valve**—a valve controlling flow of water from the fire hydrant outlet with provision for attachment of a fire hose.

**1.3.10 Low-rise installation**—a fire hydrant installation in a single or multistorey building other than a high-rise structure.

**1.3.11 Regulatory authority**—a Minister of the Crown, a government department or other public authority having power to issue regulations, orders, or other instructions having the force of law in respect of any subject covered by this Standard.

NOTE: There may be one or more regulatory authorities for any particular installation, or even for some aspect of it. Fire authorities have the necessary expertise to assist the regulatory authority in interpreting and applying the requirements of this Standard.

**1.3.12 Relay**—a firefighting term to denote that pumps are connected in series.

**1.3.13 Residual pressure**—water pressure available at a hydrant outlet at a particular flow rate.

**1.3.14 Suction connection**—a large diameter connection often used on water supply tanks where the residual pressure is within the range of  $-30$  kPa and 150 kPa.

**1.3.15 Test pressure**—not less than 1700 kPa or 1.5 times the design pressure, whichever is the greater.