

Australian/New Zealand Standard™

Electromagnetic compatibility (EMC)

**Part 4.8: Testing and measurement
techniques—Power frequency magnetic
field immunity test**



AS/NZS 61000.4.8:2012

This Joint Australian/New Zealand Standard was prepared by Joint Technical Committee EL-034, Power Quality. It was approved on behalf of the Council of Standards Australia on 4 May 2012 and on behalf of the Council of Standards New Zealand on 26 April 2012.

This Standard was published on 22 May 2012.

The following are represented on Committee EL-034:

Australian Chamber of Commerce and Industry
Australian Industry Group
Australian Information Industry Association
Bureau of Steel Manufacturers of Australia
Consumer Electronics Suppliers Association
Consumers Federation of Australia
Electrical Regulatory Authorities Council
Electricity Engineers Association, New Zealand
Energy Networks Association
Engineers Australia
Lighting Council of Australia
Ministry of Economic Development, New Zealand
National Measurement Institute
New Zealand Coordinating Committee on Power & Telecommunication Systems
New Zealand Electric Fence Energiser Manufacturers Standards WG
Telstra Corporation
University of Canterbury, New Zealand
University of Wollongong

Keeping Standards up-to-date

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about joint Australian/New Zealand Standards can be found by visiting the Standards Web Shop at www.saiglobal.com.au or Standards New Zealand web site at www.standards.co.nz and looking up the relevant Standard in the on-line catalogue.

For more frequent listings or notification of revisions, amendments and withdrawals, Standards Australia and Standards New Zealand offer a number of update options. For information about these services, users should contact their respective national Standards organization.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Please address your comments to the Chief Executive of either Standards Australia or Standards New Zealand at the address shown on the back cover.

This Standard was issued in draft form for comment as DR AS/NZS 61000.4.8.

Australian/New Zealand Standard™

Electromagnetic compatibility (EMC)

Part 4.8: Testing and measurement techniques—Power frequency magnetic field immunity test

Originated as AS/NZS 61000.4.8:2002.
Second edition 2012.

COPYRIGHT

© Standards Australia Limited/Standards New Zealand

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher, unless otherwise permitted under the Copyright Act 1968 (Australia) or the Copyright Act 1994 (New Zealand).

Jointly published by SAI Global Limited under licence from Standards Australia Limited, GPO Box 476, Sydney, NSW 2001 and by Standards New Zealand, Private Bag 2439, Wellington 6140

PREFACE

This Standard was prepared by the Joint Standards Australia/Standards New Zealand Committee EL-034, Power Quality, to supersede AS/NZS 61000.4.8:2002, *Electromagnetic compatibility (EMC)—Part 4.8: Testing and measurement techniques—Power frequency magnetic field immunity test*.

The objective of this Standard is to determine the immunity requirements of equipment, only under operational conditions, to magnetic disturbances at power frequency related to residential and commercial locations, industrial installations and power plants, and medium voltage and high voltage sub-stations.

This Standard is identical with, and has been reproduced from IEC 61000-4-8, Ed.2.0 (2009), *Electromagnetic compatibility (EMC)—Part 4-8: Testing and measurement techniques—Power frequency magnetic field immunity test*.

As this Standard is reproduced from an International Standard, the following applies:

- (a) Its number appears on the cover and title page while the International Standard number appears only on the cover.
- (b) In the source text ‘this part of IEC 61000’ should read ‘this part of AS/NZS 61000’.
- (c) A full point substitutes for a comma when referring to a decimal marker.

None of the normative references in the source document have been adopted as Australian or Australian/New Zealand Standards.

The terms ‘normative’ and ‘informative’ have been used in this Standard to define the application of the annex to which they apply. A ‘normative’ annex is an integral part of a Standard, whereas an ‘informative’ annex is only for information and guidance.

CONTENTS

| | | |
|-------|---|----|
| 1 | Scope..... | 7 |
| 2 | Normative references | 7 |
| 3 | Terms and definitions | 7 |
| 4 | General | 8 |
| 5 | Test levels..... | 9 |
| 6 | Test equipment..... | 10 |
| 6.1 | General | 10 |
| 6.2 | Test generator..... | 10 |
| 6.2.1 | Current source..... | 10 |
| 6.2.2 | Characteristics and performances of the test generator for different inductive coils..... | 10 |
| 6.2.3 | Verification of the characteristics of the test generator | 11 |
| 6.3 | Inductive coil | 12 |
| 6.3.1 | Field distribution | 12 |
| 6.3.2 | Characteristics of the inductive standard coils 1 m × 1 m and 1 m × 2,6 m | 12 |
| 6.3.3 | Characteristics of the inductive coils for table top and floor standing equipment | 12 |
| 6.3.4 | Measurement of the inductive coil factor..... | 13 |
| 6.4 | Test and auxiliary instrumentation | 13 |
| 6.4.1 | Test instrumentation | 13 |
| 6.4.2 | Auxiliary instrumentation | 14 |
| 7 | Test set-up | 14 |
| 7.1 | Test set-up components | 14 |
| 7.2 | Ground (reference) plane for floor standing equipment..... | 14 |
| 7.3 | Equipment under test | 14 |
| 7.4 | Test generator..... | 15 |
| 7.5 | Inductive coil | 15 |
| 8 | Test procedure | 15 |
| 8.1 | General..... | 15 |
| 8.2 | Laboratory reference conditions | 15 |
| 8.2.1 | General | 15 |
| 8.2.2 | Climatic conditions | 15 |
| 8.2.3 | Electromagnetic conditions..... | 16 |
| 8.3 | Carrying out the test..... | 16 |
| 9 | Evaluation of the test results | 17 |
| 10 | Test report..... | 17 |
| | Annex A (normative) Inductive coil calibration method | 22 |
| | Annex B (normative) Characteristics of the inductive coils | 23 |
| | Annex C (informative) Selection of the test levels | 29 |
| | Annex D (informative) Information on power frequency magnetic field strength | 31 |
| | Bibliography..... | 33 |

| | |
|---|----|
| Figure 1 – Example of application of the test field by the immersion method | 18 |
| Figure 2 – Example of schematic circuit of the test generator for power frequency magnetic field | 18 |
| Figure 3 – Example of test set-up for table-top equipment | 19 |
| Figure 4 – Calibration of the standard coils | 19 |
| Figure 5 – Example of test set-up for floor-standing equipment..... | 20 |
| Figure 6 – Example of investigation of susceptibility to magnetic field by the proximity method with the 1 m × 1 m inductive coil | 20 |
| Figure 7 – Illustration of Helmholtz coils | 21 |
| Figure B.1 – Characteristics of the field generated by a square inductive coil (1 m side) in its plane | 25 |
| Figure B.2 – 3 dB area of the field generated by a square inductive coil (1 m side) in its plane | 25 |
| Figure B.3 – 3 dB area of the field generated by a square inductive coil (1 m side) in the mean orthogonal plane (component orthogonal to the plane of the coil) | 26 |
| Figure B.4 – 3 dB area of the field generated by two square inductive coils (1 m side) 0,6 m spaced, in the mean orthogonal plane (component orthogonal to the plane of the coils)..... | 26 |
| Figure B.5 – 3 dB area of the field generated by two square inductive coils (1 m side) 0,8 m spaced, in the mean orthogonal plane (component orthogonal to the plane of the coils)..... | 27 |
| Figure B.6 – 3 dB area of the field generated by a rectangular inductive coil (1 m × 2,6 m) in its plane | 27 |
| Figure B.7 – 3 dB area of the field generated by a rectangular inductive coil (1 m × 2,6 m) in its plane (ground plane as a side of the inductive coil) | 28 |
| Figure B.8 – 3 dB area of the field generated by a rectangular inductive coil (1 m × 2,6 m) with ground plane, in the mean orthogonal plane (component orthogonal to the plane of the coil) | 28 |
| Table 1 – Test levels for continuous field | 9 |
| Table 2 – Test levels for short duration: 1 s to 3 s..... | 10 |
| Table 3 – Specification of the generator for different inductive coils | 11 |
| Table 4 – Verification parameter for the different inductive coils | 11 |
| Table D.1 – Values of the maximum magnetic field produced by household appliances (results of the measurements of 100 different devices of 25 basic types) | 31 |
| Table D.2 – Values of the magnetic field generated by a 400 kV line | 31 |
| Table D.3 – Values of the magnetic field in high voltage sub-station areas | 32 |
| Table D.4 – Values of the magnetic field in power plants | 32 |

FOREWORD

This edition includes the following significant technical changes with respect to the previous edition: the scope is extended in order to cover 60 Hz. Characteristics, performance and verification of the test generator and related inductive coils are revised. Modifications are also introduced in the test set-up (GRP) and test procedure.

Electromagnetic compatibility (EMC)

Part 4.8:

Testing and measurement techniques—Power frequency magnetic field immunity test

1 Scope

This part of IEC 61000 relates to the immunity requirements of equipment, only under operational conditions, to magnetic disturbances at power frequencies 50 Hz and 60 Hz related to:

- residential and commercial locations;
- industrial installations and power plants;
- medium voltage and high voltage sub-stations.

The applicability of this standard to equipment installed in different locations is determined by the presence of the phenomenon, as specified in Clause 4. This standard does not consider disturbances due to capacitive or inductive coupling in cables or other parts of the field installation.

Other IEC standards dealing with conducted disturbances cover these aspects.

The object of this standard is to establish a common and reproducible basis for evaluating the performance of electrical and electronic equipment for household, commercial and industrial applications when subjected to magnetic fields at power frequency (*continuous and short duration field*).

The standard defines:

- recommended test levels;
- test equipment;
- test set-up;
- test procedure.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60050(161), *International Electrotechnical Vocabulary (IEV) – Chapter 161: Electromagnetic compatibility*

3 Terms and definitions

For the purposes of this document the following terms and definitions apply to the restricted field of magnetic disturbances as well as the terms and definitions from IEC 60050(161) [IEV].

3.1

current distortion factor

ratio of the root-mean square value of the harmonics content of an alternating current to the root-mean square value of the fundamental current