

Australian Standard™

Programmable controllers

Part 1: General information

This Australian Standard was prepared by Committee IT-006, Information Technology for Industrial Automation. It was approved on behalf of the Council of Standards Australia on 15 January 2004 and published on 22 March 2004.

The following are represented on Committee IT-006:

Association of Consulting Engineers Australia
Australian Electrical and Electronic Manufacturers Association
CSIRO Centre for Planning and Design
CSIRO Manufacturing and Infrastructure Technology
Department of Defence, Australia
Institute of Instrumentation, Control and Automation Australia
Institution of Engineers Australia
Monash University
RMIT University
University of Melbourne

Keeping Standards up-to-date

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about Standards can be found by visiting the Standards Web Shop at www.standards.com.au and looking up the relevant Standard in the on-line catalogue.

Alternatively, the printed Catalogue provides information current at 1 January each year, and the monthly magazine, *The Global Standard*, has a full listing of revisions and amendments published each month.

Australian Standards™ and other products and services developed by Standards Australia are published and distributed under contract by SAI Global, which operates the Standards Web Shop.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Contact us via email at mail@standards.org.au, or write to the Chief Executive, Standards Australia International Ltd, GPO Box 5420, Sydney, NSW 2001.

This Standard was issued in draft form for comment as DR 03587.

Australian Standard™

Programmable controllers

Part 1: General information

Originated as AS 4168.1—1994.
Revised and redesignated as AS IEC 61131.1—2004.

COPYRIGHT

© Standards Australia International

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher.

Published by Standards Australia International Ltd
GPO Box 5420, Sydney, NSW 2001, Australia

ISBN 0 7337 5770 7

PREFACE

This Standard was prepared by the Standards Australia Committee IT-006, Information Technology for Industrial Automation to supersede AS 4168.1-1994, *Programmable controllers*, Part 1: *General information*.

This Standard is identical with, and has been reproduced from, IEC 61131-1:2003, *Programmable controllers—Part 1: General information*.

The objective of this Standard is to establish the definitions and identify the principal characteristics relevant to the selection and application of programmable controllers and their associated peripherals.

Minor editorial corrections have been made to Clause 4.6.4.

This Standard is Part 1 of AS IEC 61131 *Programmable controllers*, which consists of the following:

Part 1: General information (this Standard)

Part 2: Equipment requirements and tests

Part 3: Programming languages

Part 4: User guidelines

Part 5: Communications

Part 7: Fuzzy control programming

Part 8: Guidelines for the application and implementation of programming languages

AS IEC 61131 does not have a Part 6. A project to develop IEC 61131-6 *Programmable controller communications via field bus* was deleted in September 2000 by the IEC.

In this Standard, the following print types are used:

- requirements proper: in arial type;
- *test specifications: in italic type;*
- explanatory matter: in smaller arial type.

As this Standard is reproduced from an International Standard, the following applies:

- (a) Its number does not appear on each page of text and its identity is shown only on the cover and title page.
- (b) In the source text ‘this part of IEC 61131’ should read ‘this part of AS IEC 61131’.
- (c) A full point should be substituted for a comma when referring to a decimal marker.

CONTENTS

| | <i>Page</i> |
|---|-------------|
| INTRODUCTION | iv |
| 1 Scope | 1 |
| 2 Normative references | 1 |
| 3 Terms and definitions | 2 |
| 4 Functional characteristics..... | 3 |
| 4.1 Basic functional structure of a programmable controller system | 3 |
| 4.2 Characteristics of the CPU function..... | 6 |
| 4.3 Characteristics of the interface function to sensors and actuators | 8 |
| 4.4 Characteristics of the communication function | 9 |
| 4.5 Characteristics of the human-machine interface (HMI) function | 9 |
| 4.6 Characteristics of the programming, debugging, monitoring, testing and documentation functions | 9 |
| 4.7 Characteristics of the power-supply functions | 11 |
| 5 Availability and reliability..... | 12 |
| | |
| Bibliography | 13 |
| | |
| Figure 1 – Basic functional structure of a PLC-system | 3 |
| Figure 2 – Programmable controller hardware model (from IEC 61131-5) | 4 |
| Figure 3 – Typical interface/port diagram of a PLC-system (from IEC 61131-2) | 5 |
| | |
| Table 1 – Summary of programmable functions | 7 |

INTRODUCTION

This Part of IEC 61131 constitutes Part 1 of a series of standards on programmable controllers and their associated peripherals and should be read in conjunction with the other parts of the series.

Where a conflict exists between this and other IEC standards (except basic safety standards), the provisions of this standard should be considered to govern in the area of programmable controllers and their associated peripherals.

The purposes of this standard are:

Part 1 establishes the definitions and identifies the principal characteristics relevant to the selection and application of programmable controllers and their associated peripherals;

Part 2 specifies equipment requirements and related tests for programmable controllers (PLC) and their associated peripherals;

Part 3 defines, for each of the most commonly used programming languages, major fields of application, syntactic and semantic rules, simple but complete basic sets of programming elements, applicable tests and means by which manufacturers may expand or adapt those basic sets to their own programmable controller implementations;

Part 4 gives general overview information and application guidelines of the standard for the PLC end-user;

Part 5 defines the communication between programmable controllers and other electronic systems;

Part 6 is reserved;

Part 7 defines the programming language for fuzzy control;

Part 8 gives guidelines for the application and implementation of the programming languages defined in Part 3.

STANDARDS AUSTRALIA

Australian Standard**Programmable controllers
Part 1: General information**

1 Scope

This Part of IEC 61131 applies to programmable controllers (PLC) and their associated peripherals such as programming and debugging tools (PADTs), human-machine interfaces (HMIs), etc., which have as their intended use the control and command of machines and industrial processes.

PLCs and their associated peripherals are intended to be used in an industrial environment and may be provided as open or enclosed equipment. If a PLC or its associated peripherals are intended for use in other environments, then the specific requirements, standards and installation practices for those other environments must be additionally applied to the PLC and its associated peripherals.

The functionality of a programmable controller can be performed as well on a specific hardware and software platform as on a general-purpose computer or a personal computer with industrial environment features. This standard applies to any products performing the function of PLCs and/or their associated peripherals. This standard does not deal with the functional safety or other aspects of the overall automated system. PLCs, their application programme and their associated peripherals are considered as components of a control system.

Since PLCs are component devices, safety considerations for the overall automated system including installation and application are beyond the scope of this Part. However, PLC safety as related to electric shock and fire hazards, electrical interference immunity and error detecting of the PLC-system operation (such as the use of parity checking, self-testing diagnostics, etc.), are addressed. Refer to IEC 60364 or applicable national/local regulations for electrical installation and guidelines.

This Part of IEC 61131 gives the definitions of terms used in this standard. It identifies the principal functional characteristics of programmable controller systems.

2 Normative references

References to international standards that are struck through in this clause are replaced by references to Australian or Australian/New Zealand Standards that are listed immediately thereafter and identified by shading. Any Australian or Australian/New Zealand Standard that is identical to the International Standard it replaces is identified as such.

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

~~IEC 61131-2, Programmable controllers — Part 2: Equipment requirements and tests~~