AS/NZS 1026:2004
Reconfirmed 2017

Australian/New Zealand Standard™

Electric cables—Impregnated paper insulated—For working voltages up to and including 19/33 (36) kV

STANDARDS AUSTRALIA

STANDARDS NEW ZEALAND
Paerewa Aotearoa

This Joint Australian/New Zealand Standard was prepared by Joint Technical Committee EL-003, Electric Wires and Cables. It was approved on behalf of the Council of Standards Australia on 13 February 2004 and on behalf of the Council of Standards New Zealand on 5 March 2004. It was published on 29 April 2004.

The following are represented on Committee EL-003:

Australasian Railway Association
Australian Electrical and Electronic Manufacturers Association
Australian Industry Group
Canterbury Manufacturers Association, New Zealand
Department of Defence (Australia)
Department of Mineral Resources N.S.W.
Electrical Contractors Association of New Zealand
Electrical Regulatory Authorities Council
Electricity Supply Association of Australia
Institution of Engineers Australia
Ministry of Economic Development (New Zealand)
National Electrical and Communications Association

Keeping Standards up-to-date

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about joint Australian/New Zealand Standards can be found by visiting the Standards Web Shop at www.standards.com.au or Standards New Zealand web site at www.standards.co.nz and looking up the relevant Standard in the on-line catalogue.

Alternatively, both organizations publish an annual printed Catalogue with full details of all current Standards. For more frequent listings or notification of revisions, amendments and withdrawals, Standards Australia and Standards New Zealand offer a number of update options. For information about these services, users should contact their respective national Standards organization.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Please address your comments to the Chief Executive of either Standards Australia International or Standards New Zealand at the address shown on the back cover.

This Standard was issued in draft form for comment as DR 02316.

STANDARDS AUSTRALIA/STANDARDS NEW ZEALAND

RECONFIRMATION

OF
AS/NZS 1026:2004
Electric cables—Impregnated paper insulated—For working voltages up to and including 19/33 (36) kV

RECONFIRMATION NOTICE

Technical Committee EL-003 has reviewed the content of this publication and in accordance with Standards Australia procedures for reconfirmation, it has been determined that the publication is still valid and does not require change.

Certain documents referenced in the publication may have been amended since the original date of publication. Users are advised to ensure that they are using the latest versions of such documents as appropriate, unless advised otherwise in this Reconfirmation Notice.

Approved for reconfirmation in accordance with Standards Australia procedures for reconfirmation on 10 October 2016.

Approved for reconfirmation in New Zealand on behalf of the Standards Council of New Zealand on 13 December 2016.

The following are represented on Technical Committee EL-003:

Australian Cable Makers' Association
Australian Industry Group
Electrical Compliance Testing Association
Electrical Regulatory Authorities Council
National Electrical and Communications Association
Queensland University of Technology

NOTES

Australian/New Zealand Standard™

Electric cables—Impregnated paper insulated—For working voltages up to and including 19/33 (36) kV

Originated as AS C92—1941.
Previous edition AS 1026—1992.
Jointly revised and designated as AS/NZS 1026:2004.

Jointly published by Standards Australia International Ltd, GPO Box 5420, Sydney, NSW 2001 and Standards New Zealand, Private Bag 2439, Wellington 6020

ISBN 0 7337 5884 3

PREFACE

This Standard was prepared by the Joint Standards Australia/Standards New Zealand Committee, EL-003 Electric Wires and Cables to supersede AS 1026—1992 and NZS/AS 1026—1992, *Electric cables—Impregnated paper insulated—Working voltages up to and including 33 kV*.

The objective of this Standard is to specify the construction, dimensions and tests for paper insulated and lead alloy sheathed cables for working voltages up to and including 19/33 (36) kV.

In the preparation of this Standard, consideration was given to IEC 60055-1, *Paper-insulated metal-sheathed cables for rated voltages up to 18/30 kV (with copper or aluminium conductors and excluding gas-pressure and oil-filled cables)* Part 1: *Tests on cables and their accessories*, IEC 60055-2, *Paper-insulated metal-sheathed cables for rated voltages up to 18/30 kV (with copper or aluminium conductors and excluding gas-pressure and oil-filled cables)* Part 2: *General and construction requirements*, and BS 6480, *Impregnated paper-insulated lead or lead alloy sheathed electric cables of rated voltage up to and including 33 000 V*. The Standards Australia/Standards New Zealand Committee concurs with the comment in the Foreword of BS 6480 that, because of different local and regional requirements, it has not been possible to adopt the IEC Publication as a national Standard. Consequently, the construction and voltage ratings of cables in the Australian/New Zealand Standard have not been changed from the previous edition and are identical with corresponding cables in BS 6480.

Acknowledgment is made of the content extracted from BS 6480 and IEC 60055.

This Standard differs from the 1992 edition in the following significant ways:

(a) The Standard is published as a Joint Australian/New Zealand Standard.

(b) 0.6/1 (1.2) kV single-core, two-core and three-core cable constructions and all 1.9/3.3 (3.6) kV cable constructions have been deleted.

(c) Bedding and armour have been designated as optional processes.

(d) PE and LLDPE have been included as additional extruded bedding and non-metallic sheathing materials.

(e) Extruded bedding and non-metallic sheathing materials have been referenced to AS/NZS 3808.

(f) An internal cable pressure test has been included.

The terms ‘normative’ and ‘informative’ have been used in this Standard to define the application of the appendix to which they apply. A ‘normative’ appendix is an integral part of a Standard, whereas an ‘informative’ appendix is only for information and guidance.

CONTENTS

Page

1 SCOPE 4
2 REFERENCED DOCUMENTS 4
3 DEFINITIONS 5
4 OPERATING VOLTAGES 6
5 MAXIMUM CONDUCTOR TEMPERATURES 6
6 CONDUCTORS 7
7 CONDUCTOR SCREEN 8
8 INSULATION 9
9 CORE IDENTIFICATION 9
10 INSULATION SCREEN 9
11 LAYING UP 10
12 IMPREGNATION 10
13 LEAD ALLOY SHEATH 11
14 BEDDING (OPTIONAL) 11
15 ARMOUR (OPTIONAL) 12
16 NON-METALLIC SHEATH OR SERVING 12
17 COMPOUNDS FOR LAPPED BEDDING AND SERVING 13
18 CABLE MARKINGS 13
19 SEALING AND PREPARATION FOR DELIVERY 14
20 TESTS 14

APPENDICES

A RECOMMENDATIONS FOR SELECTION AND OPERATION 35
B RECOMMENDATIONS FOR INSTALLATION 39
C PURCHASING GUIDELINES 41
D SAMPLE TEST SAMPLE SELECTION AND RETEST PROCEDURE 42
E DETERMINATION OF THICKNESS OF LEAD ALLOY SHEATH AND EXTRUDED BEDDING 43
F METHOD OF TEST FOR WATER-SOLUBLE IMPURITIES IN INSULATING PAPER 44
G TYPE TESTS FOR 19/33 (36) kV CABLES 45
H INTERNAL PRESSURE TEST METHOD 48

STANDARDS AUSTRALIA/STANDARDS NEW ZEALAND

Australian/New Zealand Standard

Electric cables—Impregnated paper insulated—For working voltages up to and including 19/33 (36) kV

1 SCOPE

This Standard specifies requirements for non-draining mass-impregnated paper insulated and lead alloy sheathed cables for working voltage up to and including 19/33 (36) kV. Provision is made for extruded or lapped non-metallic protective coverings over the lead alloy sheath, with or without galvanized steel wire armour. Some typical constructions are shown in Figure 1.

NOTES:

1 Recommendations for selection and operation are given in Appendix A and those for installation are given in Appendix B.

2 Purchasing guidelines are provided in Appendix C.

The following cables are included in this Standard:

(a) 0.6/1 (1.2) kV four-core.

(b) 3.8/6.6 (7.2) kV single-core and three-core belted construction.

(c) 6.35/11 (12) and 11/11 (12) kV single-core and three-core belted or screened construction.

(d) 12.7/22 (24) kV and 19/33 (36) kV single-core and three-core screened or three-core separately leaded (SL).

2 REFERENCED DOCUMENTS

The following documents are referred to in this Standard:

AS		
1931	High voltage testing techniques	
1931.1	Part 1:	General definitions and test requirements
1931.2	Part 2:	Measuring systems
3983	Metal drums for insulated electric cables and bare conductors	
AS/NZS		
1125	Conductors in insulated electric cables and flexible cords	
1660	Test methods for electric cables, cords and conductors	
1660.1	Method 1:	Conductors and metallic components
1660.2.1	Method 2.1:	Insulation, extruded semi-conductive screens and non-metallic sheaths—Methods for general application
1660.3	Method 3:	Electrical tests
2857	Timber drums for insulated electric cables and bare conductors	
2893	Electric cables—Lead and lead alloy sheaths—Composition	
3008	Electric installations—Selection of cables	
3008.1	Part 1:	Cables for alternating voltages up to and including 0.6/1 kV
3808	Insulating and sheathing materials for electric cables	