

Australian Standard[®] 2021—1985

ACOUSTICS—AIRCRAFT NOISE INTRUSION—BUILDING SITING AND CONSTRUCTION

For referenced documents see Appendices A + G



STANDARDS ASSOCIATION OF AUSTRALIA

Incorporated by Royal Charter



This Australian standard was prepared by Committee AK/4, Architectural Acoustics. It was approved on behalf of the Council of the Standards Association of Australia on 1 October 1985 and published on 4 November 1985.

The following interests are represented on Committee AK/4:

Association of Australian Acoustical Consultants
Australian Acoustical Society
Confederation of Australian Industry
CSIRO, Division of Building Research
Department of Employment and Industrial Relations
Department of Housing and Construction
Institution of Engineers Australia
Public Works Department, N.S.W.
Public Works Department, W.A.
Royal Australian Institute of Architects
Royal Melbourne Institute of Technology
State Pollution Control Commission, N.S.W.
University of Adelaide
University of Sydney

Representatives of the following interests also participated in the drafting of this Australian standard:

Department of Aviation
Environment Protection Authority, Victoria

Review of Australian Standards. To keep abreast of progress in industry, Australian standards are subject to periodic review and are kept up-to-date by the issue of amendments or new editions as necessary. It is important therefore that standards users ensure that they are in possession of the latest edition, and any amendments thereto.

Full details of all SAA publications will be found in the Catalogue of SAA Publications; this information is supplemented each month by SAA's journal 'The Australian Standard', which subscribing members receive, and which gives details of new publications, new editions and amendments, and of withdrawn standards.

Suggestions for improvements to Australian standards, addressed to the head office of the Association, are welcomed. Notification of any inaccuracy or ambiguity found in an Australian standard should be made without delay in order that the matter may be investigated and appropriate action taken.

This standard was issued in draft form for comment as DR 84239. ✓

AUSTRALIAN STANDARD

ACOUSTICS—AIRCRAFT NOISE INTRUSION—BUILDING SITING AND CONSTRUCTION

AS 2021—1985

First published	1977
Second edition	1985

**PUBLISHED BY THE STANDARDS ASSOCIATION OF AUSTRALIA
STANDARDS HOUSE, 80 ARTHUR ST, NORTH SYDNEY, N.S.W.**

ISBN 0 7262 3956 9



PREFACE

This edition of this standard was prepared by the subcommittee on Building Siting and Construction Against Aircraft Noise Intrusion of the Association's Committee on Architectural Acoustics, to supersede AS 2021—1977, Code of Practice for Building Siting and Construction Against Aircraft Noise Intrusion. It provides guidance to regional and local authorities, organizations and others associated with urban and regional planning and building production on the location and construction of new buildings and on the acoustical adequacy of existing buildings in areas near airports.

The extent of aircraft noise intrusion within a building depends substantially on—

- (a) the location and orientation of the site relative to the direction of the airport's runway(s);
- (b) the type(s) of activity to be, or being, accommodated in the building(s); and
- (c) the type(s) of layout, construction and ventilation utilized.

This standard includes guidelines for the assessment of potential aircraft noise exposure at a given site, which are based on the Australian Noise Exposure Forecast (ANEF) system (for details of this system refer to Appendix B) which now replaces the NEF system used in the previous edition of this standard. It also incorporates expanded aircraft noise tables and various associated amendments to the text.

Although most of the ANEF data currently available have been estimated for 1990 or 1995, it is necessary for the purposes of this standard to use noise level data from aircraft operating in Australia in 1985. These data, contained in the Aircraft Noise Level Tables (Tables 3.4 to 3.19), are based on actual measurement and are the arithmetic averages of the maximum levels emitted by the aircraft currently operating, taken over a large number of movements. The data will be amended as new aircraft are commissioned, and as otherwise necessary. This standard deals specifically with noise from take-off and landing operations at civil airports or military air bases.

Exposure prediction below 25 ANEF may be significantly inaccurate, and therefore caution should be exercised in the evaluating of locations outside the 25 ANEF contour. In addition, the extent of noise reduction required for a building will depend in part on the amount of noise from sources other than aircraft. Because of these factors and of the special acoustic requirements of certain types of building, it will sometimes be necessary to undertake supplementary noise measurements so that a sufficiently representative prediction of the noise exposure at the site under evaluation can be obtained. This is also true for aerodromes at which a significant amount of training circuits occur. Such measurements should be performed only by acoustically qualified personnel.

Human reaction to aircraft noise is known to depend not only on the amount of noise, but also on psychosocial factors such as personal sensitivity to noise, fear of aircraft crashing and attitudes towards aviation. Thus some individuals will be seriously disturbed by aircraft noise even when the building is sited and constructed according to this standard.

An example of the application of this standard is given in Appendix E.

© Copyright — STANDARDS ASSOCIATION OF AUSTRALIA 1985

Users of standards are reminded that copyright subsists in all SAA publications. No part of this publication may be reproduced, stored in a retrieval system in any form or transmitted by any means without prior permission in writing of the Standards Association of Australia.

CONTENTS

	<i>Page</i>
SECTION 1. SCOPE AND GENERAL	
1.1 Scope	4
1.2 Application	4
1.3 Referenced Documents	4
1.4 Definitions	4
SECTION 2. BUILDING SITING AGAINST AIRCRAFT NOISE INTRUSION	
2.1 Determination of Noise Exposure of Building Site	6
2.2 Determination of Building Site Acceptability	6
2.3 Action Resulting From Acceptability Determination	6
SECTION 3. BUILDING CONSTRUCTION AGAINST AIRCRAFT NOISE INTRUSION	
3.1 Aircraft Noise Level	7
3.2 Noise Reduction Requirements	8
3.3 Construction Requirements	8
APPENDICES	
A Guide to Sound Transmission Data of Building Components	29
B Australian Noise Exposure Forecast System	35
C Direct Computation of ANA_c	39
D Calculation of Errors Due to Different Angles of Irradiation	40
E Example of Application of this Standard	42
F Method for Determining Building Site Acceptability for Airports Without ANEF Maps	44
G References	45

STANDARDS ASSOCIATION OF AUSTRALIA

Australian Standard
for

ACOUSTICS—AIRCRAFT NOISE INTRUSION—BUILDING SITING AND CONSTRUCTION

SECTION 1. SCOPE AND GENERAL

1.1 SCOPE. This standard, together with the most appropriate Australian Noise Exposure Forecast (ANEF) plan or locality map available for the airport under consideration, provides guidelines for determining—

- (a) whether the extent of aircraft noise intrusion makes indoor spaces unacceptable for the activities to be, or being, accommodated;
- (b) the extent of noise reduction required to provide acceptable noise levels indoors for the types of activity to be, or being, accommodated; and
- (c) the type of building construction necessary to provide the noise reduction required, provided that windows and doors are closed (see Note 1).

The acceptability of outdoor spaces is not covered by this standard.

NOTES:

1. The recommendations for building construction are based on the assumption that windows and doors are shut. If windows or doors are opened for ventilation or other purposes, the noise attenuation values for various components given in Clause 3.3 will not be achieved. Paragraph (c) above implies that mechanical ventilation must be installed when windows and doors are shut to provide adequate protection against aircraft noise intrusion. Whether or not sufficient ventilation can be achieved by mechanical or other means should be considered before the selection of building components described in Clause 3.3.
2. In certain circumstances it may be necessary to construct or upgrade buildings on sites that would normally be classed as unacceptable, e.g. a hotel in the immediate vicinity of an airport. However, the type of construction necessary to obtain an acceptable acoustic environment inside such buildings falls outside the scope of this standard and specialist acoustic advice should always be obtained.

1.2 APPLICATION. Application of this standard should be considered when a building site is located within certain distances from an airport as given below; however, these distances should be used as guidelines only, to indicate when the recommendations contained in this standard may be applicable.

- (a) Within 13 km of an international airport, or major domestic airport, or major military air base.
- (b) Within 5 km of a domestic airport with scheduled regular public transport services.
- (c) Within 3 km of any other type of airport or airfield for which an ANEF map is available.

Section 2 of this standard gives guidelines for determining the acoustic acceptability of a particular site. Conversely, the standard could be used to assess the noise impact of a new airport or of altering an existing one. Section 3, used in sequence with Section 2, gives guidelines for determining the extent of noise reduction and type(s) of construction required for a particular building.

Reference to the appropriate ANEF map will be necessary finally to determine the applicability of the recommendations of this standard.

NOTES:

1. A flow chart setting out the various steps contained in this standard is shown in Fig. 1.1.
2. A worked example of the application of the standard is given in Appendix E.

1.3 REFERENCED DOCUMENTS. The following standards are referred to in this standard:

AS 1259	Sound Level Meters
AS 1276	Methods for Determination of Sound Transmission Class and Noise Isolation Class of Building Partitions
AS 2107	Code of Practice for Ambient Sound Levels for Areas of Occupancy Within Buildings
ISO 717/3	Acoustics—Rating of Sound Insulation in Buildings and of Building Elements, Part 3—Airborne Sound Insulation of Facade Elements and Facades

1.4 DEFINITIONS. For the purpose of this standard, the following definitions apply:

1.4.1 Australian noise exposure forecast (ANEF)—a single number index for predicting the cumulative exposure to aircraft noise in communities near airports during a specified time period.

NOTE: The computation of this index includes—

- (a) measurements of aircraft noise (expressed in Effective Perceived Noise Decibels, EPNdB), which take account of the spectral, temporal and spatial aspects of the noise;
- (b) estimates and generalizations of aircraft type groups and mix, number of operations, runway utilization, flight paths and operational procedures; and
- (c) time of day, i.e. whether daytime (0700 hours to 1900 hours) or evening/night-time (1900 hours to 0700 hours).

This single number index is useful for rating the compatibility of various land uses with respect to aircraft noise. For this purpose, equivalent ANEF values at individual positions around an airport are combined on a map to form ANEF contours. (See Appendix B for a description of the ANEF system and the method for its determination.)

1.4.2 Building site—the proposed location for a new building or the location of an existing building in which it is desired to reduce aircraft noise intrusion.

1.4.3 Aircraft noise level—the average maximum A-weighted sound level occurring during an aircraft fly-over measured in decibels(A) (dB(A)) using the S time-weighting of a sound level meter.

NOTE: The A-weighting frequency curve approximates the response of the human ear to sound at different frequencies (see AS 1259).

1.4.4 Relevant runway—the runway whose end is closest to the building site under consideration.