

Australian/New Zealand Standard™

**Performance of close control
airconditioners**

Part 1: Testing for rating



AS/NZS 4965.1:2008

This Joint Australian/New Zealand Standard was prepared by Joint Technical Committee EL-015, Quality and Performance of Household Electrical Appliances. It was approved on behalf of the Council of Standards Australia on 15 September 2008 and on behalf of the Council of Standards New Zealand on 24 September 2008.

This Standard was published on 14 November 2008.

The following are represented on Committee EL-015:

Australian Association of Certification Bodies
Australian Consumers' Association
Australian Electrical and Electronic Manufacturers Association
Australian Industry Group
Australian Retailers Association
Business New Zealand
Consumer Electronic Suppliers Association
Department of Energy, Utilities and Sustainability, New South Wales
Department of Industrial Relations, Queensland
Department of Minerals and Energy, Queensland
Electrical Compliance Testing Association
Energy Efficiency and Conservation Authority, New Zealand
Energy Safe, Victoria
Institution of Professional Engineers, New Zealand
National Appliance and Equipment Energy Efficiency Committee
New Zealand Manufacturers Federation
Office of the Chief Electrical Inspector, Victoria
Office of the Technical Regulator, South Australia

Keeping Standards up-to-date

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about joint Australian/New Zealand Standards can be found by visiting the Standards Web Shop at www.standards.com.au or Standards New Zealand web site at www.standards.co.nz and looking up the relevant Standard in the on-line catalogue.

Alternatively, both organizations publish an annual printed Catalogue with full details of all current Standards. For more frequent listings or notification of revisions, amendments and withdrawals, Standards Australia and Standards New Zealand offer a number of update options. For information about these services, users should contact their respective national Standards organization.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Please address your comments to the Chief Executive of either Standards Australia or Standards New Zealand at the address shown on the back cover.

This Standard was issued in draft form for comment as DR 08027.

Australian/New Zealand Standard™

Performance of close control airconditioners

Part 1: Testing for rating

First published as AS/NZS 4965.1:2008.

COPYRIGHT

© Standards Australia/Standards New Zealand

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher.

Jointly published by Standards Australia, GPO Box 476, Sydney, NSW 2001 and Standards New Zealand, Private Bag 2439, Wellington 6020

ISBN 0 7337 8938 2

PREFACE

This Standard was prepared by the Joint Standards Australia/Standards New Zealand Committee EL-015, Quality and Performance of Household Electrical Appliances.

The overall objective of the AS/NZS 4965 series of Standards is to promote high levels of performance and energy efficiency in close control airconditioners.

The AS/NZS 4965 series of Standards consists of the following:

AS/NZS

4965 Performance of close control airconditioners

4965.1 Part 1: Testing for rating (this Standard)

4965.2 Part 2: Minimum energy performance standard (MEPS) requirements

This Standard is published with the approval of the combined state and territory regulatory authorities and is structured to be suitable for reference in legislation calling up minimum energy performance standards and also for reference in energy labelling regulatory legislation.

Acknowledgment is due to the American Society of Heating, Refrigerating, and Air-Conditioning Engineers, whose Standard ASHRAE 127-2007 was reviewed during the development of this Standard. This Standard is a Joint Australian/New Zealand Standard and is not an ASHRAE Standard.

Statements expressed in mandatory terms in notes to figures are deemed to be requirements of this Standard.

The terms 'normative' and 'informative' have been used in this Standard to define the application of the appendix to which they apply. A 'normative' appendix is an integral part of a Standard, whereas an 'informative' appendix is only for information and guidance.

CONTENTS

	<i>Page</i>
1 SCOPE.....	4
2 APPLICATION	4
3 REFERENCED DOCUMENTS.....	4
4 DEFINITIONS.....	4
5 COOLING TESTS.....	6
6 TEST METHODS AND UNCERTAINTY OF MEASUREMENT.....	7
7 TEST RESULTS.....	11
8 PUBLICATION OF RATINGS	14
 APPENDICES	
A TEST PROCEDURES	15
B CALORIMETER TEST METHOD	16
C HEATING AND COOLING CAPACITY CALCULATIONS	24
D AIRFLOW MEASUREMENT	28
E REFRIGERANT ENTHALPY TEST METHOD.....	32
F LIST OF SYMBOLS	34

STANDARDS AUSTRALIA/STANDARDS NEW ZEALAND**Australian/New Zealand Standard
Performance of close control airconditioners****Part 1: Testing for rating****1 SCOPE**

This Standard specifies the conditions on which the capacity and energy consumption of factory-made close control airconditioners are based and the test methods to be applied to determine the capacity and efficiency ratings. This Standard covers equipment utilizing a single or multiple refrigerated direct expansion (DX) system designed to control and monitor temperature and humidity and may include supplementary conditioning equipment.

Appendix A establishes testing procedures. Appendix B describes the test facilities required for the calorimeter method. Appendix C provides formulae for calculating heating and cooling capacities. Appendix D describes methods for measuring airflow. Appendix E describes the refrigerant enthalpy test method. Appendix F lists the symbols used in this Standard.

This Standard does not cover the determination of seasonal efficiencies, which may be required in some countries.

2 APPLICATION

Close control airconditioners are used for applications where temperature and humidity are required to be monitored and maintained within narrow limits. Examples of such applications are computer rooms, data processing units, telecommunication facilities and other industrial process areas.

3 REFERENCED DOCUMENTS

The following documents are referred to in this Standard:

AS/NZS

62301 Household electrical appliances—Measurement of standby power (IEC 62301, Ed. 1.01 (2005) MOD)

ASHRAE

52.2 Method of testing general ventilation air-cleaning devices for removal efficiency by particle size

127 Method of testing for rating computer and data processing room unitary air conditioners

4 DEFINITIONS

For the purpose of this Standard, the definitions below apply. Appendix F lists the symbols used in this Standard.