

Australian Standard™

Thermally released links

This Australian Standard was prepared by Committee ME/62, Ventilation and Airconditioning. It was approved on behalf of the Council of Standards Australia on 12 February 1999 and published on 5 May 1999.

The following interests are represented on Committee ME/62:

Air Conditioning and Mechanical Contractors Association of Australia
Air Conditioning and Refrigeration Equipment Manufacturers of Australia
Australasian Fire Authorities Council
Australian Building Codes Board
Australian Chamber of Commerce and Industry
Australian Industry Group
Australian Institute of Building Surveyors
Australian Institute of Refrigeration Air Conditioning and Heating
Chartered Institution of Building Services Engineers
CSIRO Building, Construction and Engineering
Department of Contract and Management Services W.A.
FPA Australia
Institution of Engineers Australia
Institution of Refrigeration Heating and Airconditioning Engineers New Zealand
Plastics and Chemicals Industries Association Incorporated
Property Council of Australia
Thermal Insulation Contractors Association of Australia

Review of Australian Standards. *To keep abreast of progress in industry, Australian Standards are subject to periodic review and are kept up to date by the issue of amendments or new editions as necessary. It is important therefore that Standards users ensure that they are in possession of the latest edition, and any amendments thereto.*

Full details of all Australian Standards and related publications will be found in the Standards Australia Catalogue of Publications; this information is supplemented each month by the magazine 'The Australian Standard', which subscribing members receive, and which gives details of new publications, new editions and amendments, and of withdrawn Standards.

Suggestions for improvements to Australian Standards, addressed to the head office of Standards Australia, are welcomed. Notification of any inaccuracy or ambiguity found in an Australian Standard should be made without delay in order that the matter may be investigated and appropriate action taken.

This Standard was issued in draft form for comment as DR 98486.

AS 1890—1999

Australian Standard™

Thermally released links

Originated as AS 1890—1976.
Second edition 1999.

Published by Standards Australia
(Standards Association of Australia)
1 The Crescent, Homebush NSW 2140

ISBN 0 7337 2583 X

PREFACE

This Standard was prepared by Joint Standards Australia/Standards New Zealand Committee ME/62, Ventilation and Airconditioning, to supersede AS 1890—1976.

The objective of this document is to provide standardized construction, performance and test requirements for thermally released links for use by manufacturers, specifiers and users of these products.

Thermally released links are intended to be mounted so as to be primarily under tension. For applications where the thermally released link will be subject to an in-service tension force of less than 1.47 N (0.15 kgf), special certification as to suitability should be required from the manufacturer.

© Copyright – STANDARDS AUSTRALIA

Users of Standards are reminded that copyright subsists in all Standards Australia publications and software. Except where the Copyright Act allows and except where provided for below no publications or software produced by Standards Australia may be reproduced, stored in a retrieval system in any form or transmitted by any means without prior permission in writing from Standards Australia. Permission may be conditional on an appropriate royalty payment. Requests for permission and information on commercial software royalties should be directed to the head office of Standards Australia.

Standards Australia will permit up to 10 percent of the technical content pages of a Standard to be copied for use exclusively in-house by purchasers of the Standard without payment of a royalty or advice to Standards Australia.

Standards Australia will also permit the inclusion of its copyright material in computer software programs for no royalty payment provided such programs are used exclusively in-house by the creators of the programs.

Care should be taken to ensure that material used is from the current edition of the Standard and that it is updated whenever the Standard is amended or revised. The number and date of the Standard should therefore be clearly identified.

The use of material in print form or in computer software programs to be used commercially, with or without payment, or in commercial contracts is subject to the payment of a royalty. This policy may be varied by Standards Australia at any time.

CONTENTS

	<i>Page</i>
1 SCOPE	4
2 REFERENCED DOCUMENTS	4
3 IDENTIFICATION	4
4 CONSTRUCTION.....	5
5 PERFORMANCE REQUIREMENTS AND TESTS	5
6 MANUFACTURING AND PRODUCTION CONTROL TESTS	8
7 MARKING.....	8
 APPENDICES	
A HIGH TEMPERATURE FATIGUE TEST PROCEDURES FOR USE IN HIGH TEMPERATURE INDUSTRIAL ENVIRONMENT.....	10
B MEANS FOR DEMONSTRATING COMPLIANCE WITH THIS STANDARD	11

STANDARDS AUSTRALIA

Australian Standard Thermally released links

1 SCOPE

This Standard specifies requirements for thermally released links for general fire protection services in buildings. Thermally released links are commonly used in fire dampers, fire shutters, smoke and heat ventilators and fire doors.

The Standard includes requirements for construction, testing, identification and marking of thermally released links, as well as special high temperature fatigue test procedures for uncoated and coated thermally released links, for use in high temperature industrial environments.

This Standard does not apply to links incorporated in sprinkler heads.

2 REFERENCED DOCUMENTS

The following documents are referred to in this Standard:

AS

- | | |
|---------|--|
| 1199 | Sampling procedures and table for inspection by attributes |
| 1399 | Guide to AS 1199—Sampling procedures and tables for inspection by attributes |
| 2362 | Automatic fire detection and alarm systems—Methods of test for actuating devices |
| 2362.1 | Method 1: Heat sensitivity testing of Types A, B, C and D heat detectors |
| 2362.13 | Method 13: Corrosion test |
| 2831 | Thermometers—Solid system—Long and short—For precision use |

AS/NZS

- | | |
|------------|--|
| ISO 9000 | Quality management and quality assurance standards |
| ISO 9000.1 | Part 1: Guidelines for selection and use |
| ISO 9004 | Quality management and quality system elements |
| ISO 9004.1 | Part 1: Guidelines |

SAA

- | | |
|---------|--|
| HB18 | Guidelines for third-party certification and accreditation |
| HB18.28 | Guide 28—General rules for model third-party certification scheme for products |

3 IDENTIFICATION

Thermally released links shall be identified by temperature rating, type of coating or plating, maximum working load and other factors, which may have a bearing on their intended use.

The identification, legibly marked, shall be in accordance with Clause 7.