

Australian/New Zealand Standard™

Electromagnetic compatibility (EMC)

Part 4.34: Testing and measurements techniques—Voltage dips, short interruptions and voltage variations immunity tests for equipment with mains current more than 16 A per phase



AS/NZS 61000.4.34:2012

This Joint Australian/New Zealand Standard was prepared by Joint Technical Committee EL-034, Power Quality. It was approved on behalf of the Council of Standards Australia on 4 June 2012 and on behalf of the Council of Standards New Zealand on 7 June 2012.

This Standard was published on 28 June 2012.

The following are represented on Committee EL-034:

Australian Chamber of Commerce and Industry
Australian Industry Group
Australian Information Industry Association
Bureau of Steel Manufacturers of Australia
Consumer Electronics Suppliers Association
Consumers Federation of Australia
Electrical Regulatory Authorities Council
Electricity Engineers Association, New Zealand
Energy Networks Association
Engineers Australia
Lighting Council of Australia
Ministry of Economic Development, New Zealand
National Measurement Institute
New Zealand Coordinating Committee on Power & Telecommunication Systems
New Zealand Electric Fence Energiser Manufacturers Standards WG
Telstra Corporation
University of Canterbury, New Zealand
University of Wollongong

Keeping Standards up-to-date

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about joint Australian/New Zealand Standards can be found by visiting the Standards Web Shop at www.saiglobal.com.au or Standards New Zealand web site at www.standards.co.nz and looking up the relevant Standard in the on-line catalogue.

For more frequent listings or notification of revisions, amendments and withdrawals, Standards Australia and Standards New Zealand offer a number of update options. For information about these services, users should contact their respective national Standards organization.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Please address your comments to the Chief Executive of either Standards Australia or Standards New Zealand at the address shown on the back cover.

Australian/New Zealand Standard™

Electromagnetic compatibility (EMC)

Part 4.34: Testing and measurements techniques—Voltage dips, short interruptions and voltage variations immunity tests for equipment with mains current more than 16 A per phase

Originated as AS/NZS 61000.4.34:2007.
Second edition 2012.

COPYRIGHT

© Standards Australia Limited/Standards New Zealand

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher, unless otherwise permitted under the Copyright Act 1968 (Australia) or the Copyright Act 1994 (New Zealand).

Jointly published by SAI Global Limited under licence from Standards Australia Limited, GPO Box 476, Sydney, NSW 2001 and by Standards New Zealand, Private Bag 2439, Wellington 6140

ISBN 978 1 74342 188 8

PREFACE

This Standard was prepared by the Joint Standards Australia/Standards New Zealand Committee EL-034, Power Quality to supersede AS/NZS 61000.4.34:2007.

The objective of this Standard is to establish a common reference for evaluating the immunity of electric and electronic equipment when subjected to voltage dips, short interruptions and voltage variations.

This Standard is an adoption with national modifications and has been reproduced from IEC 61000-4-34 Ed.1.1 (2009), *Electromagnetic compatibility (EMC)—Part 4-34: Testing and measurement techniques—Voltage dips, short interruptions and voltage variations immunity tests for equipment with mains current more than 16 A per phase*, and has been varied as indicated to take account of Australian/New Zealand conditions.

Variations to IEC 61000-4-34:2009 are indicated at the appropriate places within this Standard. Strikethrough (~~example~~) identifies IEC text, tables and figures which, for the purpose of this Australian Standard, are deleted. Where text, tables or figures are added, each is set in its proper place and identified by shading (example).

IEC 61000-4-34 Ed.1.1 (2009) consists of the IEC 61000-4-34 Ed.1.0 (2005) and its amendment 1 (2009). A vertical line in the margin of the document shows where the base publication has been modified by amendment 1.

As this Standard is reproduced from an International Standard, the following applies:

- (a) Its number appears on the cover and title page while the International Standard number appears only on the cover.
- (b) In the source text 'this part of IEC 61000' should read 'this part of AS/NZS 61000'.
- (c) A full point substitutes for a comma when referring to a decimal marker.

The terms 'normative' and 'informative' have been used in this Standard to define the application of the annex to which they apply. A 'normative' annex is an integral part of a Standard, whereas an 'informative' annex is only for information and guidance.

CONTENTS

1	Scope.....	7
2	Normative references	8
3	Terms and definitions	8
4	General	9
5	Test levels.....	10
5.1	Voltage dips and short interruptions	10
5.2	Voltage variations (optional)	11
6	Test instrumentation	14
6.1	Test generator.....	14
6.2	Power source	15
7	Test set-up	15
8	Test procedures	15
8.1	Laboratory reference conditions	16
8.2	Execution of the test.....	16
9	Evaluation of test results	19
10	Test report.....	19
	Annex A (normative) Test generator current drive capability	20
	Annex B (informative) Electromagnetic environment classes.....	22
	Annex C (informative) Vectors for three-phase testing	23
	Annex D (informative) Test instrumentation	29
	Annex E (informative) Dip immunity tests for equipment with large mains current	32
	Bibliography.....	34
	Figure 1 – Voltage dip – 70 % voltage dip sine wave graph.....	13
	Figure 2 – Voltage variation	13
	Figure 3a – Phase-to-neutral testing on three-phase systems	18
	Figure 3b – Phase-to-phase testing on three-phase systems – Acceptable Method 1 phase shift.....	18
	Figure 3c – Phase-to-phase testing on three-phase systems – Acceptable Method 2 phase shift.....	18
	Figure 3d – Not acceptable – phase-to-phase testing without phase shift.....	18
	Figure A.1 – Circuit for determining inrush current drive capability	21
	Figure C.1 – Phase-to-neutral dip vectors	23
	Figure C.2 – Acceptable Method 1 – phase-to-phase dip vectors	25
	Figure C.3 – Acceptable Method 2 – phase-to-phase dip vectors	27
	Figure D.1 – Schematic of example test instrumentation for voltage dips and short interruptions using tapped transformer and switches.....	29

Figure D.2 – Applying the example test instrumentation of Figure D.1 to create the Acceptable Method 1 vectors of Figures C.1, C.2, 4a and 4b	30
Figure D.3 – Schematic of example test instrumentation for three-phase voltage dips, short interruptions and voltage variations using power amplifier.....	31
Table 1 – Preferred test level and durations for voltage dips	11
Table 2 – Preferred test level and durations for short interruptions	11
Table 3 – Timing of short-term supply voltage variations.....	11
Table 4 – Generator specifications.....	14
Table A.1 – Minimum peak inrush current capability.....	20
Table C.1 – Vector values for phase-to-neutral dips.....	24
Table C.2 – Acceptable Method 1 – vector values for phase-to-phase dips	26
Table C.3 – Acceptable Method 2 – vector values for phase-to-phase dips	28

AUSTRALIAN/NEW ZEALAND STANDARD

Electromagnetic compatibility (EMC)

Part 4.34:

Testing and measurements techniques—Voltage dips, short interruptions and voltage variations immunity tests for equipment with mains current more than 16 A per phase

Any table, figure or text of the international standard that is struck through is not part of this standard. Any Australian/New Zealand table, figure or text that is added is part of this standard and is identified by shading.

1 Scope

This part of IEC 61000 defines the immunity test methods and range of preferred test levels for electrical and electronic equipment connected to low-voltage power supply networks for voltage dips, short interruptions, and voltage variations.

This standard applies to electrical and electronic equipment having a rated mains current exceeding 16 A per phase. (See Annex E for guidance on electrical and electronic equipment rated at more than 200 A per phase.) It covers equipment installed in residential areas as well as industrial machinery, specifically voltage dips and short interruptions for equipment connected to either 50 Hz or 60 Hz a.c. networks, including 1-phase and 3-phase mains.

NOTE 1 Equipment with a rated mains current of 16 A or less per phase is covered by publication IEC 61000-4-11.

NOTE 2 There is no upper limit on rated mains current in this publication. However, in some countries, the rated mains current may be limited to some upper value, for example 75 A or 250 A, because of mandatory safety standards.

It does not apply to electrical and electronic equipment for connection to 400 Hz a.c. networks. Tests for equipment connected to these networks will be covered by future IEC standards.

The object of this standard is to establish a common reference for evaluating the immunity of electrical and electronic equipment when subjected to voltage dips, short interruptions and voltage variations.

NOTE 1 Voltage fluctuations are covered by publication IEC 61000-4-14.

NOTE 2 For equipment under test with rated currents above 250 A, suitable test equipment may be difficult to obtain. In these cases, the applicability of this standard should be carefully evaluated by committees responsible for generic, product and product-family standards. Alternatively, this standard might be used as a framework for an agreement on performance criteria between the manufacturer and the purchaser.

The test method documented in this part of IEC 61000 describes a consistent method to assess the immunity of equipment or a system against a defined phenomenon. As described in IEC Guide 107, this is a basic EMC publication for use by product committees of the IEC. As also stated in Guide 107, the IEC product committees are responsible for determining whether this immunity test standard should be applied or not, and if applied, they are responsible for defining the appropriate test levels. Technical committee 77 and its sub-committees are prepared to co-operate with product committees in the evaluation of the value of particular immunity tests for their products.