



American National Standard for

# Rotodynamic Pumps

for Nomenclature and Definitions



American National Standard for  
**Rotodynamic Pumps**  
for Nomenclature and Definitions

Sponsor  
**Hydraulic Institute**  
[www.Pumps.org](http://www.Pumps.org)

Approved April 9, 2019  
**American National Standards Institute, Inc.**

# American National Standard

Approval of an American National Standard requires verification by ANSI that the requirements for due process, consensus, and other criteria for approval have been met by the standards developer.

Consensus is established when, in the judgement of the ANSI Board of Standards Review, substantial agreement has been reached by directly and materially affected interests. Substantial agreement means much more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered, and that a concerted effort be made toward their resolution.

The use of American National Standards is completely voluntary; their existence does not in any respect preclude anyone, whether he has approved the standards or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standards.

The American National Standards Institute does not develop standards and will in no circumstances give an interpretation of any American National Standard. Moreover, no person shall have the right or authority to issue an interpretation of an American National Standard in the name of the American National Standards Institute. Requests for interpretations should be addressed to the secretariat or sponsor whose name appears on the title page of this standard.

**CAUTION NOTICE:** This American National Standard may be revised or withdrawn at any time. The procedures of the American National Standards Institute require that action be taken periodically to reaffirm, revise, or withdraw this standard. Purchasers of American National Standards may receive current information on all standards by calling or writing the American National Standards Institute.

Published By

**Hydraulic Institute, Inc.**  
**6 Campus Drive, First Floor North**  
**Parsippany, NJ 07054-4406**  
**[www.Pumps.org](http://www.Pumps.org)**

Copyright © 2019 Hydraulic Institute  
All rights reserved.

No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without prior written permission of the publisher.

Printed in the United States of America  
ISBN 978-1-935762-79-9



# Contents

Page

Foreword .....	xi	
14.1	Types and nomenclature .....	1
14.1.1	Introduction .....	1
14.1.1.1	Purpose .....	1
14.1.1.2	Scope .....	1
14.1.2	Definition of rotodynamic pump .....	2
14.1.3	Types of rotodynamic pumps .....	2
14.1.3.1	Overhung impeller type (OH) .....	2
14.1.3.1.1	Flexibly coupled (OH0, OH1, OH2, OH3, and OH6) .....	4
14.1.3.1.2	Rigidly coupled/short coupled (OH4 and OH13) .....	4
14.1.3.1.2.1	Rigidly coupled .....	4
14.1.3.1.2.2	Short-coupled .....	4
14.1.3.1.3	Close-coupled (OH5, OH6, OH7, and OH8) .....	4
14.1.3.1.3.1	High-speed integral, gear-driven pumps (OH6) .....	4
14.1.3.2	Impeller between-bearing type (BB) .....	5
14.1.3.2.1	One and two stage with axially split casing (BB1) .....	5
14.1.3.2.2	One and two stage with radially split casing (BB2) .....	5
14.1.3.2.3	Multistage with axially split casing and volute (BB3) .....	6
14.1.3.2.4	Multistage with radially split casing held in place with tie bolts (BB4) .....	6
14.1.3.2.5	Multistage with radially split casing external casing and internal pumping elements (BB5) .....	6
14.1.3.3	Impeller vertically suspended type (VS) .....	6
14.1.3.3.1	Single casing .....	8
14.1.3.3.1.1	Submersible (VS0) .....	8
14.1.3.3.1.2	Discharge through column (VS1, VS2, and VS3) .....	8
14.1.3.3.1.3	Separate Discharge (VS4 and VS5) .....	8
14.1.3.3.2	Double casing (VS6, VS7, and VS8) .....	8
14.1.3.4	Regenerative turbine type (RT) .....	8
14.1.3.5	Circulator pumps (CP) .....	9

14.1.3.5.1.1	Close-coupled circulator pumps (CP1 and CP2) . . . . .	10
14.1.3.5.1.2	Flexibly coupled circulator pumps (CP3) . . . . .	10
14.1.3.6	Hydraulic power recovery turbine . . . . .	10
14.1.3.7	Pumps of other configurations . . . . .	10
14.1.3.7.1	Casing/Impeller Types. . . . .	12
14.1.3.7.1.1	Diffuser, vaned (a) . . . . .	12
14.1.3.7.1.3	Volute (b) . . . . .	12
14.1.3.7.1.4	Axial (c) . . . . .	12
14.1.3.7.1.5	Pitot Tube (d) . . . . .	12
14.1.3.7.2	Vertical . . . . .	12
14.1.3.7.2.1	In-line (std) . . . . .	12
14.1.3.7.2.2	End Suction (g) . . . . .	12
14.1.3.7.3	Self-priming (h) . . . . .	12
14.1.3.7.4	Sealless (i) . . . . .	13
14.1.3.7.4.1	Magnetic Drive . . . . .	13
14.1.3.7.4.3	Canned motor . . . . .	13
14.1.3.7.5	Multistage (j) . . . . .	13
14.1.3.7.6	Rotodynamic pump types – overhung impeller. . . . .	14
14.1.3.7.7	Rotodynamic pump types – vertically suspended. . . . .	15
14.1.3.7.8	Rotodynamic pump types – between bearing. . . . .	15
14.1.3.7.9	Rotodynamic pump types – regenerative turbine . . . . .	15
14.1.3.7.10	Rotodynamic pump types – circulator pump. . . . .	16
14.1.4	Impeller Designs . . . . .	16
14.1.4.1	Specific speed ( $n_s$ ), type number ( $K$ ), and suction specific speed (S) . . . . .	18
14.1.4.1.1	Specific Speed . . . . .	18
14.1.4.1.2	Type Number . . . . .	18
14.1.4.1.3	Suction Specific Speed. . . . .	19
14.1.4.2	Radial flow . . . . .	20
14.1.4.3	Francis vane (modified radial flow) . . . . .	20
14.1.4.4	Mixed flow. . . . .	20
14.1.4.5	Axial flow . . . . .	21

14.1.4.6	Vortex (recessed impeller) type . . . . .	21
14.1.5	Discharge casing design . . . . .	21
14.1.5.1	Volute . . . . .	22
14.1.5.2	Concentric (circular) casing . . . . .	22
14.1.5.2.1	Modified concentric casing . . . . .	22
14.1.5.3	Vaned diffuser/collector . . . . .	22
14.1.5.3.1	Bowl and stage casing . . . . .	22
14.1.6	Construction drawings . . . . .	22
14.1.7	General information . . . . .	62
14.1.7.1	Size of a rotodynamic pump . . . . .	62
14.1.7.2	Definition of duplicate performance pump . . . . .	63
14.1.7.3	Definition of dimensionally interchangeable pump . . . . .	63
14.1.7.4	Definition of identical pump (performance and dimensional) . . . . .	63
14.1.7.5	Definitions for major pump sub-assemblies . . . . .	63
14.1.7.5.1	Overhung pumps . . . . .	63
14.1.7.5.1.1	Liquid end (or wet end assembly) . . . . .	63
14.1.7.5.1.2	Power end (or frame assembly) . . . . .	64
14.1.7.5.1.3	Back pull-out assembly . . . . .	64
14.1.7.5.1.4	Bare rotor . . . . .	65
14.1.7.5.1.5	Rotating assembly . . . . .	65
14.1.7.6	Bowl assembly . . . . .	65
14.1.7.7	Position of casing . . . . .	65
14.1.7.8	Rotation of shaft . . . . .	66
14.1.7.8.1	Gear driven . . . . .	67
14.1.7.8.2	Double-extended shaft . . . . .	67
14.1.7.9	Special case ASME/ANSI B73.1, C-frame adapter . . . . .	67
14.1.7.10	Drivers for vertically suspended pumps . . . . .	68
14.1.7.10.1	Vertical solid shaft driver . . . . .	68
14.1.7.10.2	Vertical hollow shaft driver . . . . .	68
14.1.7.11	Open/enclosed line shaft . . . . .	68
14.1.7.12	Vertically suspended pump length . . . . .	69

14.1.7.12.1	Total pump length . . . . .	69
14.1.7.12.2	Pump setting . . . . .	69
14.1.8	Pump nomenclature. . . . .	70
14.1.8.1	Definitions - part names . . . . .	70
14.1.8.2	Overhung and between-bearing pump dimensions . . . . .	80
14.2	Definitions, terminology, and symbols . . . . .	86
14.2.1	Volume rate of flow (Q) . . . . .	89
14.2.1.1	BEP rate of flow ( $Q_{opt}$ ) . . . . .	89
14.2.1.2	Minimum continuous stable flow ( $Q_{min\ all\ stable}$ ) . . . . .	90
14.2.1.3	Minimum continuous thermal flow ( $Q_{min\ thermal}$ ) . . . . .	90
14.2.1.4	Maximum allowable flow ( $Q_{max\ all}$ ) . . . . .	90
14.2.2	Speed (n) . . . . .	90
14.2.2.1	Maximum allowable continuous speed ( $n_{max\ all}$ ) . . . . .	90
14.2.2.2	Minimum allowable continuous speed ( $n_{min\ all}$ ) . . . . .	90
14.2.2.3	Rated speed ( $n_r$ ) . . . . .	90
14.2.3	Head (h) [H] . . . . .	90
14.2.3.1	Gauge head ( $h_g$ ) [ $H_{Mx}$ ] . . . . .	90
14.2.3.2	Velocity head ( $h_v$ ) . . . . .	90
14.2.3.3	Elevation head (Z) [ $H_{stat}$ ] . . . . .	91
14.2.3.4	NPSH datum plane. . . . .	91
14.2.3.5	Total suction head ( $h_s$ ), open suction . . . . .	91
14.2.3.6	Total suction head ( $h_s$ ), closed suction . . . . .	91
14.2.3.7	Total discharge head ( $h_d$ ) . . . . .	92
14.2.3.8	Total head (H) [ $H_{tx}$ ] . . . . .	92
14.2.3.9	Bowl assembly total head ( $H_{ba}$ ) . . . . .	92
14.2.3.10	Atmospheric head ( $h_{atm}$ ) . . . . .	92
14.2.3.11	Friction head ( $h_f$ or $h_j$ ) . . . . .	92
14.2.4	Condition points . . . . .	93
14.2.4.1	Rated condition point ( $Q_r$ ) or ( $H_r$ ) . . . . .	93
14.2.4.2	Specified condition point . . . . .	93
14.2.4.3	Normal condition point ( $Q_N$ ) or ( $H_N$ ) . . . . .	93

14.2.4.4	Best efficiency point (BEP) . . . . .	93
14.2.4.5	Shutoff (SO) . . . . .	93
14.2.4.6	Operating regions . . . . .	93
14.2.4.6.1	Preferred operating region (POR) . . . . .	93
14.2.4.6.2	Allowable operating region (AOR) . . . . .	93
14.2.5	Suction conditions . . . . .	94
14.2.5.1	Submerged suction . . . . .	94
14.2.5.2	Flooded suction . . . . .	94
14.2.5.3	Static suction lift ( $l_s$ ) . . . . .	94
14.2.5.4	Net positive suction head (NPSH) . . . . .	94
14.2.5.5	Net positive suction head available (NPSHA) . . . . .	94
14.2.5.6	Net positive suction head required (NPSHR) . . . . .	94
14.2.5.7	Net positive suction head resulting in 3% loss of total head (NPSH3) . . . . .	94
14.2.5.8	Maximum suction pressure ( $p_{s\ max}$ , [ $p_{1\ max\ op}$ or $p_{1\ max\ all}$ ] . . . . .	95
14.2.6	Power . . . . .	95
14.2.6.1	Electric motor input power ( $P_{mot}$ ) [ $P_1$ ] . . . . .	95
14.2.6.2	Pump input power ( $P_p$ ) [ $P$ ] . . . . .	95
14.2.6.3	Bowl assembly input power ( $P_{ba}$ ) . . . . .	95
14.2.6.4	Pump output power ( $P_w$ ) [ $P_u$ ] . . . . .	95
14.2.6.5	Overall efficiency ( $\eta_{OA}$ ) . . . . .	95
14.2.6.6	Pump efficiency ( $\eta_p$ ) . . . . .	96
14.2.6.7	Bowl assembly efficiency ( $\eta_{ba}$ ) . . . . .	96
14.2.6.8	Pump pressures . . . . .	96
14.2.6.8.1	Working pressure (pd) [ $p_{2\ max\ op}$ ] . . . . .	96
14.2.6.8.2	Maximum allowable working pressure (MAWP) . . . . .	96
14.2.6.8.3	Field-test pressure . . . . .	96
14.2.6.8.4	Rated discharge pressure . . . . .	96
14.2.6.9	Impeller balancing . . . . .	96
14.2.6.9.1	Single-plane balancing (formerly called static balancing) . . . . .	96
14.2.6.9.2	Two-plane balancing (formerly called dynamic balancing) . . . . .	96

Appendix A .....	97
Appendix B .....	98
Appendix C .....	105
Appendix D .....	107

Figures

14.1.3 — Rotodynamic pump types .....	2
14.1.3.7 — Typical vertical pump impeller types with rings (casing and/or impeller).....	17
14.1.4.1 — General impeller types .....	20
14.1.4.2 — Double suction radial flow impeller .....	20
14.1.4.4 — Mixed-flow impeller .....	21
14.1.4.5 — Axial-flow impeller .....	21
14.1.4.6 — Vortex (recessed impeller) type .....	21
14.1.6a — Overhung impeller – flexibly coupled – frame mounted – single stage .....	23
14.1.6b — Overhung impeller – flexibly coupled – frame mounted – single-stage – lined pump .....	24
14.1.6c — Overhung impeller – flexibly coupled – horizontal – axial flow – single-stage .....	25
14.1.6d — Pitot tube pump .....	26
14.1.6e — Overhung impeller – flexibly coupled – foot mounted – single-stage – stock pump .....	27
14.1.6f — Overhung impeller – flexibly coupled – foot mounted – single-stage .....	28
14.1.6g — Overhung impeller – flexibly coupled – foot mounted – single-stage – ASME B73.1 .....	29
14.1.6h — Overhung impeller – flexibly coupled – foot mounted – self-priming – single-stage .....	30
14.1.6i — Overhung impeller – flexibly coupled – centerline mounted – single-stage – API 610 .....	31
14.1.6j — Overhung impeller – flexibly coupled – vertical – in-line – integral bearing frame – single-stage .....	32
14.1.6k — Overhung impeller – flexibly coupled – vertical – end suction – single-stage .....	33
14.1.6l — Overhung impeller – rigidly coupled – vertical – in-line – single-stage .....	34
14.1.6m — Overhung impeller – close-coupled – vertical – in-line – single-stage (showing seal and packing) ..	35
14.1.6n — Overhung impeller – close-coupled – vertical – end suction – single-stage – vertically mounted ..	36
14.1.6o — Overhung impeller – close-coupled – high-speed integral gear – single-stage .....	37
14.1.6p — Overhung impeller – close-coupled – horizontal – single -stage – end suction .....	38
14.1.6q — Overhung impeller – close-coupled – submersible – diffuser – single-stage – end suction .....	39
14.1.6r — Overhung impeller – close-coupled – submersible – volute – single-stage – end suction .....	40
14.1.6s — Between bearings – single-stage – axially split pump .....	41
14.1.6t — Between bearings – single-stage – radially split pump .....	42
14.1.6u — Between bearings – multistage – axially split pump .....	43
14.1.6v — Between bearings – multistage – radially split – single casing pump .....	44

14.1.6w — Between bearings – multistage – radially split – double casing pump . . . . .	45
14.1.6x — Regenerative turbine – overhung side channel . . . . .	46
14.1.6y — Regenerative turbine – overhung peripheral . . . . .	47
14.1.6z — Regenerative turbine – between bearings - peripheral . . . . .	48
14.1.6aa — Close-coupled sealless with canned motor . . . . .	49
14.1.6bb — Close-coupled horizontal in-line. . . . .	49
14.1.6cc — Flexibly coupled horizontal in-line. . . . .	50
14.1.6dd — Vertically suspended – single casing – submersible pump . . . . .	51
14.1.6ee — Vertically suspended – single casing – discharge through column – deep-well (set) pumps. . . . .	52
14.1.6ff — Vertically suspended – single casing – discharge through column – short-set pump . . . . .	53
14.1.6gg — Vertically suspended – single casing – discharge through column – short-set - mixed flow pump . . . . .	54
14.1.6hh — Vertically suspended – single casing – discharge through column – volute pump . . . . .	55
14.1.6ii — Vertically suspended – single casing – discharge through column – axial flow pump . . . . .	56
14.1.6jj — Vertically suspended – single casing – separate discharge – line shaft pump. . . . .	57
14.1.6kk — Vertically suspended – single casing – separate discharge – cantilever pump . . . . .	58
14.1.6ll — Vertically suspended – double casing – diffuser pump. . . . .	59
14.1.6mm — Vertically suspended – double casing – volute/diffuser multistage pump . . . . .	60
14.1.6nn — Vertically suspended – double casing – volute multistage pump . . . . .	61
14.1.6oo — Vertically suspended – in-line casing diffuser . . . . .	62
14.1.7.5.1.1 — Liquid end (or wet end) assembly. . . . .	63
14.1.7.5.1.2 — Power end (or frame assembly) . . . . .	64
14.1.7.5.1.3 — Back pull-out assembly. . . . .	65
14.1.7.7 — Position of casing and shaft rotation. . . . .	66
14.1.7.8a — Horizontal pump – shaft rotation (CW rotation). . . . .	66
14.1.7.8b — Vertical pump – shaft rotation (CW rotation) . . . . .	67
14.1.7.9 — Pump with C-frame motor adapter, short coupled . . . . .	68
14.1.7.12 — Vertically suspended pump dimensions . . . . .	69
14.1.8.2a — Overhung impeller – flexibly coupled – single-stage – frame mounted. . . . .	80
14.1.8.2b — Overhung impeller – flexibly coupled – single-stage – frame mounted – pump on base plate . . . . .	81
14.1.8.2c — Overhung impeller – flexibly coupled – single-stage – centerline mounted . . . . .	81
14.1.8.2d — Overhung impeller – flexibly coupled – single-stage – centerline mounted – pump on baseplate . . . . .	82
14.1.8.2e — Overhung impeller – flexibly coupled – single-stage – centerline mounted (top suction) . . . . .	82
14.1.8.2f — Overhung impeller – flexibly coupled – single-stage – centerline mounted – pump on baseplate (top suction) . . . . .	83
14.1.8.2g — Impeller between bearings – flexibly coupled – single-stage – axial (horizontal) split case – pump on baseplate. . . . .	83

14.1.8.2h — Impeller between bearings – flexibly coupled – single-stage – axial (horizontal) split case . . . . .	84
14.1.8.2i — Overhung impeller – close-coupled – single-stage – end suction . . . . .	84
14.1.8.2j — Overhung impeller – flexibly coupled – vertical – end suction – single-stage – separate driver support. . . . .	85
14.1.8.2k — Overhung impeller – flexibly coupled – vertical – end suction – single-stage – integral driver support . . . . .	85
14.1.8.2l — Overhung impeller – close-coupled – single-stage – vertical end suction . . . . .	86
14.2.3.4 — Datum elevation for various pump designs at eye of first-stage impeller . . . . .	91
14.2.4.6.2 — Performance curve for rotodynamic pumps . . . . .	93
B.1 — Dimensions for types JM and JP, alternating current, face-mounting, close-coupled pump motors having rolling element contact bearings. (This figure relates to Tables B.1 and B.2.). . . . .	100
B.4 — Standard dimensions for HI – NEMA type HP and HPH vertical, solid-shaft motors . . . . .	103
B.5 — Standard dimensions for HI – NEMA vertical hollow-shaft motors . . . . .	104

Tables

14.1.1 – Rotodynamic pump type designations cross reference. . . . .	1
14.1.3.1 – Rotodynamic pump types – overhung . . . . .	3
14.1.3.2 – Rotodynamic pump types - between-bearing . . . . .	5
14.1.3.3 – Rotodynamic pump types - vertically suspended . . . . .	7
14.1.3.4 – Rotodynamic pump types – regenerative turbine type . . . . .	9
14.1.3.5 – Rotodynamic pump types – circulator pumps. . . . .	9
14.1.3.7 – Rotodynamic pump sub-classifications . . . . .	11
14.1.8.1a – Rotodynamic pump nomenclature - alphabetical listing . . . . .	70
14.1.8.1b – Rotodynamic pump nomenclature - numerical listing. . . . .	78
14.2a – Principal symbols . . . . .	86
14.2b – Subscripts. . . . .	88
B.3 – provides open drip-proof frame selections. . . . .	98
B.1 – Dimensions for type JM, alternating current, face-mounting, close-coupled pump motors (US customary units) . . . . .	99
B.2 – Dimensions for type JP, alternating current, face-mounting, close-coupled pump motors (US customary units) . . . . .	100
B.2 – Dimensions for type JP, alternating current, face-mounting, close-coupled pump motors (US customary units) . . . . .	101
B.3 – Open drip-proof frame selections. . . . .	101
B.4 – Standard dimensions for HI – NEMA type HP and HPH vertical solid-shaft motors (US customary units) . . . . .	102
B.5 – Dimensions for vertical hollow-shaft driver couplings (US customary units) . . . . .	103