

Australian/New Zealand Standard™

Explosive atmospheres

Part 20.1: Material characteristics for gas and vapour classification — Test methods and data (ISO/IEC 80079-20- 1:2017, (ED. 1.0)/COR1:2018, MOD)



AS/NZS 80079.20.1:2019

This Joint Australian/New Zealand Standard™ was prepared by Joint Technical Committee EL-014, Equipment for Explosive Atmospheres. It was approved on behalf of the Council of Standards Australia on 12 November 2019 and by the New Zealand Standards Approval Board on 4 December 2019.

This Standard was published on 20 December 2019.

The following are represented on Committee EL-014:

- Auckland Regional Chamber of Commerce
- Australian Chamber of Commerce and Industry
- Australian Industry Group
- Australian Institute of Petroleum
- Australian Petroleum Production and Exploration Association
- Australian Pipelines and Gas Association
- Aviation & Marine Engineers Association
- Bureau of Steel Manufacturers of Australia
- Business New Zealand
- Communications, Electrical and Plumbing Union — Electrical Division (Australia)
- Department of Natural Resources, Mines and Energy (Queensland)
- Electrical Compliance Testing Association of Australia
- Electrical Safety New Zealand
- Engineering New Zealand
- Engineers Australia
- Institute of Electrical Inspectors (Australia)
- Institute of Instrumentation, Control and Automation Australia
- Master Electricians (New Zealand)
- Mining Electrical and Mining Mechanical Engineering Society (Australia)
- NSW Department of Planning, Industry and Environment
- SafeWork NSW
- University of Newcastle
- WorkSafe New Zealand

This Standard was issued in draft form for comment as DR AS/NZS 80079.20.1:2019.

Keeping Standards up-to-date

Ensure you have the latest versions of our publications and keep up-to-date about Amendments, Rulings, Withdrawals, and new projects by visiting:

www.standards.org.au

www.standards.govt.nz

ISBN 978 1 76072 677 5

Australian/New Zealand Standard™

Explosive atmospheres

Part 20.1: Material characteristics for gas and vapour classification — Test methods and data (ISO/IEC 80079-20- 1:2017, (ED. 1.0)/COR1:2018, MOD)

First published as AS/NZS 80079.20.1:2019.

COPYRIGHT

© ISO/IEC 2019 — All rights reserved

© Standards Australia Limited/the Crown in right of New Zealand, administered by the New Zealand Standards Executive 2019

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher, unless otherwise permitted under the Copyright Act 1968 (Cth) or the Copyright Act 1994 (New Zealand).

Preface

This Standard was prepared by the Joint Standards Australia/Standards New Zealand Committee EL-014, Equipment for Explosive Atmospheres.

The objective of this Standard is to provide guidance on classification of gases and vapours. It describes a test method intended for the measurement of the maximum experimental safe gaps (MESG) for gas-air mixtures or vapour-air mixtures under normal conditions of temperature and pressure (20 °C, 101,3 kPa) so as to permit the selection of an appropriate group of equipment. This document also describes a test method intended for use in the determination of the auto-ignition temperature (AIT) of a vapour-air mixture or gas-air mixture at atmospheric pressure, so as to permit the selection of an appropriate temperature class of equipment.

Values of chemical properties of materials are provided to assist in the selection of equipment to be used in hazardous areas. Further data may be added as the results of validated tests become available.

The materials and the characteristics included in a table (see Annex B) have been selected with particular reference to the use of equipment in hazardous areas. The data in this document have been taken from a number of references which are given in the bibliography.

These methods for determining the MESG or the AIT may also be used for gas-air-inert mixtures or vapour-air-inert mixtures. However, data on air-inert mixtures are not tabulated.

This Standard is an adoption with national modifications, and has been reproduced from, ISO/IEC 80079-20-1:2017, *Explosive atmospheres – Part 20-1: Material characteristics for gas and vapour classification – Test methods and data* and its Corrigendum 1 (2018). The modifications are additional requirements and are set out in [Appendix ZZ](#), which has been added at the end of the source text.

[Appendix ZZ](#) lists the variations to ISO/IEC 80079-20-1:2017 for the application of this Standard in Australia and New Zealand.

As this document has been reproduced from an International Standard, the following applies:

- (a) In the source text “this part of ISO/IEC 80079” should read “this Australian/New Zealand Standard”.
- (b) A full point substitutes for a comma when referring to a decimal marker.

Australian or Australian/New Zealand Standards that are identical adoptions of international normative references may be used interchangeably. Refer to the online catalogue for information on specific Standards.

The terms “normative” and “informative” are used in Standards to define the application of the appendices or annexes to which they apply. A “normative” appendix or annex is an integral part of a Standard, whereas an “informative” appendix or annex is only for information and guidance.

NOTES

CONTENTS

FOREWORD.....	5
1 Scope.....	7
2 Normative references	7
3 Terms and definitions	7
4 Classification of gases and vapours.....	9
4.1 General.....	9
4.2 Classification according to the maximum experimental safe gap (MESG).....	9
4.3 Classification according to the minimum igniting current ratio (MIC ratio).....	10
4.4 Classification according to the similarity of chemical structure	10
4.5 Classification of mixtures of gases	10
5 Data for flammable gases and vapours, relating to the use of equipment.....	11
5.1 Determination of the properties	11
5.1.1 General	11
5.1.2 Equipment group	11
5.1.3 Flammable limits.....	11
5.1.4 Flash point (FP).....	11
5.1.5 Temperature class	12
5.1.6 Minimum igniting current (MIC).....	12
5.1.7 Auto-ignition temperature (AIT).....	12
5.2 Properties of particular gases and vapours	12
5.2.1 Coke oven gas.....	12
5.2.2 Ethyl nitrite	12
5.2.3 MESG of carbon monoxide	12
5.2.4 Methane, Equipment Group IIA.....	13
6 Method of test for the maximum experimental safe gap (MESG).....	13
6.1 Outline of method	13
6.2 Test apparatus.....	13
6.2.1 General	13
6.2.2 Material and mechanical strength	14
6.2.3 Exterior chamber	14
6.2.4 Interior chamber	14
6.2.5 Gap adjustment	14
6.2.6 Injection of mixture	14
6.2.7 Position of ignition source.....	14
6.3 Procedure	14
6.3.1 Preparation of gas mixtures	14
6.3.2 Temperature and pressure.....	14
6.3.3 Gap adjustment	15
6.3.4 Ignition	15
6.3.5 Observation of the ignition process.....	15
6.4 Determination of maximum experimental safe gap (MESG).....	15
6.4.1 General	15
6.4.2 Preliminary tests.....	15
6.4.3 Confirmatory tests	15
6.4.4 Reproducibility of maximum experimental safe gaps (MESG).....	15
6.4.5 Tabulated values	16

6.5	Verification of the MESH determination method	16
7	Method of test for auto-ignition temperature (AIT).....	16
7.1	Outline of method	16
7.2	Apparatus	16
7.2.1	General	16
7.2.2	Test vessel and support.....	17
7.2.3	Thermocouples	17
7.2.4	Oven	17
7.2.5	Metering devices	18
7.2.6	Mirror	18
7.2.7	Timer	18
7.2.8	Equipment for purging the test vessel with air	18
7.2.9	Automated apparatus.....	18
7.3	Sampling, preparation and preservation of test samples	19
7.3.1	Sampling	19
7.3.2	Preparation and preservation.....	19
7.4	Procedure	19
7.4.1	General	19
7.4.2	Sample injection	20
7.4.3	Determination of the auto-ignition temperature (AIT).....	20
7.5	Auto-ignition temperature (AIT)	21
7.6	Validity of results	21
7.6.1	Repeatability	21
7.6.2	Reproducibility.....	21
7.7	Data.....	22
7.8	Verification of the auto-ignition temperature determination method	22
Annex A (normative)	Ovens of test apparatus for the tests of auto-ignition temperature	23
A.1	General.....	23
A.2	“IEC oven”	23
A.3	“DIN oven”	23
Annex B (informative)	Tabulated values	30
Annex C (informative)	Determination of cool flames	84
Annex D (informative)	Volume dependence of auto-ignition temperature.....	86
Bibliography.....		87
Figure 1	– Test apparatus	13
Figure A.1	– Test apparatus: assembly	24
Figure A.2	– Section A-A (flask omitted)	25
Figure A.3	– Base heater (board made of refractory material)	25
Figure A.4	– Flask guide ring (board made of refractory material)	26
Figure A.5	– Neck heater (board made of refractory material)	26
Figure A.6	– Oven.....	27
Figure A.7	– Lid of steel cylinder.....	28
Figure A.8	– Lid of steel cylinder.....	29
Figure A.9	– Injection of gaseous sample.....	29
Figure C.1	– Additional thermocouple to detect cool flames	84

Figure C.2 – ‘Negative temperature coefficient’ shown for butyl butyrate as an example 85

Figure D.1 – Volume dependence of auto-ignition temperature 86

Table 1 – Classification of temperature class and range of auto-ignition temperatures..... 12

Table 2 – Values for verification of the apparatus 16

Table 3 – Values for verification of the apparatus 22

Table B.1 – Material data..... 32

INTERNATIONAL ELECTROTECHNICAL COMMISSION

EXPLOSIVE ATMOSPHERES –**Part 20-1: Material characteristics for gas and vapour classification –
Test methods and data**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard ISO/IEC 80079-20-1 has been prepared by subcommittee 31M: Non-electrical equipment and protective systems for explosive atmospheres, of IEC technical committee 31: Equipment for explosive atmospheres.

This first edition of ISO/IEC 80079-20-1 cancels and replaces IEC 60079-20-1:2010. It constitutes a technical revision. No significant changes were made with respect to IEC 60079-20-1:2010.

It is published as a double logo standard.

The text of this standard is based on the following documents:

FDIS	Report on voting
31M/122/FDIS	31M/126/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 60079 series, under the general title: *Explosive atmospheres*, as well as the International Standard 80079 series, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

EXPLOSIVE ATMOSPHERES –

Part 20-1: Material characteristics for gas and vapour classification – Test methods and data

1 Scope

This part of ISO/IEC 80079 provides guidance on classification of gases and vapours. It describes a test method intended for the measurement of the maximum experimental safe gaps (MESG) for gas-air mixtures or vapour-air mixtures under normal conditions of temperature and pressure (20 °C, 101,3 kPa) so as to permit the selection of an appropriate group of equipment. This document also describes a test method intended for use in the determination of the auto-ignition temperature (AIT) of a vapour-air mixture or gas-air mixture at atmospheric pressure, so as to permit the selection of an appropriate temperature class of equipment.

Values of chemical properties of materials are provided to assist in the selection of equipment to be used in hazardous areas. Further data may be added as the results of validated tests become available.

The materials and the characteristics included in a table (see Annex B) have been selected with particular reference to the use of equipment in hazardous areas. The data in this document have been taken from a number of references which are given in the bibliography.

These methods for determining the MESG or the AIT may also be used for gas-air-inert mixtures or vapour-air-inert mixtures. However, data on air-inert mixtures are not tabulated.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60050-426, *International Electrotechnical Vocabulary – Part 426: Electrical apparatus for explosive atmospheres* (available at <http://www.electropedia.org/>)

IEC 60079-11, *Explosive atmospheres – Part 11: Equipment protection by intrinsic safety "i"*

IEC 60079-14, *Explosive atmospheres – Part 14: Electrical installations design, selection and erection*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in IEC 60050-426 and the following apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <http://www.iso.org/obp>