

Australian/New Zealand Standard™

**Utility-interconnected photovoltaic
inverters — Test procedure of islanding
prevention measures**



AS/NZS IEC 62116:2020

This Joint Australian/New Zealand Standard™ was prepared by Joint Technical Committee EL-042, Renewable Energy Power Supply Systems and Equipment. It was approved on behalf of the Council of Standards Australia on 24 March 2020 and by the New Zealand Standards Approval Board on 4 March 2020.

This Standard was published on 3 April 2020.

The following are represented on Committee EL-042:

Australasian Fire and Emergency Service Authorities Council
Australian Energy Council
Australian Energy Market Operator
Australian Industry Group
Australian PV Institute
Clean Energy Council, Australia
Clean Energy Regulator, Australia
Communications, Electrical and Plumbing Union — Electrical Division, Australia
Consumer Electronics Suppliers Association, Australia
Consumers' Federation of Australia
CSIRO
Electrical Compliance Testing Association of Australia
Electrical Regulatory Authorities Council, Australia
Electrical Safety New Zealand
Electricity Engineers Association of New Zealand
Energy Efficiency and Conservation Authority, New Zealand
Energy Networks Australia
Engineers Australia
Institute of Electrical and Electronics Engineers, Australia
Institute of Electrical Inspectors, Australia
Joint Accreditation System of Australia and New Zealand
Master Electricians Australia
National Electrical and Communications Association, Australia
NSW FairTrading
Office of the Technical Regulator, SA
Smart Energy Council, Australia
Solar Energy Industries Association, Australia
Sustainable Electricity Association New Zealand
Sustainable Energy Association of Australia
University of New South Wales
Wellington Electrical Association
WorkSafe New Zealand

This Standard was issued in draft form for comment as DR AS/NZS IEC 62116:2019.

Keeping Standards up-to-date

Ensure you have the latest versions of our publications and keep up-to-date about Amendments, Rulings, Withdrawals, and new projects by visiting:

www.standards.org.au

www.standards.govt.nz

ISBN 978 1 76072 799 4

Australian/New Zealand Standard™

**Utility-interconnected photovoltaic
inverters — Test procedure of islanding
prevention measures**

First published as AS/NZS IEC 62116:2020.

COPYRIGHT

© IEC 2020 — All rights reserved

© Standards Australia Limited/the Crown in right of New Zealand, administered by the New Zealand Standards Executive 2020

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher, unless otherwise permitted under the Copyright Act 1968 (Cth) or the Copyright Act 1994 (New Zealand).

Preface

This Standard was prepared by the Joint Standards Australia/Standards New Zealand Committee EL-042, Renewable Energy Power Supply Systems and Equipment.

The objective of this Standard is to provide a test procedure to evaluate the performance of islanding prevention measures used with utility-interconnected PV systems.

This Standard describes a guideline for testing the performance of automatic islanding prevention measures installed in or with single or multi-phase utility interactive PV inverters connected to the utility grid.

This Standard is identical with, and has been reproduced from, IEC 62116:2014, *Utility-interconnected photovoltaic inverters — Test procedure of islanding prevention measures*.

As this document has been reproduced from an International Standard, the following applies:

- (a) In the source text “this International Standard” should read “this Australian/New Zealand Standard”.
- (b) A full point substitutes for a comma when referring to a decimal marker.

Australian or Australian/New Zealand Standards that are identical adoptions of international normative references may be used interchangeably. Refer to the online catalogue for information on specific Standards.

The terms “normative” and “informative” are used in Standards to define the application of the appendices or annexes to which they apply. A “normative” appendix or annex is an integral part of a Standard, whereas an “informative” appendix or annex is only for information and guidance.

NOTES

CONTENTS

FOREWORD.....	4
INTRODUCTION.....	6
1 Scope.....	7
2 Normative references	7
3 Terms and definitions	7
4 Testing circuit.....	9
5 Testing equipment.....	11
5.1 Measuring instruments.....	11
5.2 DC power source	11
5.2.1 General	11
5.2.2 PV array simulator.....	12
5.2.3 Current and voltage limited DC power supply with series resistance.....	12
5.2.4 PV array	12
5.3 AC power source	13
5.4 AC loads.....	13
6 Test for single or multi-phase inverter.....	13
6.1 Test procedure.....	13
6.2 Pass/fail criteria	17
7 Documentation	17
Annex A (informative) Islanding as it applies to PV systems	20
A.1 General.....	20
A.2 Impact of distortion on islanding.....	21
Annex B (informative) Test for independent islanding detection device (relay)	22
B.1 General.....	22
B.2 Testing circuit	22
B.3 Testing equipment	22
B.3.1 General	22
B.3.2 AC input source.....	22
B.4 Testing procedure.....	23
B.5 Documentation.....	23
Annex C (informative) Gate blocking signal.....	24
C.1 General.....	24
C.2 Gate blocking signal used in photovoltaic systems.....	24
C.3 Monitoring the gate blocking signal	24
Bibliography.....	25
Figure 1 – Test circuit for islanding detection function in a power conditioner (inverter)	11
Figure B.1 – Test circuit for independent islanding detection device (relay)	22
Table 1 – Parameters to be measured in real time	10
Table 2 – Specification of array simulator (test conditions).....	12
Table 3 – PV array test conditions	13
Table 4 – AC power source requirements	13
Table 5 – Test conditions.....	14

Table 6 – Load imbalance (real, reactive load) for test condition A (EUT output = 100 %)	16
Table 7 – Load imbalance (reactive load) for test condition B (EUT output = 50 % to 66 %) and test condition C (EUT output = 25 % to 33 %)	16
Table 8 – Specification of the EUT provided by the manufacturer (example)	17
Table 9 – List of tested condition and run on time (example).....	18
Table 10 – Specification of testing equipment (example).....	19

INTERNATIONAL ELECTROTECHNICAL COMMISSION

UTILITY-INTERCONNECTED PHOTOVOLTAIC INVERTERS – TEST PROCEDURE OF ISLANDING PREVENTION MEASURES

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 62116 has been prepared by IEC technical committee 82: Solar photovoltaic energy systems.

This second edition cancels and replaces the first edition issued in 2008 and constitutes a technical revision.

The main technical changes with regard to the previous edition are as follows:

Previous edition		Present edition
Clause	Real power	Active power
3.7		
5.1		
5.4		
6.1 b)		
6.1 d)		
6.1 e)		
6.1 g)		
Table 1		
Table 6		
Table 7		
Table 9		
5.2	A PV array or PV array simulator (preferred) may be used. If the EUT can operate in utility-interconnected mode from a storage battery, a DC power source may be used in lieu of a battery as long as the DC power source is not the limiting device as far as the maximum EUT input current is concerned.	A DC power source, such as a PV array simulator, a PV array, or a current and voltage limited DC power supply with series resistance may be used. If the EUT can operate in utility-interconnected mode from a storage battery, a DC power source may be used in lieu of a battery as long as the DC power source shall not be the limiting device as far as the maximum EUT input current is concerned.
Table 5	EUT input voltage 90 %	EUT input voltage 75 %
	EUT input voltage 10 %	EUT input voltage 20 %
	EUT Trip Settings Manufacturer specified voltage and frequency trip settings	Voltage and frequency trip settings according to National standards and/or local code
Tables 6 & 7 (Heading)	Percent change in real load, reactive load from nominal	Percent change in active load, reactive load from nominal output power

The text of this standard is based on the following documents:

FDIS	Report on voting
82/813/FDIS	82/827/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

Islanding is a condition in which a portion of an electric power grid, containing both load and generation, is isolated from the remainder of the electric power grid. This situation is one which electric power providers (utilities) regularly contend with. When an island is created purposely by the controlling utility – to isolate large sections of the utility grid, for example – it is called an intentional island. Conversely, an unintentional island can be created when a segment of the utility grid containing only customer-owned generation and load is isolated from the utility control.

Normally, the customer-owned generation is required to sense the absence of utility-controlled generation and cease energizing the grid. However, when the generation and load within the segment are well balanced prior to the isolation event, the utility is providing little power to the grid segment, thus making it difficult to detect when the isolation occurs. Damage can occur to customer equipment if the generation in the island, no longer under utility control, operates outside of normal voltage and frequency conditions. Customer and utility equipment can be damaged if the main grid recloses into the island out of synchronization. Energized lines within the island present a shock hazard to unsuspecting utility lineworkers who think the lines are dead.

The PV industry has pioneered the development of islanding detection and prevention measures. To satisfy the concerns of electric power providers, commercially-available utility-interconnected PV inverters have implemented a variety of islanding detection and prevention (also called anti-islanding) techniques. The industry has also developed a test procedure to demonstrate the efficacy of these anti-islanding techniques; that procedure is the subject of this document.

This standard provides a consensus test procedure to evaluate the efficacy of islanding prevention measures used by the power conditioner of utility-interconnected PV systems. Note that while this document specifically addresses inverters for photovoltaic systems, with some modifications the setup and procedure may also be used to evaluate inverters used with other generation sources or to evaluate separate anti-islanding devices intended for use in conjunction with PV inverters or other generation sources acting as or supplementing the anti-islanding feature of those sources.

Inverters and other devices meeting the requirements of this document can be considered non-islanding, meaning that under reasonable conditions, the device will detect island conditions and cease to energize the public electric power grid.

UTILITY-INTERCONNECTED PHOTOVOLTAIC INVERTERS – TEST PROCEDURE OF ISLANDING PREVENTION MEASURES

1 Scope

The purpose of this International Standard is to provide a test procedure to evaluate the performance of islanding prevention measures used with utility-interconnected PV systems.

This standard describes a guideline for testing the performance of automatic islanding prevention measures installed in or with single or multi-phase utility interactive PV inverters connected to the utility grid. The test procedure and criteria described are minimum requirements that will allow repeatability. Additional requirements or more stringent criteria may be specified if demonstrable risk can be shown. Inverters and other devices meeting the requirements of this standard are considered non-islanding as defined in IEC 61727.

This standard may be applied to other types of utility-interconnected systems (e.g. inverter-based microturbine and fuel cells, induction and synchronous machines). However, technical review may be necessary for other than inverter-based PV systems.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC/TS 61836, *Solar photovoltaic energy systems – Terms, definitions and symbols*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in IEC 61836 as well as the following apply.

3.1

PV array simulator

DC power source used to simulate PV array output

3.2

EUT

equipment under test

inverter or anti-islanding device on which these tests are performed

Note 1 to entry: This note applies to the French language only.

3.3

MPPT

maximum power point tracking

PV array control strategy used to maximize the output of the system under the prevailing conditions

Note 1 to entry: This note applies to the French language only.