



CGA C-7—2020
GUIDE TO CLASSIFICATION
AND LABELING OF
COMPRESSED GASES

ELEVENTH EDITION
(Corrected 5/6/2020)

DEDICATION

This publication is dedicated in the memory of Kevin Paradis, who served as an active participant of the Committee that developed this publication.

PLEASE NOTE:

The information contained in this document was obtained from sources believed to be reliable and is based on technical information and experience currently available from members of the Compressed Gas Association, Inc. and others. However, the Association or its members, jointly or severally, make no guarantee of the results and assume no liability or responsibility in connection with the information or suggestions herein contained. Moreover, it should not be assumed that every acceptable commodity grade, test or safety procedure or method, precaution, equipment or device is contained within, or that abnormal or unusual circumstances may not warrant or suggest further requirements or additional procedure.

This document is subject to periodic review, and users are cautioned to obtain the latest edition. The Association invites comments and suggestions for consideration. In connection with such review, any such comments or suggestions will be fully reviewed by the Association after giving the party, upon request, a reasonable opportunity to be heard. Proposed changes may be submitted via the Internet at our website, www.cganet.com.

This document should not be confused with Federal, state, provincial, or municipal specifications or regulations; insurance requirements; or national safety codes. While the Association recommends reference to or use of this document by government agencies and others, this document is purely voluntary and not binding unless adopted by reference in regulations.

A listing of all publications, audiovisual programs, safety and technical bulletins, and safety posters is available via the Internet at our website at www.cganet.com. For more information contact CGA at Phone: 703-788-2700, ext. 799. E-mail: customerservice@cganet.com.

Work Item 20-001
Hazard Communication Committee

NOTE—Due to the extensive changes in this document, technical changes from the previous edition are not identified.

NOTE—Appendices A, B, C, D, E, F, G and H (Normative) are requirements.

ELEVENTH EDITION: 2020 (CORRECTED 5/6/2020)
TENTH EDITION: 2014
NINTH EDITION: 2011
EIGHTH EDITION: 2004

© 2020 The Compressed Gas Association, Inc. All rights reserved.

All materials contained in this work are protected by United States and international copyright laws. No part of this work may be reproduced or transmitted in any form or by any means, electronic or mechanical including photocopying, recording, or any information storage and retrieval system without permission in writing from The Compressed Gas Association, Inc. All requests for permission to reproduce material from this work should be directed to The Compressed Gas Association, Inc., 8484 Westpark Drive, Suite 220, McLean, VA 22102. You may not alter or remove any trademark, copyright or other notice from this work.

| Contents | Page |
|--|-------------|
| 1 Introduction..... | 1 |
| 2 Scope | 1 |
| 3 Responsibility | 2 |
| 4 Definitions..... | 2 |
| 5 Label and marking description | 5 |
| 5.1 U.S. Department of Transportation/Transport Canada..... | 5 |
| 5.2 U.S. Occupational Safety and Health Administration | 6 |
| 6 General principles | 8 |
| 6.1 Gas mixtures | 8 |
| 6.2 DOT-4L/TC-4LM liquid cylinders | 8 |
| 7 Specific requirements..... | 8 |
| 7.1 Label content for hazard communication | 8 |
| 7.2 Label content for transport | 10 |
| 7.3 Label content for medical applications | 10 |
| 7.4 Mixture classification | 10 |
| 8 Label diagrams and examples | 10 |
| 9 References | 38 |
| 10 Additional references..... | 38 |

Figures

| | |
|---|----|
| Figure 1—Inhalation hazard label | 6 |
| Figure 2—Cryogenic liquid label | 6 |
| Figure 3—Marine pollutant mark..... | 7 |
| Figure 4—GHS pictograms | 7 |
| Figure 5—Example of a cylinder shoulder label layout | 11 |
| Figure 6—Example of a cylinder sidewall label layout | 12 |
| Figure 7—Example of an Air, Compressed cylinder shoulder label..... | 13 |
| Figure 8—Example of an Acetylene, Dissolved cylinder sidewall label | 14 |
| Figure 9—Example of an Acetylene, Dissolved cylinder shoulder label | 15 |
| Figure 10—Example of an Acetylene, Dissolved cylinder shoulder label for transport and use within Canada | 16 |
| Figure 11—Example of an Ammonia, Anhydrous cylinder sidewall label for domestic transport and use..... | 17 |
| Figure 12—Example of an Ammonia, Anhydrous cylinder sidewall label for international transport and use | 18 |
| Figure 13—Example of an Argon, Compressed cylinder sidewall label..... | 19 |
| Figure 14—Example of an Argon, Refrigerated Liquid cylinder sidewall label..... | 20 |
| Figure 15—Example of a Carbon Dioxide cylinder sidewall label..... | 21 |
| Figure 16—Example of a Carbon Dioxide, Refrigerated Liquid cylinder sidewall label | 22 |
| Figure 17—Example of a Carbon Monoxide cylinder sidewall label | 23 |
| Figure 18—Example of a Chlorine cylinder sidewall label for domestic transport and use..... | 24 |
| Figure 19—Example of an Ethylene cylinder sidewall label..... | 25 |
| Figure 20—Example of a Helium cylinder sidewall label | 26 |
| Figure 21—Example of a Hydrogen cylinder sidewall label | 27 |
| Figure 22—Example of a Hydrogen Sulfide cylinder sidewall label for domestic transport and use | 28 |
| Figure 23—Example of a Nitrogen cylinder sidewall label | 29 |
| Figure 24—Example of a Nitrogen, Refrigerated Liquid cylinder sidewall label..... | 30 |
| Figure 25—Example of a Nitrous Oxide cylinder sidewall label..... | 31 |
| Figure 26—Example of a Nitrous Oxide, Refrigerated Liquid cylinder sidewall label | 32 |
| Figure 27—Example of an Oxygen cylinder sidewall label for domestic transport and use..... | 33 |
| Figure 28—Example of an Oxygen cylinder shoulder label for transport and use within Canada | 34 |
| Figure 29—Example of an Oxygen, Refrigerated Liquid cylinder sidewall label for domestic transport and use..... | 35 |
| Figure 30—Example of a Propane cylinder sidewall label | 36 |
| Figure 31—Example of a Propylene cylinder sidewall label | 37 |

Table

| | |
|---|---|
| Table 1—Examples of hazard statements and their associated signal words | 9 |
|---|---|

Appendices

| | |
|---|-----|
| Appendix A—CGA marking system for compressed gas cylinders (Normative)..... | 40 |
| Appendix B—CGA labeling guide for compressed medical gases classified as drugs (Normative)..... | 47 |
| Appendix C—CGA labeling guide for compressed medical gases classified as medical devices or used with medical devices (Normative)..... | 59 |
| Appendix D—Pure product classifications (Normative) | 63 |
| Appendix E—Gaseous mixture classification decision tree (Normative) | 100 |
| Appendix F—Guide for use of 360 degree wrap around product identification for DOT-4L/TC-4LM and similar cylinders (Normative)..... | 117 |
| Appendix G—Hazard and precautionary statements and codes (Normative) | 119 |
| Appendix H—CGA-recommended hazard and precautionary statements and rules for their use (Normative)..... | 129 |

Appendices figures

| | |
|---|-----|
| Figure A-1—Basic markings | 42 |
| Figure A-2—Basic markings for multiple hazard diamonds (overlapped)..... | 43 |
| Figure A-3—Example of CGA marking system for multiple hazard diamonds (overlapped) | 43 |
| Figure A-4—Basic markings for multiple hazard diamonds (truncated)..... | 44 |
| Figure A-5—Examples of CGA marking system | 45 |
| Figure A-6—Examples of CGA marking system for U.S. domestic shipment of oxygen and ammonia as described in A.4 (not to scale)..... | 46 |
| Figure B-1—Example of a small ownership sticker..... | 48 |
| Figure B-2—Example of a separate sticker containing supplementary information..... | 48 |
| Figure B-3—Example of an Oxygen, Compressed USP cylinder sidewall label..... | 49 |
| Figure B-4—Example of an Oxygen, Refrigerated Liquid USP cylinder sidewall label..... | 50 |
| Figure B-5—Example of a Carbon Dioxide USP cylinder sidewall label..... | 51 |
| Figure B-6—Example of a Helium, Compressed USP cylinder sidewall label | 52 |
| Figure B-7—Example of a Nitrous Oxide USP cylinder sidewall label..... | 53 |
| Figure B-8—Example of a Nitrogen, Compressed NF cylinder sidewall label | 54 |
| Figure B-9—Example of a Medical Air, USP cylinder sidewall label..... | 55 |
| Figure E-1—Determination of physical state of mixtures | 100 |
| Figure E-2—Determination of flammability or oxidizing classification of mixtures | 101 |
| Figure E-3—Determination of pyrophoricity classification of mixtures | 102 |
| Figure E-4—Determination of inhalation toxicity classification of mixtures | 103 |
| Figure E-5—Determination of skin corrosion/irritation classification of mixtures ¹⁴⁾ | 104 |
| Figure E-6—Determination of eye damage/irritation classification of mixtures ¹⁹⁾ | 105 |
| Figure E-7—Determination of respiratory and skin sensitization classification of mixtures | 106 |
| Figure E-8—Determination of germ cell mutagenicity and carcinogenicity classifications of mixtures | 107 |
| Figure E-9—Determination of reproductive toxicity classifications of mixtures..... | 108 |
| Figure E-10—Determination of Specific Target Organ Toxicity (STOT) Single Exposure (SE) and Repeated Exposure (RE) classifications of mixtures | 109 |
| Figure E-11—Determination of Simple Asphyxiant classification of mixtures..... | 110 |
| Figure E-12—Determination of aquatic toxicity classification of mixtures ²⁵⁾ | 111 |
| Figure E-13—Determination of hazards to the ozone layer of mixtures | 112 |
| Figure E-14—Determination of gas-specific statements for mixtures (Part 1)..... | 113 |
| Figure E-15—Determination of gas-specific statements for mixtures (Part 2)..... | 114 |
| Figure E-16—Determination of medical drug gas mixtures | 115 |
| Figure E-17—Determination of medical device gas mixtures | 116 |
| Figure F-1—Example of industrial cryogenic identification | 117 |

Appendices tables

| | |
|---|-----|
| Table F-1—Color coding for portable cryogenic medical gas containers..... | 118 |
| Table G-1—Hazard statement codes and associated label elements | 119 |
| Table G-2—Precautionary statement codes and text | 126 |
| Table H-1—Hazard statement codes, text, and rules for use | 129 |
| Table H-2—Precautionary statement codes, text, and rules for use..... | 130 |

1 Introduction

The compressed gas industry has developed precautionary labels and markings for use on containers of compressed gases, cryogenic liquids, and other hazardous materials for the purpose of identifying the contents, warning of principal physical, health, and environmental hazards, and providing appropriate precautionary information following the *Globally Harmonized System of Classification and Labelling of Chemicals* (GHS) as allowed by the U.S. Occupational Safety and Health Administration (OSHA) [1].¹

GHS was established by the United Nations (UN) to develop a means of hazard classification and communication via labels, pictograms, and consistent hazard language on a global basis. Internationally, competent authorities may adopt the GHS in whole or in part and may also require additional information on labels.

2 Scope

The Compressed Gas Association (CGA) has prepared this publication to state the general principles for labels and markings and give recommended minimum requirements for many hazardous gases and selected liquids. Additional information may be shown by gas suppliers if desired.

The methods of preparing label information established by GHS as required by Title 29 of the U.S. *Code of Federal Regulations* (29 CFR) Part 1910.1200 (OSHA's Hazard Communication Standard) have been followed to meet the specific labeling and marking needs of the compressed gas industry [1, 2]. OSHA's Hazard Communication Standard and the currently referenced edition of GHS shall be used in conjunction with this publication when classifying products and creating labels [2, 1].

This publication is not intended to address state, provincial, territorial, or local regulatory label and marking requirements such as the "Proposition 65" warnings required by the state of California. This publication does not fully address the requirements of the Canadian Hazardous Product Regulations-Workplace Hazardous Materials Information System 2015 (WHMIS 2015), which has adopted the Fifth Revised Edition of GHS [3]. The example labels in this guideline for Canadian transport comply with WHMIS 2015 [3].

Labels shall be applied to compressed gas and cryogenic liquid containers to identify the container contents and to warn of principal physical and health hazards associated with the container and its contents. Containers in transportation not exceeding 454 kg (1000 lb) water capacity require the U.S. Department of Transportation (DOT) and Transport Canada (TC) hazard label.

Labels as given herein with regard to cylinder handling and storage information may be modified with respect to format so they can be applied as required to fixed storage vessels, portable tanks, tube trailers, cargo tanks, or other packaging.

Labels shown in this publication are examples of labels and markings that warn of principal physical and health hazards involved in the handling and use of these specific products. The words label or labeling as used in this publication include labels, markings, decals, tags, stenciling, and similar methods of presenting precautionary information.

Appendix A illustrates the basic marking consisting of DOT or TC proper shipping name; identification number; and 30-mm (1.25-in) diamond, which is permitted under conditions authorized by DOT and TC regulations as an alternative to the DOT/TC 100-mm (3.9-in) diamond label and marking [4, 5].

Appendices B, C, and portions of F provide additional labeling and marking information to aid in complying with applicable regulations of the U.S. Food and Drug Administration (FDA) for the labeling of medical gases, including mixtures, that are classified as drugs and medical devices.

Appendix D includes the GHS classifications and codes for corresponding hazard and precautionary statements, signal word, and GHS pictograms for the pure gases listed in this publication. This Appendix also contains DOT's transportation classifications and CGA-developed hazard and precautionary statements.

¹ References are shown by bracketed numbers and are listed in the order of appearance in the reference section.