



BSI Standards Publication

High-voltage switchgear and controlgear

Part 312: Guidance for the transferability of type tests of high-voltage/low-voltage prefabricated substations

National foreword

This Published Document is the UK implementation of IEC TR 62271-312:2021.

The UK participation in its preparation was entrusted to Technical Committee PEL/17, High voltage switchgear, controlgear and assemblies.

A list of organizations represented on this committee can be obtained on request to its secretary.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

© The British Standards Institution 2021
Published by BSI Standards Limited 2021

ISBN 978 0 539 04035 7

ICS 29.130.10

Compliance with a British Standard cannot confer immunity from legal obligations.

This Published Document was published under the authority of the Standards Policy and Strategy Committee on 31 January 2021.

Amendments/corrigenda issued since publication

Date	Text affected
------	---------------



TECHNICAL REPORT



High-voltage switchgear and controlgear – Part 312: Guidance for the transferability of type tests of high-voltage/ low-voltage prefabricated substations

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 29.130.10

ISBN 978-2-8322-9228-0

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD.....	6
1 Scope.....	8
2 Normative references	8
3 Terms and definitions	9
4 Use of transferability criteria.....	11
4.1 General.....	11
4.2 Design parameters for transferability criteria.....	12
4.3 Use of calculations.....	12
4.3.1 General	12
4.3.2 Temperature rise calculations.....	13
4.3.3 Electric field calculations	13
4.3.4 Electromagnetic field calculations.....	13
4.3.5 Mechanical stress calculations.....	13
4.3.6 Short-circuit current calculations.....	13
4.3.7 Internal arc calculations.....	14
4.4 Information needed for transferability of type test results	14
5 Application of transferability criteria.....	15
5.1 General.....	15
5.2 Temperature rise tests	15
5.3 Dielectric tests	16
5.4 Electromagnetic field tests	17
5.5 Mechanical tests.....	19
5.6 Short-time withstand current and peak withstand current tests.....	21
5.7 Internal arc tests.....	22
6 Transferability of type test reports	24
6.1 General.....	24
6.2 Transferability of a type test report to another prefabricated substation (situation a)	24
6.3 Validation of a substation design by existing type test reports (situation b))	25
6.4 Validation of a design modification (situation c))	26
Annex A (informative) Rationale for the transferability criteria.....	27
A.1 General.....	27
A.2 Temperature rise	27
A.2.1 Layout and enclosure	27
A.2.2 Ventilation openings (items 2.1, 2.2, 2.3 and 2.4 of Table 2).....	30
A.2.3 Distances between ventilation openings and power transformer (items 3 and 5 of Table 2)	30
A.2.4 Clearance between low-voltage-switchgear and controlgear and the power transformer (item 4 of Table 2).....	32
A.2.5 Power transformer insulation type (item 6 of Table 2).....	32
A.2.6 Power transformer total losses (item 7 of Table 2).....	32
A.2.7 Current of the low-voltage circuit (items 8 and 9 of Table 2)	32
A.3 Dielectric	33
A.3.1 General	33
A.3.2 Clearances (items 2 and 3 of Table 3)	33
A.3.3 Insulating supports and material (items 4 and 5 of Table 3)	33
A.3.4 Live parts (items 6 and 7 of Table 3).....	33

A.4	Electromagnetic field	34
A.4.1	General	34
A.4.2	Substation layout and distance from components to external surfaces of the enclosure (items 1 and 2 of Table 4).....	34
A.4.3	Rated voltages (item 3 of Table 4).....	36
A.4.4	Rated normal currents (item 4 of Table 4).....	36
A.4.5	Rated frequency (item 5 of Table 4).....	37
A.4.6	Permeability and conductivity of the enclosure material(s) (items 6 and 12 of Table 4).....	37
A.4.7	Interconnections (items 7, 8 and 9 of Table 4)	38
A.4.8	Power transformer type of insulation (item 10 of Table 4)	39
A.4.9	Distance between main circuit phases of the low-voltage switchgear and controlgear (item 11 of Table 4).....	40
A.5	Mechanical stress	40
A.5.1	General	40
A.5.2	Common design parameters to be assessed for the key components.....	40
A.5.3	Considerations for different enclosure materials, fasteners and reinforcements (items 1, 2, 3 and 4 of Table 5).....	42
A.6	Short-time withstand current and peak withstand current	43
A.6.1	General	43
A.6.2	Rated short-time and peak currents (items 1 and 2 of Table 6)	43
A.6.3	Rated duration of short-circuit (item 3 of Table 6)	43
A.6.4	Centre distance between phase conductors (item 4 of Table 6)	43
A.6.5	Conductors (items 5, 9 and 11 of Table 6)	43
A.6.6	Insulating conductor supports (items 6, 7 and 8 of Table 6)	44
A.6.7	Type of high-voltage and low-voltage terminations (item 10 of Table 6)	44
A.6.8	Temperature class of insulating material in contact with conductors (item 12 of Table 6)	44
A.7	Internal arc	44
A.7.1	General	44
A.7.2	Rated arc fault current, arc fault peak current and arc fault duration (items 1 and 2 of Table 7).....	45
A.7.3	High-voltage switchgear family (item 3 of Table 7).....	45
A.7.4	Layout of the prefabricated substation (item 4 of Table 7).....	46
A.7.5	Expansion volumes (items 5, 6 and 7 of Table 7).....	46
A.7.6	Cross-section of ventilation openings (item 8 of Table 7)	51
A.7.7	Design, position, cross-section of the cooling device(s) and gas flow (item 9 of Table 7)	51
A.7.8	Distances between high-voltage switchgear and controlgear assembly and the prefabricated substation enclosure (walls and roof) (item 10 of Table 7).....	53
A.7.9	Mechanical strength of the enclosure (item 11 of Table 7)	54
A.7.10	The shortest path length of hot gases in the last compartment to the closest ventilation opening before leaving the substation (item 12 of Table 7).....	54
A.7.11	Type of high-voltage interconnection and electrical protection of the circuit (items 13 and 14 of Table 7).....	54
Annex B (informative)	Collection of design parameters for the assessment of transferability of type test results	56
B.1	General.....	56
B.2	Information needed for the assessment of the temperature-rise test	56
B.3	Information needed for the assessment of the dielectric test	57

B.4	Information needed for the assessment of the electromagnetic field test.....	58
B.5	Information needed for the assessment of the mechanical stress test	59
B.6	Information needed for the assessment of the short-circuit current test.....	59
B.7	Information needed for the assessment of the internal arc test.....	60
	Bibliography.....	61
	Figure 1 – Transferability of one type test report	25
	Figure 2 – Validation of a prefabricated substation by existing test reports	26
	Figure A.1 – Different examples of non-walk-in type-tested prefabricated substation and related prefabricated substation under consideration	28
	Figure A.2 – Different examples of walk-in type-tested prefabricated substation and related prefabricated substation under consideration	29
	Figure A.3 – Types of ventilation opening designs	30
	Figure A.4 – Distance from air inlet and air outlet ventilation openings.....	31
	Figure A.5 – Difference in height between power transformer and air outlet ventilation openings.....	31
	Figure A.6 – Clearance between low-voltage-switchgear and controlgear and the power transformer.....	32
	Figure A.7 – Prefabricated substation not acceptable alternative layouts	35
	Figure A.8 – Distances from main components to external surfaces of the enclosure	36
	Figure A.9 – Frequency influence on magnetic field	37
	Figure A.10 – Magnetic field behaviour under shielded technologies.....	37
	Figure A.11 – Example of magnetic field for different distributions of phase currents in a three-phase interconnection having the same geometry and number of cables per phase	39
	Figure A.12 – Examples of different door designs	41
	Figure A.13 – Examples of different roof designs	41
	Figure A.14 – Different size of prefabricated substations with same layout	46
	Figure A.15 – Gas flow in a non-walk-in type and walk-in type prefabricated substations with separate high-voltage switchgear compartment.....	48
	Figure A.16 – Gas flow in a non-walk-in type and walk-in type prefabricated substations without separate high-voltage switchgear compartment.....	48
	Figure A.17 – Gas flow in a walk-in type prefabricated substation with high-voltage switchgear compartment without gas flow cooling device	49
	Figure A.18 – Gas flow in a walk-in type prefabricated substation with high-voltage switchgear compartment and high-voltage switchgear and controlgear with integrated gas flow cooling device	49
	Figure A.19 – Gas flow in a walk-in type prefabricated substation and high-voltage switchgear and controlgear with integrated gas flow cooling device without separate high-voltage switchgear compartment	50
	Figure A.20 – Transferability according to volume-criteria items 5, 6 and 7 of Table 7	51
	Figure A.21 – Layers with different transmittance for a multi-layer gas flow cooling device.....	52
	Figure A.22 – Top view of a prefabricated substation design with different gas flow cooling device arrangements	53
	Figure A.23 – Top view of one basic substation design with different positions of high- voltage switchgear and controlgear within the high-voltage switchgear compartment	53
	Figure A.24 – Prefabricated substations with different length of hot gases flow path with regard to ventilation openings.....	54

Table 1 – Examples of design parameters.....	12
Table 2 – Transferability criteria for temperature rise performance.....	15
Table 3 – Transferability criteria for dielectric withstand performance	17
Table 4 – Transferability criteria for electromagnetic field performance	18
Table 5 – Transferability criteria for the mechanical strength of the enclosure.....	19
Table 6 – Transferability criteria for short-time and peak withstand current performance.....	21
Table 7 – Transferability criteria for internal arc fault withstand performance	23
Table A.1 – Material thermal conductivity.....	29
Table B.1 – Information needed for the assessment of temperature-rise test	56
Table B.2 – Information needed for the assessment of dielectric test	58
Table B.3 – Information needed for the assessment of electromagnetic field test	58
Table B.4 – Information needed for the assessment of mechanical test.....	59
Table B.5 – Information needed for the assessment of short-circuit current test	60
Table B.6 – Information needed for the assessment of internal arc test.....	60

INTERNATIONAL ELECTROTECHNICAL COMMISSION

HIGH-VOLTAGE SWITCHGEAR AND CONTROLGEAR –**Part 312: Guidance for the transferability of type tests of high-voltage/low-voltage prefabricated substations**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

The main task of IEC technical committees is to prepare International Standards. However, a technical committee may propose the publication of a Technical Report when it has collected data of a different kind from that which is normally published as an International Standard, for example "state of the art".

IEC TR 62271-312, which is a Technical Report, has been prepared by subcommittee 17C: Assemblies, of IEC technical committee 17: High-voltage switchgear and controlgear.

The text of this Technical Report is based on the following documents:

Draft TR	Report on voting
17C/737/DTR	17C/753B/RVDTR

Full information on the voting for the approval of this Technical Report can be found in the report on voting indicated in the above table.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 62271 series, published under the general title *High-voltage switchgear and controlgear*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

HIGH-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

Part 312: Guidance for the transferability of type tests of high-voltage/low-voltage prefabricated substations

1 Scope

This document refers to high-voltage / low-voltage prefabricated substations (hereinafter prefabricated substations) as specified in IEC 62271-202:2014.

This document, among other options as agreed between manufacturer and user, can be used for the transferability of type tests performed on one or more prefabricated substations with a defined set of ratings and arrangement of components to another prefabricated substation with a different set of ratings or different arrangement of components. It supports the selection of appropriate representative test objects for that purpose in order to optimize the type testing procedure for a consistent conformity assessment.

This document utilises a combination of sound technical and physical principles, manufacturer and user experience and mutually agreed upon methods of calculation to establish pragmatic guidance for the transferability of type test results, covering various design and rating aspects.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60050-441:1984, *International Electrotechnical Vocabulary (IEV) – Part 441: Switchgear, controlgear and fuses*
IEC 60050-441:1984/AMD1:2000

IEC 60076-1:2011, *Power transformers – Part 1: General*

IEC 60076-2, *Power transformers – Part 2: Temperature rise for liquid-immersed transformers*

IEC 60076-7, *Power transformers – Part 7: Loading guide for mineral-oil-immersed power transformers*

IEC 60076-11, *Power transformers – Part 11: Dry-type transformers*

IEC 60076-12, *Power transformers – Part 12: Loading guide for dry-type power transformers*

IEC 60282-1:2020, *High-voltage fuses – Part 1: Current-limiting fuses*

IEC 61439-1:2020, *Low-voltage switchgear and controlgear assemblies – Part 1: General rules*

IEC 62271-1:2017, *High-voltage switchgear and controlgear – Part 1: Common specifications for alternating current switchgear and controlgear*

IEC 62271-200:2011, *High-voltage switchgear and controlgear – Part 200: AC metal-enclosed switchgear and controlgear for rated voltages above 1 kV and up to and including 52 kV*