

FINAL VERSION

VERSION FINALE

**Industrial communication networks – Fieldbus specifications –
Part 3-2: Data-link layer service definition – Type 2 elements**

**Réseaux de communication industriels – Spécifications des bus de terrain –
Partie 3-2: Définition des services de la couche liaison de données – Eléments
de type 2**



CONTENTS

FOREWORD.....	4
INTRODUCTION.....	6
INTRODUCTION to the Amendment	6
1 Scope.....	7
1.1 General.....	7
1.2 Specifications	7
1.3 Conformance	7
2 Normative references	8
3 Terms, definitions, symbols, abbreviations and conventions	8
3.1 Reference model terms and definitions	8
3.2 Service convention terms and definitions	10
3.3 Common data-link service terms and definitions	11
3.4 Additional Type 2 data-link specific definitions	13
3.5 Common symbols and abbreviations	15
3.6 Additional Type 2 symbols and abbreviations.....	16
3.7 Common conventions.....	16
4 Connection-mode and connectionless-mode data-link service	17
4.1 Overview	17
4.2 Facilities of the data-link service	21
4.3 Model of the data-link service	22
4.4 Sequence of primitives.....	24
4.5 Connection-mode data transfer	26
4.6 Connectionless-mode data transfer.....	28
4.7 Queue maintenance	31
4.8 Tag filter	33
5 DL-management services	34
5.1 Sequence of primitives.....	34
5.2 Link synchronization	35
5.3 Synchronized parameter change.....	36
5.4 Event reports	38
5.5 Bad FCS	40
5.6 Current moderator	40
5.7 Enable moderator	41
5.8 Power-up and online	42
5.9 Listen only	43
5.10 Time distribution	44
Bibliography.....	46
Figure 1 – Relationships of DLSAPs, DLSAP-addresses and group DL-addresses	12
Figure 2 – NUT structure	18
Figure 3 – Medium access during scheduled time	19
Figure 4 – Medium access during unscheduled time	20
Figure 5 – Queue model for the peer and multipoint DLS, DLSAPs and their DLCEPs	21
Figure 6 – Queue model of a multipoint DLS between a sending DLS-user and one or more receiving DLS-users.....	23

Figure 7 – DLS primitive time-sequence diagram	25
Figure 8 – State transition diagram for sequences of DLS primitives at one DLSAP	26
Figure 9 – Sequence of primitives for a successful connection-mode transfer	28
Figure 10 – Sequence of primitives for an unsuccessful connection-mode transfer	28
Figure 11 – Sequence of primitives for a successful connectionless-mode transfer	31
Figure 12 – Sequence of primitives for an unsuccessful connectionless-mode transfer	31
Figure 13 – Sequence of primitives for a queue maintenance request	33
Figure 14 – Sequence of primitives for a tag filter request	34
Figure 15 – Sequence of primitives for a local link synchronization	36
Figure 16 – Sequence of primitives for a DLM-get/set parameters request	38
Figure 17 – Sequence of primitives for a DLM-tMinus change request	38
Figure 18 – Sequence of primitives for a DLM-event indication	40
Figure 19 – Sequence of primitives for a DLM-bad-FCS indication	40
Figure 20 – Sequence of primitives for a DLM-current-moderator indication	41
Figure 21 – Sequence of primitives for a DLM-enable-moderator request	42
Figure 22 – Sequence of primitives for a DLM-power-up indication	43
Figure 23 – Sequence of primitives for a DLM-online request	43
Figure 24 – Sequence of primitives for a DLM-listen-only request	43
Table 1 – Summary of connection-mode and connectionless-mode primitives and parameters	25
Table 2 – DL-connection-mode transfer primitives and parameters	27
Table 3 – DL-connectionless-mode transfer primitives and parameters	29
Table 4 – Fixed tag services available to the DLS-user	30
Table 5 – DL-queue maintenance primitives and parameters	32
Table 6 – DL-connectionless-mode tag filter primitives and parameters	33
Table 7 – Summary of DL-management primitives and parameters	35
Table 8 – Link synchronization primitives and parameters	36
Table 9 – Synchronized parameter change primitives and parameters	37
Table 10 – DLMS-configuration-data	37
Table 11 – Event report primitives and parameters	39
Table 12 – DLMS events being reported	39
Table 13 – Bad FCS primitives and parameters	40
Table 14 – Current moderator primitives and parameters	41
Table 15 – Enable moderator primitives and parameters	41
Table 16 – Power-up and online primitives and parameters	42
Table 17 – Listen-only primitives and parameters	43
Table 18 – DLMS time and time quality parameters	44
Table 19 – Time distribution source quality	45

INTERNATIONAL ELECTROTECHNICAL COMMISSION

INDUSTRIAL COMMUNICATION NETWORKS – FIELDBUS SPECIFICATIONS –

Part 3-2: Data-link layer service definition – Type 2 elements

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

This consolidated version of the official IEC Standard and its amendment has been prepared for user convenience.

IEC 61158-3-2 edition 2.1 contains the second edition (2014-08) [documents 65C/759/FDIS and 65C/769/RVD] and its amendment 1 (2019-04) [documents 65C/945/FDIS and 65C/954/RVD].

This Final version does not show where the technical content is modified by amendment 1. A separate Redline version with all changes highlighted is available in this publication.

Attention is drawn to the fact that the use of the associated protocol type is restricted by its intellectual-property-right holders. In all cases, the commitment to limited release of intellectual-property-rights made by the holders of those rights permits a layer protocol type to be used with other layer protocols of the same type, or in other type combinations explicitly authorized by its intellectual-property-right holders.

NOTE Combinations of protocol types are specified in IEC 61784-1 and IEC 61784-2.

International Standard IEC 61158-3-2 has been prepared by subcommittee 65C: Industrial networks, of IEC technical committee 65: Industrial-process measurement, control and automation.

This second edition constitutes a technical revision.

The main changes with respect to the previous edition are listed below.

- Correction of references for fixed tag usage in 4.6.3.6.
- Update of core bibliographic references (original source documents from consortium).
- Miscellaneous editorial corrections.

This publication has been drafted in accordance with ISO/IEC Directives, Part 2.

A list of all the parts of the IEC 61158 series, under the general title *Industrial communication networks – Fieldbus specifications*, can be found on the IEC web site.

The committee has decided that the contents of the base publication and its amendment will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

This standard is one of a series produced to facilitate the interconnection of automation system components. It is related to other standards in the set as defined by the “three-layer” fieldbus reference model described in IEC 61158-1.

Throughout the set of fieldbus standards, the term “service” refers to the abstract capability provided by one layer of the OSI Basic Reference Model to the layer immediately above. Thus, the data-link layer service defined in this standard is a conceptual architectural service, independent of administrative and implementation divisions.

INTRODUCTION to the Amendment

Source documents referenced by this standard have been updated, this needs to be reflected in the corresponding sections of the document.

INDUSTRIAL COMMUNICATION NETWORKS – FIELDBUS SPECIFICATIONS –

Part 3-2: Data-link layer service definition – Type 2 elements

1 Scope

1.1 General

This part of IEC 61158 provides common elements for basic time-critical messaging communications between devices in an automation environment. The term “time-critical” is used to represent the presence of a time-window, within which one or more specified actions are required to be completed with some defined level of certainty. Failure to complete specified actions within the time window risks failure of the applications requesting the actions, with attendant risk to equipment, plant and possibly human life.

This standard defines in an abstract way the externally visible service provided by the Type 2 fieldbus data-link layer in terms of:

- a) the primitive actions and events of the service;
- b) the parameters associated with each primitive action and event, and the form which they take; and
- c) the interrelationship between these actions and events, and their valid sequences.

The purpose of this standard is to define the services provided to:

- the Type 2 fieldbus application layer at the boundary between the application and data-link layers of the fieldbus reference model;
- systems management at the boundary between the data-link layer and systems management of the fieldbus reference model.

Type 2 DL-service provides both a connected and a connectionless subset of those services specified in ISO/IEC 8886.

1.2 Specifications

The principal objective of this standard is to specify the characteristics of conceptual data-link layer services suitable for time-critical communications and thus supplement the OSI Basic Reference Model in guiding the development of data-link protocols for time-critical communications. A secondary objective is to provide migration paths from previously-existing industrial communications protocols.

This specification may be used as the basis for formal DL-Programming-Interfaces. Nevertheless, it is not a formal programming interface, and any such interface will need to address implementation issues not covered by this specification, including:

- a) the sizes and octet ordering of various multi-octet service parameters;
- b) the correlation of paired request and confirm, or indication and response, primitives.

1.3 Conformance

This standard does not specify individual implementations or products, nor does it constrain the implementations of data-link entities within industrial automation systems.