



CGA C-10—2019
GUIDELINE TO PREPARE
CYLINDERS AND TUBES FOR
GAS SERVICE AND
CHANGES IN GAS SERVICE

SIXTH EDITION

PLEASE NOTE:

The information contained in this document was obtained from sources believed to be reliable and is based on technical information and experience currently available from members of the Compressed Gas Association, Inc. and others. However, the Association or its members, jointly or severally, make no guarantee of the results and assume no liability or responsibility in connection with the information or suggestions herein contained. Moreover, it should not be assumed that every acceptable commodity grade, test or safety procedure or method, precaution, equipment or device is contained within, or that abnormal or unusual circumstances may not warrant or suggest further requirements or additional procedure.

This document is subject to periodic review, and users are cautioned to obtain the latest edition. The Association invites comments and suggestions for consideration. In connection with such review, any such comments or suggestions will be fully reviewed by the Association after giving the party, upon request, a reasonable opportunity to be heard. Proposed changes may be submitted via the Internet at our website, www.cganet.com.

This document should not be confused with federal, state, provincial, or municipal specifications or regulations; insurance requirements; or national safety codes. While the Association recommends reference to or use of this document by government agencies and others, this document is purely voluntary and not binding unless adopted by reference in regulations.

A listing of all publications, audiovisual programs, safety and technical bulletins, and safety posters is available via the Internet at our website at www.cganet.com. For more information contact CGA at Phone: 703-788-2700, ext. 799. E-mail: customerservice@cganet.com.

Work Item 17-048
Specialty Gases Committee

NOTE—Technical changes from the previous edition are underlined.

NOTE—Appendix A (Informative) is for information only.

SIXTH EDITION 2019
FIFTH EDITION: 2013
FOURTH EDITION: 2005
REAFFIRMED: 1999

© 2019 The Compressed Gas Association, Inc. All rights reserved.

All materials contained in this work are protected by United States and international copyright laws. No part of this work may be reproduced or transmitted in any form or by any means, electronic or mechanical including photocopying, recording, or any information storage and retrieval system without permission in writing from The Compressed Gas Association, Inc. All requests for permission to reproduce material from this work should be directed to The Compressed Gas Association, Inc., 8484 Westpark Drive, Suite 220, McLean, VA 22102. You may not alter or remove any trademark, copyright or other notice from this work.

Contents	Page
1 Introduction.....	1
2 Scope	1
2.1 Cylinders and tubes for which procedures apply.....	1
2.2 Application of recommended guidelines.....	2
2.3 Gas property categorization	2
2.4 Contaminant detection	2
2.5 Contaminant removal	2
3 Definitions.....	2
4 Guidelines to determine cylinders suitable for change of service	3
4.1 Cylinders authorized by federal regulations	3
4.2 Cylinders restricted to specific service	3
4.3 Gases that can affect cylinder condition.....	3
5 General guidelines for change of cylinder service and classification of gases.....	4
5.1 Qualifying cylinder, valve, and PRD for a gas service.....	4
5.2 Cylinder and valve preparation for gas service	5
5.3 Classification of gases.....	5
6 Recommended examinations according to category of service	6
6.1 General.....	6
6.2 Changes within and between specific categories.....	6
7 Operator requirements	8
7.1 General.....	8
7.2 Qualifying cylinders, valve, and PRD	8
7.3 Cylinder and valve preparation.....	8
8 Inspection and test procedures	8
8.1 General.....	8
8.2 External visual inspection	8
8.3 Odor test.....	8
8.4 Oil test	9
8.5 Internal visual inspection	9
9 Procedures for cleaning compressed gas cylinders.....	9
9.1 General.....	9
9.2 Cleaning restrictions	9
9.3 Identification of contaminants.....	9
9.4 Selection of cleaning agents	9
10 References	10
 Appendix	
Appendix A—Table of category 6 gases (Informative).....	12

This page is intentionally blank.

1 Introduction

This publication has been prepared as a guide to assist those persons establishing procedures for changing cylinders from one gas service to another. It is necessary that this guide is general in nature, although some specific recommendations are included, particularly regarding seamless steel and welded steel cylinders. It is assumed that persons using this publication are knowledgeable in the handling of compressed gases and familiar with the chemical and physical properties of the commodities they charge into cylinders and the contaminants that are likely to be found there. Cylinders that have been restricted to certain applications such as medical cylinders and have been filled with gases of a known quality may justifiably be processed in a manner other than those covered by these general recommendations.

It is occasionally desirable to change compressed gas cylinders from one gas service to another. Some of these service changes can be made easily. Others require a careful inspection of the interior and exterior of the cylinder to detect the presence of corrosion products or contaminants that shall be removed for safety reasons or to avoid undesirable contamination of the contained gas. Also, there are some compressed gas cylinders that shall be restricted to the service that they are in and not changed at all.

When cylinders are changed from one gas service to another, a thorough inspection of the cylinders shall be conducted. This inspection is done to accumulate information on how well the cylinder performed in its previous service, to ensure the cylinder is suitable for its proposed new gas service, and to determine the necessary action to be taken to prepare the cylinder for the change of service.

This publication does not attempt to identify each and every aspect of an inspection of the cylinder, valve, and pressure relief device (PRD), which is the responsibility of the party changing service.

2 Scope

2.1 Cylinders and tubes for which procedures apply

The cleaning recommendations contained in this publication are intended for cylinders of water capacities from 0.5 L to 454 L and tubes up to 3000 L that are fabricated in accordance with specifications promulgated by the U.S. Department of Transportation (DOT) in the United States and the Canadian Transport Commission (CTC) or Transport Canada (TC) in Canada and are authorized for reuse [1, 2, 3, 4].¹ Unless otherwise specified, when the word “cylinder” is used in this publication, it applies to both cylinders and tubes.

In general, the references made in this publication apply equally to DOT specifications and regulations in the United States and TC specifications and regulations in Canada [1, 2, 3, 4].

In the United States new cylinders are prefaced by “DOT” or “UN” and in Canada new cylinder specifications are prefaced by “TC” or “UN”. Older U.S. cylinders are prefaced by “ICC” and older Canadian cylinders are prefaced by “CTC”. Cylinders marked “CTC/DOT” or “TC/DOT” are authorized for service in both the United States and Canada. These procedures also apply to these older cylinder specifications.

These recommendations do not apply to:

- nonrefillable and composite cylinders;
- cylinders with internal linings, plating, or treatments; and
- cargo tanks, portable tanks, and tank cars.

These recommendations are not intended to address the requirements for cylinders in nonmedical gas service being changed to medical or food grade gas service except as required in CGA M-18, *Standard for the Change of Product and Change of Grade for High Pressure and Refrigerated Liquid Containers* [5].

¹ References are shown by bracketed numbers and are listed in order of appearance in the reference section.