

NEMA Standards Publication



ANSI C80.1-2020

American National Standard for Electrical Rigid Steel Conduit (ERSC)

National Electrical Manufacturers Association



National Electrical Manufacturers Association
1300 North 17th Street, Suite 900 • Rosslyn, VA 22209
www.NEMA.org





ANSI C80.1-2020

**Approved as an American National Standard
ANSI Approval Date: December 29, 2020**

*American National Standard for
Electrical Rigid Steel Conduit (ERSC)*

Secretariat:

National Electrical Manufacturers Association

Approved: December 29, 2020

American National Standards Institute, Inc.

NOTICE AND DISCLAIMER

The information in this publication was considered technically sound by the consensus of persons engaged in the development and approval of the document at the time it was developed. Consensus does not necessarily mean that there is unanimous agreement among every person participating in the development of this document.

NEMA Standards and guideline publications, of which the document contained herein is one, are developed through a voluntary consensus Standards development process. This process brings together volunteers and/or seeks out the views of persons who have an interest in the topic covered by this publication. While NEMA administers the process and establishes rules to promote fairness in the development of consensus, it does not write the document and it does not independently test, evaluate, or verify the accuracy or completeness of any information or the soundness of any judgments contained in its Standards and guideline publications.

NEMA disclaims liability for any personal injury, property, or other damages of any nature whatsoever, whether special, indirect, consequential, or compensatory, directly or indirectly resulting from the publication, use of, application, or reliance on this document. NEMA disclaims and makes no guaranty or warranty, express or implied, as to the accuracy or completeness of any information published herein, and disclaims and makes no warranty that the information in this document will fulfill any of your particular purposes or needs. NEMA does not undertake to guarantee the performance of any individual manufacturer or seller's products or services by virtue of this Standard or guide.

In publishing and making this document available, NEMA is not undertaking to render professional or other services for or on behalf of any person or entity, nor is NEMA undertaking to perform any duty owed by any person or entity to someone else. Anyone using this document should rely on his or her own independent judgment or, as appropriate, seek the advice of a competent professional in determining the exercise of reasonable care in any given circumstances. Information and other Standards on the topic covered by this publication may be available from other sources, which the user may wish to consult for additional views or information not covered by this publication.

NEMA has no power, nor does it undertake to police or enforce compliance with the contents of this document. NEMA does not certify, test, or inspect products, designs, or installations for safety or health purposes. Any certification or other statement of compliance with any health- or safety-related information in this document shall not be attributable to NEMA and is solely the responsibility of the certifier or maker of the statement.

AMERICAN NATIONAL STANDARD

Approval of an American National Standard requires verification by ANSI that the requirements for due process, consensus, and other criteria for approval have been met by the Standards developer.

Consensus is established when, in the judgment of the ANSI Board of Standards Review, substantial agreement has been reached by directly and materially affected interests. Substantial agreement means much more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered, and that a concerted effort be made toward their resolution.

The use of American National Standards is completely voluntary; their existence does not in any respect preclude anyone, whether he has approved the Standards or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the Standards.

The American National Standards Institute does not develop Standards and will in no circumstances give an interpretation of any American National Standard. Moreover, no person shall have the right or authority to issue an interpretation of an American National Standard in the name of the American National Standards Institute. Requests for interpretations should be addressed to the secretariat or sponsor whose name appears on the title page of this Standard.

Caution Notice: This American National Standard may be revised or withdrawn at any time. The procedures of the American National Standards Institute require that action be taken periodically to reaffirm, revise, or withdraw this Standard. Purchasers of American National Standards may receive current information on all Standards by calling or writing the American National Standards Institute, 25 West 43rd Street, 4th floor, New York, NY 10036, Tel: 212.642.4900.

Published by

**National Electrical Manufacturers Association
1300 North 17th Street, Rosslyn, VA 22209**

www.nema.org

© 2021 National Electrical Manufacturers Association. All rights reserved including translation into other languages, reserved under the Universal Copyright Convention, the Berne Convention for the Protection of Literary and Artistic Works, and the International and Pan American Copyright Conventions.

No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.

Printed in the United States of America

Foreword (This foreword is not part of American National Standard C80.1-2020)

This Standard was developed by the Accredited Standards Committee on Raceways for Electrical Wiring Systems, C80. The objective of the committee is to produce a comprehensive specification that will establish uniform dimensions and Standard construction requirements for Electrical Rigid Steel Conduit, Steel Electrical Metallic Tubing, Electrical Intermediate Metal Conduit, and Electrical Aluminum Rigid Conduit raceway products and their associated components.

This Standard was originally approved in 1950 and revised in 1953, 1959, 1963, 1966, 1977, 1983, 1990, 1994, 2004, 2005, and 2015.

Suggestions for improvement of this Standard are welcome. They should be sent to:

NEMA Technical Operations Director
National Electrical Manufacturers Association
1300 North 17th Street, Suite 900
Rosslyn, VA 22209

This Standard was processed and approved for submittal to ANSI by the Accredited Standards Committee (ASC C80), Raceways for Electrical Wiring Systems. Committee approval of the Standard does not necessarily imply that all committee Members voted for its approval. At the time it approved this Standard, the C80 Committee had the following Members:

J. Burris, Chairman

K. Shen, Secretary

Organization Represented:

ABB Inc.
Atkore International
Atkore International
Emerson Automation Solutions
IBEW
International Association of Electrical Inspectors
National Electrical Contractors Association
Nucor
SAPA Extrusions North America
STI
UL LLC
Western Tube (Division of Zekelman Industries)
Wheatland Tube Company

Name of Representative:

D. Kendall
R. Horner
E. Iverson
S. Blais
P. Hickman
D. Humphrey
M. Johnston
J. Broussard
H. Harper
J. Andre
D. Gerstetter
A. Nunez
J. Burris

The following Members of the NEMA Steel Conduit & Electrical Metallic Tubing - Codes/Communications/ Technical Committee worked on this Standard prior to its publication:

J. Burris, Co-Chair

R. Horner, Co-Chair

K. Shen, Secretary

Organization Represented:

ABB Inc.
Atkore International
Atkore International
Atkore International
Consultant (STI)
Nucor
Nucor

Name of Representative:

D. Kendall
B. Deacy
R. Horner
E. Iverson
P. Dobrowsky
J. Broussard
N. Fraser

Nucor
Nucor
Robroy Industries, Inc.
Steel Tube Institute of North America
STI
Western Tube (Division of Zekelman Industries)
Wheatland Tube Company
Wheatland Tube Company

G. Fuentes
C. Wood
S. Voelzke
B. Sullivan
J. Andre
A. Nunez
J. Burris
G. Maurer

< This page is left blank intentionally. >

CONTENTS

1	Scope	1
2	Normative References	1
3	Definitions	2
4	Units of Measurement	2
5	General Requirements	2
5.1	Circular Cross-Section	2
5.2	Wall Thickness	2
5.3	Interior Surface	2
5.4	Welding	2
5.5	Cleaning	3
5.6	Protective Coating for Corrosion Resistance	3
5.7	Surface Treatments	3
6	Detailed Requirements	3
6.1	Exterior Coating	3
6.1.1	Zinc Coating	3
6.1.2	Alternate Corrosion-Resistant Coating (ACRC)	3
6.2	Interior Coating	3
6.3	Threading and Chamfering	3
6.4	Identification	3
6.5	Dimensions	3
6.6	Threads	4
6.7	Couplings	4
6.8	Elbows and Nipples	4
7	Test Procedures	4
7.1	Bending Properties	4
7.1.1	Ductility of Steel	4
7.1.2	Ductility of Coating at Ambient Temperature	4
7.2	Thickness of Zinc Coating	4
7.3	Alternate Corrosion-Resistant Coatings (ACRC)	5
7.4	Quality of Organic Coating for Use on Interior Surface	5
8	Examination of Product	5
8.1	Place of Inspection	5
8.2	Visual Inspection of Conduit	5
8.3	Visual Inspection of Elbows	5
8.4	Restrictions on Localized Surface Imperfections	5
8.5	Retests	5
9	Markings	6
9.1	General	6

9.2 Supplementary Coating Marking 6

Tables

Table 1 Dimensions of Threads for Electrical Rigid Steel Conduit 7
Table 2 Dimensions and Weights for Rigid Steel Conduit 8
Table 3 Dimensions of Couplings 9
Table 4 Dimensions of 90-Degree Elbows and Weights of Nipples per Hundred 10

1 Scope

This Standard covers the requirements for an electrical rigid steel conduit for use as a raceway for wires or cables of an electrical system. Finished conduit is produced in standard 10 ft. (3.05 m) lengths, threaded on each end with one coupling attached. The production of lengths shorter or longer than the Standard length shall be allowed, whether threaded or unthreaded and with or without couplings. ERMC-S is protected on the exterior surface with a metallic zinc coating or alternate corrosion protection coating (as specified in clauses 5.3.3, 6.2.4, 7.8, and 7.9 in UL 6) and on the interior surface with zinc or organic coating.

This Standard also covers conduit couplings, elbows, and nipples.

Properly assembled systems of conduit, couplings, elbows, and nipples manufactured in accordance with this Standard and other identified fitting provide for the electrical continuity required of an equipment grounding conductor.

2 Normative References

The following Standards contain provisions that, through reference in this text, constitute requirements of this American National Standard. At the time of publication, the editions indicated were valid. All Standards are subject to revision, and parties to agreements based on this American National Standard are encouraged to investigate the possibility of applying the most recent editions of the Standards indicated below unless otherwise specified.

American Society of Mechanical Engineers (ASME)

Two Park Avenue
New York, NY 10016-5990

ASME B1.20.1 – 18 *Pipe Threads, General Purpose (Inch)*

ASTM International (ASTM)

100 Barr Harbor Drive
West Conshohocken, PA 19428-2959

ASTM A239 – 19 *Standard Practice for Locating the Thinnest Spot in a Zinc (Galvanized) Coating on Iron or Steel Articles*

ASTM B117 – 19 *Standard Practice for Operating Salt Spray (Fog) Apparatus*

ASTM B499 – 14 *Standard Test Method for Measurement of Coating Thicknesses by the Magnetic Method: Nonmagnetic Coatings on Magnetic Basis Metals*

ASTM D638 – 14 *Standard Test Method for Tensile Properties of Plastics*

ASTM D1654 – 16 *Standard Test Method for Evaluation of Painted or Coated Specimens Subjected to Corrosive Environments*

ASTM D2444 – 19 *Standard Test Method for Determination of the Impact Resistance of Thermoplastic Pipe and Fittings by Means of a Tup (Falling Weight)*

ASTM D3359 – 17 *Standard Test Method for Measuring Adhesion by Tape Test*

ASTM G 151 – 19 *Standard Practice for Exposing Nonmetallic Materials in Accelerated Test Devices that Use Laboratory Light Sources*

ASTM G 153 – 13 *Standard Practice for Operating Enclosed Carbon Arc Light Apparatus for Exposure of Nonmetallic Materials*

ASTM G 155 – 13 *Standard Practice for Operating Xenon Arc Light Apparatus for Exposure of Non-Metallic Materials*