

AS/NZS IEC 62226.3.1:2021
IEC 62226-3-1:2007+AMD1:2016 CSV



Australian/New Zealand Standard™

Exposure to electric or magnetic fields in the low and intermediate frequency range — Methods for calculating the current density and internal electric field induced in the human body

Part 3.1: Exposure to electric fields — Analytical and 2D numerical models



AS/NZS IEC 62226.3.1:2021

This Joint Australian/New Zealand Standard™ was prepared by Joint Technical Committee TE-007, Human Exposure to Electromagnetic Fields. It was approved on behalf of the Council of Standards Australia on 20 May 2021 and by the New Zealand Standards Approval Board on 04 May 2021.

This Standard was published on 4 June 2021.

The following are represented on Committee TE-007:

- Australian Centre for Radiofrequency Bioeffects Research
- Australian Industry Group
- Australian Mobile Telecommunications Association
- Australian Radiation Protection and Nuclear Safety Agency
- Commercial Radio Australia
- Communications, Electrical and Plumbing Union — Electrical Division
- Department of Defence (Australian Government)
- Electrical Engineers Association of NZ
- Engineers Australia
- Ministry of Health (NZ)
- National Measurement Institute
- National Radiation Laboratory New Zealand
- Victoria University of Wellington NZ

This Standard was issued in draft form for comment as DR AS/NZS IEC 62226.3.1:2021.

Keeping Standards up-to-date

Ensure you have the latest versions of our publications and keep up-to-date about Amendments, Rulings, Withdrawals, and new projects by visiting:

www.standards.org.au

www.standards.govt.nz

ISBN 978 1 76113 359 6

Australian/New Zealand Standard™

Exposure to electric or magnetic fields in the low and intermediate frequency range — Methods for calculating the current density and internal electric field induced in the human body

Part 3.1: Exposure to electric fields — Analytical and 2D numerical models

First published as AS/NZS IEC 62226.3.1:2021.



© IEC Geneva Switzerland 2021 — All rights reserved

© Standards Australia Limited/the Crown in right of New Zealand, administered by the New Zealand Standards Executive 2021

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of either the IEC or the publisher, unless otherwise permitted under the Copyright Act 1968 (Cth) or the Copyright Act 1994 (New Zealand). If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please see the contact details on the back cover or the contact us page of the website for further information.

Preface

This Standard was prepared by the Joint Standards Australia/Standards New Zealand Committee TE-007, Human Exposure to Electromagnetic Fields.

The objective of this document is to define in detail the coupling factor K — introduced by the AS/NZS IEC 62226 series to enable exposure assessment for complex exposure situations, such as non-uniform magnetic field or perturbed electric field — for the case of simple models of the human body, exposed to uniform electric fields. The coupling factor K has different physical interpretations depending on whether it relates to electric or magnetic field exposure. It is the so called “shape factor for electric field”.

This document applies to the frequency range for which exposure limits are based on the induction of voltages or currents in the human body when exposed to electric fields.

This document can be used when the electric field can be considered to be uniform, for frequencies up to at least 100 kHz.

This situation of exposure to a “uniform” electric field is mostly found in the vicinity of high voltage overhead power systems. For this reason, illustrations given in this part are given for power frequencies (50 Hz and 60 Hz).

This document is identical with, and has been reproduced from, IEC 62226-3-1:2007+AMD1:2016 CSV, *Exposure to electric or magnetic fields in the low and intermediate frequency range — Methods for calculating the current density and internal electric field induced in the human body — Part 3-1: Exposure to electric fields — Analytical and 2D numerical models*

As this document has been reproduced from an International Standard, the following applies:

- (a) In the source text “this part of IEC 62226” should read “this Australian/New Zealand Standard”.
- (b) A full point substitutes for a comma when referring to a decimal marker.

As this document has been reproduced from an International Standard, a full point substitutes for a comma when referring to a decimal marker.

Australian or Australian/New Zealand Standards that are identical adoptions of international normative references may be used interchangeably. Refer to the online catalogue for information on specific Standards.

The terms “normative” and “informative” are used in Standards to define the application of the appendices or annexes to which they apply. A “normative” appendix or annex is an integral part of a Standard, whereas an “informative” appendix or annex is only for information and guidance.

NOTES

CONTENTS

FOREWORD..... 5

INTRODUCTION..... 7

1 Scope..... 8

2 Exposure to electric field 8

3 General procedure..... 11

 3.1 Shape factor..... 11

 3.2 Procedure 11

4 Human body models 12

 4.1 General..... 12

 4.2 Surface area 12

 4.3 Semi-spheroidal model..... 13

 4.4 Axisymmetrical body model 15

5 Calculation of induced current 16

 5.1 General..... 16

 5.2 Semi-spheroid 16

 5.3 Axisymmetrical models..... 20

 5.4 Comparison of the analytical and numerical models 27

6 Influence of electrical parameters 28

 6.1 General..... 28

 6.2 Influence of permittivity 28

 6.3 Influence of conductivity..... 28

 6.4 Non-homogeneous conductivity..... 29

7 Measurement of currents induced by electric fields..... 29

 7.1 General..... 29

 7.2 Current flowing to the ground 29

Annex A (normative) Analytical solutions for a spheroid in a uniform electric field..... 31

Annex B (normative) Human body axisymmetrical model 34

Annex C (informative) Child body model 39

Annex D (informative) Example of use of this standard 41

Annex E (informative) Numerical calculation methods..... 45

Bibliography..... 53

Figure 1 – Illustration of the phenomenon of currents induced by electric field in a human body standing on the ground 10

Figure 2 – Potential lines of the electric field generated by an energised wire in the absence of any objects (all distances in metres) 10

Figure 3 – A realistic body model..... 12

Figure 4 – Scheme of the semi-spheroid simulating a human being standing on a zero potential plane 13

Figure 5 – Equivalent spheroid radius, R , versus height, L , and for different mass, M 15

Figure 6 – The axisymmetrical body model for the reference man (left) and woman (right)..... 15

Figure 7 – Conductive spheroid exposed to electric field.....	16
Figure 8 – Calculation of the <i>shape factor for electric field</i> K_E for a spheroid exposed to an unperturbed electric field.....	17
Figure 9 – Current density J_S induced by an unperturbed electric field (1 kV/m, 50 Hz) in a spheroid versus parameter L/R (values in $\mu\text{A}/\text{m}^2$).....	18
Figure 10 – Dimensions and mesh of the semi-spheroid	19
Figure 11 – Distortion of power frequency electric field lines close to the conductive semi-spheroid	19
Figure 12 – Calculated induced current density $J_A(h)$ in the body standing in a vertical 50 Hz electric field of 1 kV/m	21
Figure 13 – Computation domain	23
Figure 14 – Mesh of the man body model and distortion of power frequency electric field lines close to model.....	23
Figure 15 – Distribution of potential lines and 50 Hz electric field magnitude (man model)	24
Figure 16 – Computation of induced currents J_A along a vertical axis, and distribution of induced currents in the man model at 50 Hz	25
Figure 17 – Mesh of the woman body model and distortion of power frequency electric field lines close to model.....	25
Figure 18 – Distribution of potential lines and 50 Hz electric field magnitude (woman model)	26
Figure 19 – Computation of induced currents J_A along a vertical axis, and distribution of induced currents in the woman model at 50 Hz	27
Figure A.1 – Conductive spheroid exposed to electric field	31
Figure B.1 – Normalised axisymmetrical models. Left: man, Right: woman	36
Figure C.1 – Computation of induced currents J_Z along a vertical axis, and distribution of induced currents in the 10 years reference child model.....	40
Figure E.1 – Spheroid model.....	46
Figure E.2 – Space potential model	47
Figure E.3 – Exemple of charge simulation method using rings.....	48
Figure E.4 – Superficial charges integral equation method, cutting of the body into N elements.....	49
Figure E.5 – Mesh of the body using finite element method	50
Figure E.6 – Impedance method	51
Figure E.7 – Yee-method: Electric and magnetic grids for spatial discretization	52
Table 1 – Data for reference man and reference woman.....	13
Table 2 – Values of $\arcsin(e) / e$ for different values of L/R	14
Table 3 – Derived data using spheroid model at 50 Hz	20
Table 4 – Electric field E_{BR} required to produce basic restrictions J_{BR} or E_{iBR} in the neck at 50 Hz.....	22
Table 5 – Comparison of values of the shape factor for electric field K_E and corresponding current densities for an unperturbed 50 Hz electric field of 1 kV/m.....	28
Table B.1 – Measures from antropomorphic survey used to construct vertical dimensions of axisymmetrical model [56]	35

Table B.2 – Measures from antropomorphic survey used to construct the radial dimensions of axisymmetrical model [56]	35
Table B.3 – Normalised model dimensions.....	37
Table B.4 – Axisymmetric model dimensions for reference man and reference woman whose mass and height are defined by ICRP [38] and are given in Table 1	38
Table C.1 – Reference values provided by ICRP for male and female children.....	39
Table C.2 – Dimensions of the reference children (in m excepted SB_R in m ²)	39
Table C.3 – Results of analytical method for the reference children	40
Table D.1 – Normalised dimensions of the women model.....	41
Table D.2 – Calculation of the dimensions for a specific person	42

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**EXPOSURE TO ELECTRIC OR MAGNETIC FIELDS
IN THE LOW AND INTERMEDIATE FREQUENCY RANGE –
METHODS FOR CALCULATING THE CURRENT DENSITY AND
INTERNAL ELECTRIC FIELD INDUCED IN THE HUMAN BODY –****Part 3-1: Exposure to electric fields –
Analytical and 2D numerical models**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

DISCLAIMER

This Consolidated version is not an official IEC Standard and has been prepared for user convenience. Only the current versions of the standard and its amendment(s) are to be considered the official documents.

This Consolidated version of IEC 62226-3-1 bears the edition number 1.1. It consists of the first edition (2007-05) [documents 106/125/FDIS and 106/128/RVD] and its amendment 1 (2016-10) [documents 106/376/FDIS and 106/378/RVD]. The technical content is identical to the base edition and its amendment.

This Final version does not show where the technical content is modified by amendment 1. A separate Redline version with all changes highlighted is available in this publication.

International Standard IEC 62226-3-1 has been prepared by IEC technical committee 106: Methods for the assessment of electric, magnetic and electromagnetic fields associated with human exposure.

This standard is to be used in conjunction with the first edition of IEC 62226-1:2004, *Exposure to electric or magnetic fields in the low and intermediate frequency range – Methods for calculating the current density and internal electric field induced in the human body – Part 1: General*.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

This International Standard constitutes Part 3-1 of IEC 62226 series, which will regroup several international standards and technical reports within the framework of the calculation of induced current densities and internal electric fields.

A list of all parts of the IEC 62226 series, published under the general title *Exposure to electric or magnetic fields in the low and intermediate frequency range – Methods for calculating the current density and internal electric field induced in the human body*, can be found on the IEC website.

The committee has decided that the contents of the base publication and its amendment will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

Public interest concerning human exposure to electric and magnetic fields has led international and national organisations to propose limits based on recognised adverse effects.

This standard applies to the frequency range for which the exposure limits are based on the induction of voltages or currents in the human body, when exposed to electric and magnetic fields. This frequency range covers the low and intermediate frequencies, up to 100 kHz. Some methods described in this standard can be used at higher frequencies under specific conditions.

The exposure limits based on biological and medical experimentation about these fundamental induction phenomena are usually called “basic restrictions”. They include safety factors.

The induced electrical quantities are not directly measurable, so simplified derived limits are also proposed. These limits, called “reference levels” are given in terms of external electric and magnetic fields. They are based on very simple models of coupling between external fields and the body. These derived limits are conservative.

Sophisticated models for calculating induced currents in the body have been used and are the subject of a number of scientific publications. These models use numerical 3D electromagnetic field computation codes and detailed models of the internal structure with specific electrical characteristics of each tissue within the body. However such models are still developing; the electrical conductivity data available at present has considerable shortcomings; and the spatial resolution of models is still progressing. Such models are therefore still considered to be in the field of scientific research and at present it is not considered that the results obtained from such models should be fixed indefinitely within standards. However it is recognised that such models can and do make a useful contribution to the standardisation process, specially for product standards where particular cases of exposure are considered. When results from such models are used in standards, the results should be reviewed from time to time to ensure they continue to reflect the current status of the science.

EXPOSURE TO ELECTRIC OR MAGNETIC FIELDS IN THE LOW AND INTERMEDIATE FREQUENCY RANGE – METHODS FOR CALCULATING THE CURRENT DENSITY AND INTERNAL ELECTRIC FIELD INDUCED IN THE HUMAN BODY –

Part 3-1: Exposure to electric fields – Analytical and 2D numerical models

1 Scope

This part of IEC 62226 applies to the frequency range for which exposure limits are based on the induction of voltages or currents in the human body when exposed to electric fields.

This part defines in detail the coupling factor K – introduced by the IEC 62226 series to enable exposure assessment for complex exposure situations, such as non-uniform magnetic field or perturbed electric field – for the case of simple models of the human body, exposed to uniform electric fields. The coupling factor K has different physical interpretations depending on whether it relates to electric or magnetic field exposure. It is the so called “shape factor for electric field”.

This part of IEC 62226 can be used when the electric field can be considered to be uniform, for frequencies up to at least 100 kHz.

This situation of exposure to a “uniform” electric field is mostly found in the vicinity of high voltage overhead power systems. For this reason, illustrations given in this part are given for power frequencies (50 Hz and 60 Hz).

2 Exposure to electric field

Alternating electric fields are generated by energised conductors (i.e. under voltage). In the immediate vicinity of domestic electrical equipment, such as lights, switches, food mixers and irons, local electric-field strengths about 100 V/m may be found. Such fields are non-uniform, but their strengths are far below the levels recommended in safety guidelines, so there is no need of calculation of induced currents in such exposure situations.

Higher electric-field strengths may be found in the vicinity of high voltage equipment such as electric power line. In the frequency range covered by this standard, it is considered that exposure from power lines is the only significant exposure source for public regarding safety guidelines limits.

Guidelines on human exposure to electric fields are generally expressed in terms of induced current density or internal electric field. These quantities cannot be measured directly and the purpose of this document is to give guidance on how to assess these quantities induced in the human body by external (environmental) electric fields E_0 .