

ASSE LEC 2012-2021a



Listing Evaluation Criteria for
**Packaged Plumbing and
Mechanical Systems for Continuous
Microbiological Mitigation**

ASSE Board Approved: June 2021
ICS Codes: 13 060 99 | 97 100 01



General Information

Neither this document, nor any portion thereof, may be reproduced without the written consent of ASSE International.

No product may be said to be ASSE listed unless the manufacturer has applied to ASSE International, has had its product tested according to the applicable standards or listing evaluation criteria (LEC), and when the product has passed the test, displays the ASSE Seal on the product.

Instructions for receiving the authorization to display the seal are available from the ASSE International office. Organizations wishing to adopt or list to any ASSE standard or LEC should print the ASSE number on the cover page first and in equal or larger type to that of the adopting or listing organization.

ASSE International
Mokena, Illinois
Copyright © 2021
All rights reserved.

Foreword

This foreword shall not be considered a part of the listing evaluation criteria (LEC); however, it is offered to provide background information.

ASSE International standards and LECs are developed in the interest of consumer safety. ASSE considers LEC's to be of great value in the development of improved plumbing systems.

The working group that developed this LEC was set up within the framework of the Product Standards Committee of ASSE International.

Water-borne pathogens such as Legionella, Pseudomonas, and Non-Tuberculosis Mycobacterium infect humans regularly, whether or not symptoms manifest. Existing technologies can mitigate the replication of and infection ability of microorganisms. These products on their own are specified by plumbing and mechanical engineers as part of a complete system design. This LEC covers system packages that have combined technologies of ultraviolet disinfection, and water heaters with thermal disinfection controls that follow current best practices.

Recognition is made of the time volunteered by members of the working group and of the support of the manufacturers who also participated in meetings for this LEC.

This LEC does not imply ASSE's endorsement of a product which conforms to these requirements. Compliance with this LEC does not imply acceptance by any code body.

It is recommended that these devices be installed consistent with local codes by qualified and trained professionals. It is recommended that these devices be maintained and serviced per the manufacturer's recommendation, filters are replaced at regular intervals per the manufacturer's instructions.

2020 Product Standards Committee

Tsan-Liang Su, PhD, Chairperson

*Stevens Institute of Technology
Hoboken, NJ*

Chris Haldiman

*Watts Water Technologies
Springfield, MO*

Karl Abrahamson

*Saint Paul Department of Safety
and Inspections
Cottage Grove, MN*

John F. Higdon, P.E.

*Supply Source Products
Matthews, NC*

Brian Andersen

*Plumbers' JAC LU130, Chicago
Manhattan, IL*

Jim Kendzel

*American Supply Association
Minneapolis, MN*

William T. Briggs Jr.

*MGJ Associates
New York, NY*

Ramiro Mata

*American Society of Plumbing
Engineers (ASPE)
Mentor, OH*

Terry Burger (non-voting)

*ASSE International
Cleveland, OH*

Robert Neff

*Delta Faucet
Pendleton, IN*

William Chapin

*Professional Code Consulting, LLC
Cullman, AL*

David Orton

*NSF International
Ann Arbor, MI*

Mark E. Fish

*Zurn Industries, LLC
Cary, NC*

Thomas Pitcherello

*State of New Jersey
Bordentown, NJ*

Ron George

*Plumb-Tech Design & Consulting Services LLC
Newport, MI*

Daniel Rademacher

*Veiga, LLC
Butte, MT*

Mark Gibeault

*Kohler Company
Kohler, WI*

Shabbir Rawalpindiwala

*Kohler Company
Kohler, WI*

Daniel Gleiberman

*Sloan
Los Angeles, CA*

Billy Smith

*American Society of Plumbing
Engineers (ASPE)
Montgomery, AL*

Brandon Gunnell

*Precision Plumbing Products
Portland, OR*

Chris White (non-voting)

*ASSE International
Mokena, IL*

ASSE LEC 2012 Working Group

Conrad L. Jahrling, Chairperson

*Watts Water Technologies
Chicago, IL*

George Istefan

*IAPMO R&T
Ontario, CA*

Hugo Aguilar

*IAPMO R&T
Ontario, CA*

Nicholas Lane

*Watts Water Technologies
Blauvelt, NY*

Vincent D'Amore

*Watts Water Technologies
Blauvelt, NY*

Andrew Macaluso

*Watts Water Technologies
Blauvelt, NY*

Michael Drake

*ASSE International
Mokena, IL*

Lee Mercer

*IAPMO
Cleveland, OH*

Mark Ferguson

*Watts Water Technologies
Fort Worth, TX*

Tom Palkon

*IAPMO
Chicago, IL*

Enrique Gonzalez

*IAPMO R&T
Ontario, CA*

Tim Reising

*ASSE International
Mokena, IL*

Chris Haldiman

*Watts Water Technologies
Springfield, MO*

Chris White

*ASSE International
Mokena, IL*

Table of Contents

Section I	1
1.0 General	1
1.1 Application	1
1.2 Scope	1
1.3 PPMS Design and Configuration	2
1.4 Reference Documents	2
Section II	4
2.0 Test Specimens and Test Laboratory	4
2.1 Samples Submitted	4
2.2 Documentation	4
2.3 Measurement	4
Section III	5
3.0 Performance Requirements and Compliance Testing	5
3.1 Individual Component Performance	5
3.2 Pressure Drop at Rated Flow	5
Figure 1	5
Equation 1	6
3.3 Self-Disinfection of the PPMS Water Heater	6
Figure 2	6
Figure 3	7
3.4 Clogged Filter Alarm	7
3.5 Outlet Water Temperature Monitoring	8
3.6 Building System Thermal Disinfection	8
3.7 Preventive Maintenance Alerts	9
3.8 Recirculation Leg Stagnancy Control	9
3.9 Automatic Blowdown	9
3.10 Hydrostatic Test	10
Section IV	11
4.0 Detailed Requirements	11
4.1 Materials	11
4.2 Installation and Maintenance Instructions	11
4.3 Identification and Markings	11
4.4 Historical Data Report	11
Section V	12
5.0 Definitions.....	12

Listing Evaluation Criteria for Packaged Plumbing and Mechanical Systems for Continuous Microbiological Mitigation

Section I

1.0 General

1.1 Application

Packaged Plumbing and Mechanical Systems (PPMS), also known as skid systems, combine devices that are typically located in a mechanical room or basement.

1.2 Scope

1.2.1 Description

This LEC covers PPMSs that are designed to inactivate and disinfect waterborne pathogens and microorganisms within hot water distribution systems from replicating and infecting humans. These PPMSs include a water heater and distribution mixing valve, or water heater with integral temperature control device, an ultraviolet treatment system that treats incoming and recirculating water, filters, an anti-scaling device, and a connection to drain.

NOTE: The temperature and pressure relief valve required for water heater installations is a part of the water heater sub-assembly.

The PPMS shall include a programmable controller that manages the disinfection and control of the PPMS. The controller includes:

- Ability to generate maintenance alerts;
- Ability to send local and remote alerts;
- Connectivity to external building automation systems (e.g. MODBUS and BACnet).

1.2.2 Connections

Pipe threads and other connections shall conform to the applicable standards.

- Tapered pipe threads shall comply with ASME B1.20.1.
- Dry seal pipe threads shall comply with ASME B1.20.3.
- Compression assemblies shall comply with SAE J512.
- Soldered connections shall comply with ASME B16.18 or ASME B16.22.
- Push fit connections shall comply with ASSE 1061.
- Press connections shall comply with ASME B16.51.

1.2.3 Minimum Heating Capacity

Integral water heaters capacities shall be 399,000 BTU/hr (118kW) and greater. Heating output shall be determined by ANSI Z21.10.3/CSA 4.3 or UL 1995.