

AS 62282.3.300:2021



Fuel cell technologies

Part 3.300: Stationary fuel cell power systems — Installation (IEC 62282-3-300:2012 (ED.1.0), MOD)



AS 62282.3.300:2021

This Australian Standard ® was prepared by ME-093, Hydrogen Technologies. It was approved on behalf of the Council of Standards Australia on 09 August 2021.

This Standard was published on 20 August 2021.

The following are represented on Committee ME-093:

- Association of Accredited Certification Bodies
- Australasian Fire and Emergency Service Authorities Council
- Australia New Zealand Industrial Gas Association
- Australian Energy Market Operator
- Australian Hydrogen Council
- Australian Industry Group
- Australian Pipelines and Gas Association
- Chemistry Australia
- CSIRO
- Energy Networks Australia
- Engineers Australia
- Future Fuels Cooperative Research Centre
- Gas Appliance Manufacturers Association of Australia
- Gas Energy Australia
- Gas Technical Regulators Committee
- Institute of Chemical Engineers
- Institute of Electrical Inspectors
- National Energy Resources Australia
- The Australian Gas Association
- University of Adelaide

This Standard was issued in draft form for comment as DR AS 62282.3.300:2020.

Keeping Standards up-to-date

Ensure you have the latest versions of our publications and keep up-to-date about Amendments, Rulings, Withdrawals, and new projects by visiting:

www.standards.org.au

ISBN 978 1 76113 464 7

Fuel cell technologies

Part 3.300: Stationary fuel cell power systems — Installation (IEC 62282-3-300:2012 (ED.1.0), MOD)

First published as AS 62282.3.300:2021.



© IEC Geneva Switzerland 2021 — All rights reserved
©Standards Australia Limited 2021

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of either the IEC or the publisher, unless otherwise permitted under the Copyright Act 1968 (Cth). If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please see the contact details on the back cover or the contact us page of the website for further information.

Preface

This Standard was prepared by the Standards Australia Committee ME-093, Hydrogen Technologies.

The objective of this document is to provide minimum safety requirements for the installation of indoor and outdoor stationary fuel cell power systems in compliance with AS 62282.3.100 and applies to the installation of the following systems —

- (a) intended for electrical connection to mains directly or with a readily accessible, manually operable switch or circuit-breaker;
- (b) intended for a stand-alone power distribution system;
- (c) intended to provide AC or DC power; and
- (d) with or without the ability to recover useful heat.

This document is limited to those conditions that may be created by the installation process that can lead to personnel hazards or damage to equipment or property external to the fuel cell power system.

This document does not cover the safety requirements of the stationary fuel cell power system which are covered by AS 62282.3.100.

Additionally, this document does not cover —

- (i) Fuel supply and/or fuel storage systems.
- (ii) Auxiliary media supply and disposal.
- (iii) Switches or circuit-breakers.
- (iv) Portable fuel cell power systems.
- (v) Propulsion fuel cell power systems.
- (vi) APU (auxiliary power units) applications.

This document is an adoption with national modifications, and has been reproduced from, IEC 62282-3-300:2012, *Fuel cell technologies — Part 3-300: Stationary fuel cell power systems — Installation*.

The modifications are additional requirements and are set out in [Appendix ZZ](#), which has been added at the end of the source text.

[Appendix ZZ](#) lists the variations to IEC 62282-3-300:2012 for the application of this document in Australia.

As this document has been reproduced from an International document, the following applies:

- (A) In the source text “this part of 62282” should read “this document”.
- (B) A full point substitutes for a comma when referring to a decimal marker.

Australian or Australian/New Zealand Standards that are identical adoptions of international normative references may be used interchangeably. Refer to the online catalogue for information on specific Standards.

The terms “normative” and “informative” are used in Standards to define the application of the appendices or annexes to which they apply. A “normative” appendix or annex is an integral part of a Standard, whereas an “informative” appendix or annex is only for information and guidance.

NOTES

CONTENTS

FOREWORD.....	4
INTRODUCTION.....	6
1 Scope.....	7
2 Normative references	8
3 Terms and definitions	9
4 General safety requirements and strategy	10
5 Siting considerations	11
5.1 General siting.....	11
5.2 Outdoor installations	12
5.2.1 Air intakes and vents	12
5.2.2 Air intakes and exhaust	12
5.2.3 Exhaust outlets.....	12
5.2.4 Area around outlets	12
5.2.5 Enclosures	12
5.3 Indoor installations	12
5.3.1 General	12
5.3.2 Small fuel cell power systems.....	13
5.4 Rooftop installation.....	13
6 Ventilation and exhaust	13
6.1 General	13
6.2 Ventilation	13
6.3 Exhaust system	13
6.3.1 General	13
6.3.2 Small fuel cell systems	13
6.4 Purging and venting processes.....	13
7 Fire protection and gas detection.....	14
7.1 Fire protection and detection	14
7.1.1 Site fire protection	14
7.1.2 Combustible gas detection (indoor installations only).....	14
7.2 Fire prevention and emergency planning	14
8 Interconnections with site interfaces	15
8.1 General.....	15
8.2 Connections to fuel supplies – General	15
8.3 Fuel shut-off and piping.....	15
8.4 Connections to auxiliary media supply and media disposal	15
8.4.1 General	15
8.4.2 Combustible auxiliary gases	15
8.4.3 Non-combustible or inert auxiliary gases	15
8.4.4 Water	15
8.4.5 Waste water and condensate disposal	16
8.4.6 Discharge pipe	16
9 Environmental requirements	16
10 Approval tests	16
10.1 Gas leakage	16

10.2	Site specific shut-down devices	16
11	Maintenance tests	16
12	Documentation	17
12.1	Markings and instructions	17
12.2	Inspection checklist	17
12.3	Installation manual	17
12.4	User's information manual	17
12.5	Maintenance manual	17
Figure 1 – Fuel cell power system		8

INTERNATIONAL ELECTROTECHNICAL COMMISSION

FUEL CELL TECHNOLOGIES –

Part 3-300: Stationary fuel cell power systems – Installation

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 62282-3-300 has been prepared by IEC technical committee 105: Fuel cell technologies.

IEC 62282-3-300 cancels and replaces IEC 62282-3-3, published in 2007, and constitutes a technical revision.

IEC 62282-3-300 includes the following significant technical changes with respect to IEC 62282-3-3:

- addition in the scope to avoid overlapping between IEC 62282-3-100 and IEC 62282-3-300 concerning safety related requirements;
- updating normative references and definitions;
- requirements applicable to the stationary fuel cell removed, so that the target of this standard focuses on "installation risks";

- level of CO reduced for small fuel cell power systems which exhaust directly into a utility shed where they are installed, and where the shed is to ensure safety;
- requirement for using a combustible gas detection system modified;
- reference to the gas valve standard ISO 23551-1 added.

The text of this standard is based on the following documents:

FDIS	Report on voting
105/377/FDIS	105/388/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts of the IEC 62282 series, under the general title *Fuel cell technologies*, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

INTRODUCTION

This International Standard covers the installation of stationary fuel cell power systems that are built in compliance with IEC 62282-3-100.

The requirements of this standard are not intended to constrain innovation. Installations employing materials and/or methods differing from those detailed in this standard may be examined and tested according to the intent of the requirements and, if found to be substantially equivalent, may be considered to comply with the standard.

FUEL CELL TECHNOLOGIES –

Part 3-300: Stationary fuel cell power systems – Installation

1 Scope

This part of IEC 62282 provides minimum safety requirements for the installation of indoor and outdoor stationary fuel cell power systems in compliance with IEC 62282-3-100 and applies to the installation of the following systems:

- intended for electrical connection to mains directly or with a readily accessible, manually operable switch or circuit-breaker;
- intended for a stand-alone power distribution system;
- intended to provide AC or DC power;
- with or without the ability to recover useful heat.

This standard is limited to those conditions that may be created by the installation process that can lead to personnel hazards or damage to equipment or property external to the fuel cell power system.

This standard does not cover the safety requirements of the stationary fuel cell power system which are covered by IEC 62282-3-100.

Additionally, this standard does not cover:

- fuel supply and/or fuel storage systems;
- auxiliary media supply and disposal;
- switches or circuit-breakers;
- portable fuel cell power systems;
- propulsion fuel cell power systems;
- APU (auxiliary power units) applications.

A typical stationary fuel cell power system installation is represented in Figure 1.