

American National Standard

# ASSE/IAPMO/ANSI Series 5000-2022



## Cross-Connection Control Professional Qualifications Standard

ASSE Board Approved: March 2022

ANSI Approved: March 2022





# TABLE OF CONTENTS

## *Cross-Connection Control Professional Qualifications Standard*

<b>Copyright Information</b> .....	<b>ii</b>	<b>Standard #5120</b> .....	<b>18</b>
<b>Foreword</b> .....	<b>iii</b>	<i>Professional Qualifications Standard for Cross-Connection Control Surveyor/Specialist</i>	
<b>ASSE Professional Qualifications Standards Committee</b> .....	<b>iv</b>	<b>Standard #5130</b> .....	<b>22</b>
<b>ASSE Series 5000 Working Group</b> .....	<b>v</b>	<i>Professional Qualifications Standard for Backflow Prevention Assembly Repairers</i>	
<b>Standard #5013</b> .....	<b>1</b>	<b>Standard #5140</b> .....	<b>25</b>
<i>Minimum Performance Requirements for Testing Reduced Pressure Principle Backflow Prevention Assemblies</i>		<i>Professional Qualifications Standard for Fire Protection System Cross-Connection Control Testers</i>	
<b>Standard #5015</b> .....	<b>3</b>	<b>Standard #5150</b> .....	<b>29</b>
<i>Minimum Performance Requirements for Testing Double Check Backflow Prevention Assemblies</i>		<i>Professional Qualifications Standard for Backflow Prevention Program Administrators</i>	
<b>Standard #5020</b> .....	<b>5</b>	<b>Appendix A</b> .....	<b>33</b>
<i>Minimum Performance Requirements for Testing Pressure Vacuum Breaker Assemblies</i>		<i>Troubleshooting Flowcharts</i>	
<b>Standard #5047</b> .....	<b>7</b>	ASSE Test Procedure Flowcharts .....	33
<i>Minimum Performance Requirements for Testing Reduced Pressure Backflow Prevention Assemblies</i>		One-Hose Test Procedure Flowcharts .....	61
<b>Standard #5048</b> .....	<b>9</b>	<b>Appendix B</b> .....	<b>67</b>
<i>Minimum Performance Requirements for Testing Double Check Detector Backflow Prevention Assemblies</i>		<i>Schematics</i>	
<b>Standard #5056</b> .....	<b>11</b>	Backflow Assembly Schematics.....	67
<i>Minimum Performance Requirements for Testing Spill Resistant Vacuum Breakers</i>		Backflow Test Kit Schematics .....	77
<b>Standard #5063</b> .....	<b>13</b>	<b>Appendix C</b> .....	<b>81</b>
<i>Minimum Performance Requirements for Testing Air Valve and Vent Inflow Preventers</i>		<i>Field Test Report Forms</i>	
<b>Standard #5110</b> .....	<b>15</b>	<b>Appendix D</b> .....	<b>101</b>
<i>Professional Qualifications Standard for Backflow Prevention Assembly Testers</i>		<i>Troubleshooting Guide</i>	
		<b>Appendix E</b> .....	<b>109</b>
		<i>ASSE Field Test Procedures Using Three- and Five-Valve Test Kits</i>	
		<b>Appendix F</b> .....	<b>135</b>
		<i>One-Hose Field Test Procedures</i>	
		<b>Appendix G</b> .....	<b>149</b>
		<i>Vocabulary and Definitions</i>	

# COPYRIGHT INFORMATION

## *Cross-Connection Control Professional Qualifications Standard*

Neither this standard, nor any portion thereof, may be reproduced without the written consent of ASSE International.

Organizations wishing to adopt or list any ASSE standard should print the ASSE standard number on the cover page first and in equal or larger type to that of the adopting or listing organization.

ASSE International  
Mokena, Illinois  
Copyright © 2022, 2015, 2009, 2004, 2000, 1998, 1990  
All rights reserved.

# FOREWORD

## *Cross-Connection Control Professional Qualifications Standard*

This foreword shall not be considered a part of the standard. However, it is offered to provide background information.

ASSE International professional qualifications standards are developed in the interest of protecting public health.

In 1987, ASSE's Board of Directors recognized the need to develop a professional qualifications standard for individuals involved with backflow prevention. The resulting qualifications standard, the ASSE Series 5000, established minimum industry requirements for the backflow prevention assembly tester, backflow prevention assembly repairer and cross-connection control surveyor. This voluntary consensus standard was the first in the plumbing and water supply fields to set minimum requirements for qualified professionals. The Series 5000 was first issued by the ASSE Board of Directors in 1990 and was designated as an American National Standard by the American National Standards Institute (ANSI) on November 14, 1991. The standard series has been updated and revised in 1998, 2000, 2004 and 2009, 2015, with the current revision released in 2022.

Backflow prevention methods, devices and assemblies, along with their selection, installation, testing and repair, have been an important part of protecting the public health and the water supply for many years. With the growing use of recycled or gray water systems, and the chronic shortage of water in some areas of the country and world, it is vital that this important resource be protected. There is no understating the importance of requiring trained personnel to specify, install, test and repair this critical protection – the ASSE/IAPMO/ANSI Series 5000 standards mandate the proper level of training, testing and experience needed. To prepare, update and revise this standard, representatives from different regions and industry segments dedicated themselves to achieving true consensus, thereby advancing the backflow prevention community.

In order to better meet the needs of the industry, this revised standard defines the minimum requirements for testing backflow prevention assemblies meeting the performance requirements of ASSE Standards 1013, 1015, 1020, 1047, 1048, 1052 and 1056, and the minimum qualifications requirements for becoming an ASSE Certified Backflow Prevention Assembly Tester, Fire Protection System Cross-Connection Control Tester, Backflow Prevention Assembly Repairer, Cross-Connection Control Surveyor, and Backflow Prevention Program Administrator.

Recognition is made of the time volunteered by members of the working group, the original qualifications standards committee members, and of the industry members who participated in the previous revisions of this standard.

Compliance with this standard does not imply acceptance by any code body. It is recommended that all cross-connection control professionals be in compliance with federal, state and local codes.

This voluntary, consensus standard was promulgated in accordance with procedures developed by the American National Standards Institute (ANSI).

# ASSE PQ STANDARDS COMMITTEE

## *Cross-Connection Control Professional Qualifications Standard*

**Donald Summers Jr.**, Chairperson  
*Local 562 Plumbers & Pipefitters  
Earth City, MO*

**Brian M. Andersen**  
*Plumbers Local 130 UA, JAC  
Chicago, IL*

**Donald J. Berger**  
*New Orleans Pipe Trades LU 60  
New Orleans, LA*

**Raymond Boyd**  
*United Association  
Annapolis, MD*

**Doreen Cannon**  
*UA Local 55  
Cleveland, OH*

**Chris Cheek**  
*UA District Council 16  
Los Angeles, CA*

**Dana Colombo**  
*National Inspection Testing & Certification (NITC)  
Metairie, LA*

**Robert L. Cross**  
*UA Local 68  
Houston, TX*

**Brianne Hall**  
*Fishbeck  
Novi, MI*

**Scott Hamilton** (non-voting)  
*IAPMO  
Mokena, IL*

**Gary Howard**  
*La Grange, IL*

**Edward Lyczko**  
*Cleveland Clinic - Retiree  
Cleveland, OH*

**Douglas Marian**  
*UA Local 78  
Los Angeles, CA*

**David Otterstein**  
*National Inspection Testing & Certification (NITC)  
Los Angeles, CA*

**Richard J. Prospal**  
*Prospal Consulting Services Inc.  
Brunswick, OH*

**Daniel Rademacher**  
*Plumbing Code & Design Consulting  
Butte, MT*

**Philip Roach**  
*Sazan Group  
Portland, OR*

**Kenneth Schneider**  
*United Association ITF  
St Louis, MO*

**Debbie Vukovich**  
*Dallas JAC Local 100  
Garland, TX*

**Marianne Waickman** (non-voting)  
*ASSE International  
Mokena, IL*

**Keith Woller**  
*UA Sprinkler Fitters Local 669  
Columbia, MD*

# ASSE SERIES 5000 WORKING GROUP

## *Cross-Connection Control Professional Qualifications Standard*

**Sean Cleary, Chairperson**

*IAPMO/BPI  
Scranton, PA*

**Stu Asay**

*IAPMO / BPI  
Gunnison, CO*

**Nick Azmo**

*Apollo Flow Controls  
Hawthorne, NJ*

**Paul Baker**

*Plumbers Local 98 – PITC  
Detroit, MI*

**Mike Eisenhauer**

*Chicago Backflow  
Alsip, IL*

**Matt Kapcia**

*The Backflow School, Inc.  
Troy, MI*

**Matt King**

*Local 524 Plumbers & Pipefitters  
Scranton, PA*

**Mike Lueck**

*Mid-West Instrument  
Sterling Heights, MI*

**Janice McNellis (non-voting)**

*ASSE International  
Mokena, IL*

**John Parizek**

*Local 15 – Minneapolis Plumbers JATC  
Prior Lake, MN*

**Chris Simmons**

*Local 8 – Plumbers and Gasfitters  
Kansas City, MO*

**Donald Summers Jr.**

*Local 562 Plumbers & Pipefitters  
Earth City, MO*

**Don Sweeten**

*Sprinkler Fitters Local 692  
Philadelphia, PA*

**Marianne Waickman (non-voting)**

*ASSE International  
Mokena, IL*

**Tom Walsh**

*New Jersey Alliance of Master Plumbers  
Howell, NJ*

**Kenny Whitson**

*Local 344 – Plumbers and Pipefitters  
Oklahoma City, OK*

**Ralph Yanora**

*Commissioner, PA Public Utility  
Harrisburg, PA*

**Ralph Young**

*Sprinkler Fitters Local 669  
Lanham, MD*





## *Minimum Performance Requirements for Testing Reduced Pressure Principle Backflow Prevention Assemblies*

### **1.0 Scope, Purpose and Definitions**

#### **1.1 Scope**

This operational performance test requirement includes all activities that shall be addressed while field testing ASSE Standard 1013 Reduced Pressure Principle Backflow Prevention Assemblies.

#### **1.2 Purpose**

The purpose of this standard shall be to establish minimum field testing performance requirements for ASSE Standard 1013 Reduced Pressure Principle Backflow Prevention Assemblies.

#### **1.3 Definitions**

Field Testing Performance Requirement: A test procedure that evaluates a backflow prevention assembly for compliance to the minimum performance requirements.

Refer to Appendix G for additional definitions.

### **2.0 Field Testing Requirements**

At a minimum, backflow prevention assemblies shall be tested at the time of installation, repair or relocation and not less than on an annual schedule thereafter. Backflow prevention assemblies shall also be tested when returned to service after winterization or a similar extended period of time. The test shall be performed by a trained and certified backflow tester meeting the requirements of the 5110 standard.

#### **2.1 Administrative Issues**

- A. Initial arrangements shall be made with the responsible party to schedule the test.
- B. Arrangements/notifications shall be made where

a continuous water supply is necessary or where testing creates a special hazard, inconvenience or risk in buildings or piping systems.

- C. The proper information, reporting forms and equipment shall be gathered to properly perform the test.

#### **2.2 Site Issues**

##### **A. Safety Evaluation**

The evaluation shall be made for hazards to persons and property in accordance with applicable federal, state and local safety regulations and statutes. Some of the issues to be examined are, but are not limited to:

- Confined spaces – access, atmosphere
- Chemical, electrical or flammable hazards
- Hazards related to elevation
- Excessive noise

##### **B. Evaluation of the Installation**

1. The assembly shall be confirmed for code compliance with respect to the degree of hazard, markings, prohibited locations (i.e. where subjected to flooding, freezing, toxic fumes) and special installation requirements.
2. The assembly orientation and direction of flow shall be confirmed as proper.
3. The assembly shall be checked for alterations or special needs, such as, but not limited to, the adequacy of the air gap, the evidence of illegal bypasses and the adequacy of drainage systems from the assembly.
4. The general appearance of the assembly shall be checked for evidence of excessive discharge, condition and proper location of shutoff valves, test cocks, relief valve and air gap, and adequacy of drainage, should leakage occur.