



**CGA P-8.6—2022**  
**UNMANNED AIR GAS PLANTS:**  
**DESIGN AND OPERATION**

**THIRD EDITION**

## PREFACE

As part of a program of harmonization of industry standards, the Compressed Gas Association (CGA) has issued CGA P-8.6, *Unmanned Air Gas Plants—Design and Operation*, jointly produced by members of the International Harmonization Council and originally published by the European Industrial Gases Association (EIGA) as EIGA Doc 132, *Unmanned Air Gas Plants—Design and Operation*.

This publication is intended as an international harmonized standard for the worldwide use and application of all members of the Asia Industrial Gases Association (AIGA), Compressed Gas Association (CGA), European Industrial Gases Association (EIGA), and Japan Industrial and Medical Gases Association (JIMGA). Each association's technical content is identical, except for regional regulatory requirements and minor changes in formatting and spelling.

## PLEASE NOTE:

The information contained in this document was obtained from sources believed to be reliable and is based on technical information and experience currently available from members of the Compressed Gas Association, Inc. and others. However, the Association or its members, jointly or severally, make no guarantee of the results and assume no liability or responsibility in connection with the information or suggestions herein contained. Moreover, it should not be assumed that every acceptable commodity grade, test or safety procedure or method, precaution, equipment or device is contained within, or that abnormal or unusual circumstances may not warrant or suggest further requirements or additional procedure.

This document is subject to periodic review, and users are cautioned to obtain the latest edition. The Association invites comments and suggestions for consideration. In connection with such review, any such comments or suggestions will be fully reviewed by the Association after giving the party, upon request, a reasonable opportunity to be heard. Proposed changes may be submitted via the Internet at our web site, [www.cganet.com](http://www.cganet.com).

This document should not be confused with federal, state, provincial, or municipal specifications or regulations; insurance requirements; or national safety codes. While the Association recommends reference to or use of this document by government agencies and others, this document is purely voluntary and not binding unless adopted by reference in regulations.

A listing of all publications, audiovisual programs, safety and technical bulletins, and safety posters is available via the Internet at our website at [www.cganet.com](http://www.cganet.com). For more information contact CGA at Phone: 703-788-2700, ext. 799. E-mail: [customerservice@cganet.com](mailto:customerservice@cganet.com).

Work Item 19-034  
Atmospheric Gases and Equipment Committee

NOTE—Technical changes from the previous edition are underlined.

THIRD EDITION: 2022  
SECOND EDITION: 2015  
FIRST EDITION: 2006

© – Reproduced with permission from, the European Industrial Gases Association. All rights reserved.

<b>Contents</b>	<b>Page</b>
1 Introduction.....	1
2 Scope and purpose .....	1
3 Definitions.....	1
4 Safety aspects of plant design .....	2
4.1 General considerations.....	2
4.2 Requirements and recommendations for unmanned and remotely operated air gas plants.....	3
4.3 Plant location risk .....	4
4.4 Management of change review .....	4
5 Plant design and retrofit considerations .....	4
5.1 Compliance with permits and regulations.....	4
5.2 Shutdown systems .....	4
5.3 Fire and gas alarm system .....	5
5.4 Remote detection of liquid spillage.....	6
5.5 Process equipment guidelines.....	6
5.6 Trailer filling systems .....	6
5.7 Distribution pipeline and vaporizer systems .....	6
5.8 Control system guidelines .....	7
5.9 Design aspects of plant maintenance.....	9
6 Plant operation .....	10
6.1 Plant safety requirement.....	10
6.2 Plant responsibility.....	10
6.3 Training and skills.....	10
6.4 Documentation .....	11
6.5 Transfer of plant control.....	11
6.6 Alarm handling procedures.....	11
6.7 Remote restart considerations.....	12
6.8 Activity communication follow up.....	12
6.9 Work permits .....	12
6.10 Truck driver safety and security.....	12
6.11 Atmospheric monitoring/man-down systems.....	12
6.12 Process leaks into the cryogenic enclosure .....	13
6.13 Plant/site security .....	13
7 Plant maintenance.....	13
7.1 Planned maintenance and record keeping .....	13
7.2 Lone worker tasks .....	14
7.3 Training and skills.....	14
7.4 Interface between operations and maintenance.....	14
7.5 Lockout/tagout.....	14
8 Emergency plans and external notification.....	14
8.1 Initial responder functions.....	15
8.2 Remote operator functions during an emergency .....	15
8.3 External emergency services .....	15
8.4 Emergency drills.....	15
9 References .....	15
<b>Appendix</b>	
Appendix A—Process equipment guidelines .....	17

## 1 Introduction

This publication has been written to address issues relating to the increasing number of air gas production facilities that are run unmanned or remotely operated.

There are many similarities in the operation of manned, unmanned, and remotely operated plants; however, there are some differences. These differences are not only in how the plant is operated and maintained but also how the plant is designed. In particular, designing new unmanned plants or converting existing plants from manned to unmanned or remote operation requires specific design considerations to ensure an equivalent level of safety to that of a manned operated plant.

## 2 Scope and purpose

The purpose of this publication is to provide guidelines for the design, operation, and maintenance of a plant that has unmanned or remote operations.

Unmanned or remotely operated plant functionality can range from a plant with full remote functionality i.e., satellite plant controlled by a remote operating center (ROC) to a plant with autonomous operation.

The installations that are included in this publication are:

- cryogenic air separation plants;
- cryogenic nitrogen generators;
- noncryogenic plants (pressure swing absorption, vacuum pressure swing absorption, membrane, etc.) for oxygen and nitrogen;
- pipeline compression stations;
- compressed dry air facilities; and
- back-up systems and site storage, if existing and integrated with the production unit.

Specifically excluded are product supply tanks installed at a customer's premises, home care units (for example, concentrators), and noncryogenic plants with a capacity of 5 ton (5 000 kg) per day or less. For noncryogenic plants from 5 ton to 20 ton (5 000 kg to 20 000 kg) per day, a risk assessment shall be carried out to identify which requirements of this publication apply.

## 3 Definitions

For the purpose of this publication, the following definitions apply.

### 3.1 Publication terminology

#### 3.1.1 Shall

Indicates that the procedure is mandatory. It is used wherever the criterion for conformance to specific recommendations allows no deviation.

#### 3.1.2 Should

Indicates that a procedure is recommended.

#### 3.1.3 May

Indicates that the procedure is optional.

#### 3.1.4 Will

Is used only to indicate the future, not a degree of requirement.

#### 3.1.5 Can

Indicates a possibility or ability.