

**ERRATA ISSUED**


Find errata inside front cover. If erratum is missing, contact the ANS Standards Department at [Standards@ans.org](mailto:Standards@ans.org) or 708-579-8269 for replacement copy.

# American Nuclear Society

**WITHDRAWN****reload startup physics tests  
for pressurized water reactors**

## an American National Standard

**No longer being maintained as an American National Standard. This standard may contain outdated material or may have been superseded by another standard. Please contact the ANS Standards Administrator for details.**



published by the  
American Nuclear Society  
555 North Kensington Avenue  
La Grange Park, Illinois 60525 USA

# Erratum

In American National Standard Reload Startup Physics Tests for Pressurized Water Reactors, ANSI/ANS-19.6.1-1997, there is an error on page 12, in footnote "a" to Table A.1. The printed version reads: "For calculating percent differences, use  $(\text{Meas}-\text{Pred})/(\text{Meas})$ , where . . ." The correct text is: "For calculating percent differences, use  $(\text{Meas}-\text{Pred})/(\text{Pred})$ , where . . ." The denominator should be (Pred), not (Meas).

**American National Standard  
Reload Startup Physics Tests  
for Pressurized Water Reactors**

Secretariat  
**American Nuclear Society**

Prepared by the  
**American Nuclear Society  
Standards Committee  
Working Group ANS-19.6.1**

Published by the  
**American Nuclear Society  
555 North Kensington Avenue  
La Grange Park, Illinois 60526 USA**

Approved August 22, 1997  
by the  
**American National Standards Institute, Inc.**

## **American National Standard**

Designation of this document as an American National Standard attests that the principles of openness and due process have been followed in the approval procedure and that a consensus of those directly and materially affected by the standard has been achieved.

This standard was developed under procedures of the Standards Committee of the American Nuclear Society; these procedures are accredited by the American National Standards Institute, Inc., as meeting the criteria for American National Standards. The consensus committee that approved the standard was balanced to ensure that competent, concerned, and varied interests have had an opportunity to participate.

An American National Standard is intended to aid industry, consumers, governmental agencies, and general interest groups. Its use is entirely voluntary. The existence of an American National Standard, in and of itself, does not preclude anyone from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standard.

By publication of this standard, the American Nuclear Society does not insure anyone utilizing the standard against liability allegedly arising from or after its use. The content of this standard reflects acceptable practice at the time of its approval and publication. Changes, if any, occurring through developments in the state of the art, may be considered at the time that the standard is subjected to periodic review. It may be reaffirmed, revised, or withdrawn at any time in accordance with established procedures. Users of this standard are cautioned to determine the validity of copies in their possession and to establish that they are of the latest issue.

The American Nuclear Society accepts no responsibility for interpretations of this standard made by any individual or by any ad hoc group of individuals. Requests for interpretation should be sent to the Standards Department at Society Headquarters. Action will be taken to provide appropriate response in accordance with established procedures that ensure consensus on the interpretation.

Comments on this standard are encouraged and should be sent to Society Headquarters.

Published by

**American Nuclear Society  
555 North Kensington Avenue  
La Grange Park, Illinois 60526 USA**

Copyright © 1997 by American Nuclear Society. All rights reserved.

Any part of this standard may be quoted. Credit lines should read "Extracted from American National Standard ANSI/ANS-19.6.1-1997 with permission of the publisher, the American Nuclear Society." Reproduction prohibited under copyright convention unless written permission is granted by the American Nuclear Society.

Printed in the United States of America

## Foreword

(This Foreword is not a part of American National Standard Reload Startup Physics Tests for Pressurized Water Reactors, ANSI/ANS-19.6.1-1997.)

It is the intent of this American National Standard to provide guidance for verifying the nuclear characteristics of a commercial pressurized water reactor core. This standard is intended to cover the physics tests that are performed following a refueling or other alteration of the reactor core for which nuclear design calculations are required. This standard provides the minimum acceptable startup physics test program; however, the standard recognizes that additional tests may be required by special design features for a particular core.

Compliance with the intent of this standard can be demonstrated by carrying out the following requirements:

- (1) Perform the physics tests described herein using one or more of the acceptable test methods.
- (2) Determine if the test results agree with the predicted results within the test criteria that have been established prior to the performance of the tests.
- (3) Document the above in accordance with the requirements of Section 7 of this standard.

Suggestions for the improvement of this standard will be welcome. They should be sent to the American Nuclear Society, 555 North Kensington Avenue, La Grange Park, Illinois 60526.

This standard was developed by Working Group ANS-19.6.1 of the American Nuclear Society, which had the active participation of the following members during the period when it approved the standard:

C. T. Rombough, Chairman, *CTR Technical Services, Inc.*  
R. J. Cacciapouti, *Yankee Atomic Electric Company*  
M. Cash, *Duke Power Company*  
M. S. Chatterton, *U.S. Nuclear Regulatory Commission*  
L. R. Grobmyer, *Westinghouse Electric Corporation*  
G. P. Horne, *Duke Power Company*  
R. G. McAndrew, *Virginia Power Company*  
J. L. Perryman, *Florida Power & Light Company*  
J. R. Rec, *ABB Combustion Engineering*  
S. T. Robertson, *B&W Fuel Company*  
E. J. Wunderlich, *Florida Power & Light Company*  
E. H. Young, *Commonwealth Edison Company*

The membership of Subcommittee ANS-19 at the time of its approval of this standard was:

D. M. Cokinos, Chairman, *Brookhaven National Laboratory*  
C. T. Rombough, Secretary, *CTR Technical Services, Inc.*  
S. Baker, *Public Service Electric & Gas Company*  
M. C. Brady, *Sandia National Laboratories*  
R. J. Cacciapouti, *Yankee Atomic Electric Company*  
A. L. Casadei, *Westinghouse CNFD*  
D. J. Diamond, *Brookhaven National Laboratory*  
T. R. England, *Los Alamos National Laboratory*  
D. R. Harris, Jr., *Rensselaer Polytechnic Institute*  
P. B. Hemmig, *U.S. Department of Energy*  
A. I. Jonsson, *ABB/Combustion Engineering*  
J. Katakura, *Japan Atomic Energy Research Institute*  
L. Lois, *U.S. Nuclear Regulatory Commission*  
A. F. McFarlane, *Westinghouse Savannah River Company*  
R. D. Mosteller, *Los Alamos National Laboratory*  
L. D. Noble, *General Electric*  
S. N. Purohit, *Individual*  
R. B. Rothrock, *Oak Ridge National Laboratory*  
M. Salvatores, *CEA-Cadarache DRP/SPRC*  
R. E. Schenter, *Westinghouse Hanford Company*  
E. L. H. Tang, *Westinghouse Hanford Company*  
A. Weitzberg, *Halliburton NUS Corporation*  
W. Wilson, *Los Alamos National Laboratory*  
H. H. Windsor, *ABB/Combustion Engineering*

Consensus Committee N17, Research Reactors, Reactor Physics, Radiation Shielding, and Computational Methods, had the following membership at the time it reviewed and approved this standard:

T. M. Raby, Chairman  
A. Weitzberg, Secretary

A. D. Callihan ..... Individual  
R. E. Carter ..... Individual  
D. Cokinos ..... Brookhaven National Laboratory  
A. De La Paz ..... Vista Technologies  
B. Dodd ..... Health Physics Society  
D. Duffey ..... American Institute of Chemical Engineers  
W. A. Holt ..... American Public Health Association  
W. C. Hopkins ..... Bechtel Corporation  
L. I. Kopp ..... Individual  
J. Miller ..... Institute of Electrical and Electronics Engineers, Inc.  
J. E. Olhoeft ..... Individual  
T. M. Raby ..... American Nuclear Society  
W. J. Richards ..... U. S. Department of Defense  
T. R. Schmidt ..... Sandia National Laboratories  
R. L. Seale ..... University of Arizona  
A. O. Smetana ..... Westinghouse Savannah River Company  
J. F. Torrence ..... National Institute of Standards and Technology  
D. K. Trubey ..... Individual  
S. H. Weiss ..... U. S. Nuclear Regulatory Commission  
    A. Adams, Jr. (Alt.)  
A. Weitzberg ..... Halliburton NUS Corporation  
W. L. Whittemore ..... GA Technologies, Inc.

<b>Contents</b>	<b>Section</b>	<b>Page</b>
	1. Introduction .....	1
	2. Scope .....	1
	3. Definitions .....	1
	3.1 Limitations .....	1
	3.2 Glossary .....	1
	4. Relation to Other Standards .....	2
	5. Physics Test Program and Selection Criteria .....	3
	6. Individual Test Descriptions .....	4
	6.1 General Test Considerations .....	4
	6.2 Critical Boron Concentration—All Rods Withdrawn .....	5
	6.3 Differential Boron Worth .....	5
	6.4 Rod Worth .....	5
	6.5 Isothermal Temperature Coefficient .....	6
	6.6 Flux Symmetry .....	7
	6.7 Power Distribution—Intermediate Power .....	7
	6.8 Power Distribution—Full Power .....	8
	6.9 HZP to HFP Reactivity Difference .....	8
	7. Requirements of This Standard .....	8
	8. References .....	9
 Appendix		
	User's Guide .....	10
 Tables		
	Table 1 Required Physics Test Program .....	3
	Table A.1 Typical Test Criteria .....	12
	Table A.2 Problem Identification .....	27
	Table A.3 Supplementary Tests for Problem Identification .....	28